

Natalie Hill

From: Scott Fraser
Sent: Thursday, January 19, 2017 5:00 PM
To: 'Owen Trepanier'
Cc: Natalie Hill
Subject: DRC Comments Jan. 26, 2045 - Floodplain: 801 Eisenhower Dr.

Floodplain:

- An original of the Elevation Certificate will need to be submitted.
- The elevation measurements on the drawings aren't legible.
- Unable to determine if the building's elevation will change.
- Lattice work covering crawlspace would need to be wooden, not plastic.

Scott

Scott Fraser, CFM - FEMA/CRS Coordinator & Floodplain Administrator
T: 305-809-3810 | sfraser@cityofkeywest-fl.gov | www.CityofKeyWest-FL.gov/Flood
Mailing address: PO Box 1409, Key West, FL 33041-1409
OUR OFFICE HAS RELOCATED TO THE NEW CITY HALL...
Office address: 1300 White St., Key West, FL 33040-4854