



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

---

Development Review Committee  
July 20, 2021  
Utilities Comments

**504-506 Catherine Street**  
**Transient License Transfer**  
No comments.

**1122 Watson Street**  
**Conditional Use**  
No comments.

**1009 South Street**  
**Easement**  
No comments.

**2822 N. Roosevelt Boulevard**  
**Minor Development Plan and Landscape Waiver**

Solid Waste

Please provide a site plan that shows trash and recycling storage area(s).  
In accordance with Sec. 108-279, solid waste storage area(s) are required to be screened from adjacent properties and public view.

Storm Water Management Plan

Please provide a stormwater management plan that provides treatment volume for the parking areas, pursuant to Sec. 108-606 drainage plans for parking surfaces.

Sanitary Sewer

Please provide sewage lift station as-built information, including sump dimensions, pump capacity and rating, and discharge piping and point of connection. Lift station must comply with Florida Building Code: Plumbing Chapter 7.