

Additional Information

MATTINGLY CONSTRUCTION INC.

2932 Harris Ave,

4/06/2017

Key West, Fl. 33040

Cell # 305-797-6435 Fax # 305-296-7402

City of Key West Tree Commission,

To Whom It May Concern;

This letter is in reference to the property located at 1124 Seminary Street and a Spanish Lime tree that has grown beneath the masonry piers supporting the structure and caused major structural damage.

The base of the tree and the root system originate directly beneath two of the existing support piers located at the west side wall of the house and has caused the piers and sill beam to be raised approximately 5". The raising of the sill beam has caused damage to the exterior walls, floor framing and the roof system. The removal of the tree and the root system is the only way of to insure the structural integrity of the building.

I have met with a representative from the tree commission, Karen Demaria, on site, who had taken photographs to document the issue and the damage that the tree and root system has caused.

Should you have any questions or require anything further I may be reached @ 305-797-6435.

Thank You,

Lee Mattingly

Mattingly Construction Inc.







