

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

Development Review Committee September 23, 2021 Utilities Comments

1327 Duval Street Conditional Use

Sanitary Sewer

Grease interceptor will be required for the plumbing discharge line that will serve the food truck.

3841 N. Roosevelt Boulevard Conditional Use No comments.

500 Whitehead Street Conditional Use No comments.

1200 Whitehead Street EasementNo comments.