

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

Development Review Committee December 15, 2022 Utilities Comments

901 Fleming Street Conditional Use

Solid Waste

Please provide a site plan that shows the location for trash and recycle storage containers. Solid waste storage areas must be screened from adjacent properties and public ways. (Sec. 108-279)

Sanitary Sewer

Please provide a grease interceptor for the kitchen plumbing system, including the mop sink, three-compartment sink, and kitchen floor drains, in accordance with the Florida Building Code: Plumbing, Chapter 10, Section 1003. Sewer connections to the grease interceptor shall exclude all non-food wastewater flows. (Sec. 74-171)

1103 Watson Street Easement
No comments.

Vacant Land, Key West Easement
No comments.

21 Quay Road Easement
No comments.