

THE CITY OF KEY WEST 3140 Flagler Ave Key West, FL 33040 (305) 809-3700

TO: Bob Vitas, City Manager

FROM: Janet Muccino, Project Manager

CC: David Fernandez, Asst. City Manager

Jim Bouquet, City Engineer

DATE: June 12, 2014

SUBJECT: Award contract and necessary budget transfers for Fire Station Door Replacement to

Mingo & Company, LLC in the amount of \$101,872.

ACTION STATEMENT:

Approving the contract for the replacement of three roll-up doors at Fire Station #3 & six roll-up doors at Fire Station #1 to Mingo & Company.

This project falls under Infrastructure Goal # 4 of the 2011 Strategic Plan which is the long term sustainability of the City's hard assets.

BACKGROUND:

The Fire Station Door Replacement was competitively bid and the City received one (1) bid from Mingo Construction. The Invitation to Bid included two alternates to the base bid roll-up doors. Alternates included—overhead doors and bi-fold doors. Roll-up doors are currently installed at both stations. The base bid for roll-up doors was \$101,872. The overheads door alternate was bid at \$94,645, No bid was provide for the bi-fold alternate.

FINANCIAL IMPACT:

The Fire Station Door replacement was budgeted in FY 13/14 at \$100,000 from the Infrastructure Surtax Fund (account #101-2201-522-6200). The bid amount of \$101,872 for roll-up doors will require a budget transfer of \$1,872 from the-Infrastructure Surtax Fund Reserves (account # 101-1900-519.94).

PURPOSE & JUSTIFICATION:

The purposes of replacing the existing roll-up doors are:

- 1. The door motors are old and not functioning properly.
- 2. Some doors are twisted and do not roll properly.

The justification for replacing the existing doors with roll-up vs. overhead doors

- 1. Fire Department has requested roll-up doors based on past operational experience.
- 2. Upon further research by the Engineering Department, overhead (sectional) doors will not meet wind load requirements and have a shorter life expectancy than roll-up doors.

OPTIONS:

- 1. Approve award for roll-up doors at \$101,872; doors meet win load requirements.
- 2. Approve award for overhead doors for \$94,645; doors cannot meet wind load.
- 3. Reject the bid by Mingo Construction and rebid.

RECOMMENDATION:

Engineering staff and the Fire Department recommend awarding the contract to Mingo for roll-up doors at Fire Stations 1 & 3 for \$101,872.