

ADDENDUM NO. TWO

ITB 007-16 PRE-ENGINEERED STEEL BUILDING & FOUNDATION ON FLEMING KEY

To All Bidders:

This addendum is issued to as supplemental information to the bid package for clarification of certain matters of both a general and technical nature. The referenced Invitation to Bid is hereby addended, as fully and as completely as if the same were fully set forth therein, in accordance with the following items:

Below questions have been submitted in writing from a potential bidder. Answers are in bold type.

Question:

The Bid Package states several times that the Bidder shall procure and pay for Permit Charges and Fees; however, at the mandatory Pre-Bid meeting it was stated that all Permit Charges and Fees would be waived. Please clarify which statement is correct.

Response:

Contractors doing work in the City of Key West exceeding a period of 30 days are required to obtain City of Key West business (tax) license. Local, state, and federal permit fees will not be required.

Question:

According to the Bid Package, there is a requirement for <u>TWO</u> 20' wide by 14' high sliding doors. At the Mandatory Pre-Bid Meeting it was stated that only <u>ONE</u> 20' wide by 14' high door would be required and ONE walk-in man door. Please indicate which is correct.

Response:

Two (2) sets of sliding doors and one (1) walk-in man door will be required. Walk-in man door may be located in the sliding door or building structure.

Question:

Please confirm that the Bidder is only to furnish Signed and Sealed Engineered Drawings for the Concrete Slab and Foundation Work and the S-type Metal Building and that Civil Drawing with site plan requirements (Storm Water, Parking, Landscaping, Setback, Etc.) are not required.

Response:

Correct. Civil drawings with site plan requirements are NOT required. Signed and sealed engineered drawings for the S-type steel building and concrete slab and foundation, as a combined system, are required.

Question:

The Bid Package mentions the requirement of 4 skylights. I did not see them in the existing building and have my doubts that they would be able to meet the wind load requirements. Are they absolutely required?

Response:

Please omit the skylights. Skylights shall not be required.

Question:

In one area of the Bid Package it states the design criteria as "requirements of the Florida Building Code, Fifth Edition (2014)". In another area of the Bid Package it states the design criteria as Design Wind Loads: Wind loads for Category II structure must meet or exceed 180 miles per hour, and must meet Dade County, Florida Hurricane, Wind Load Specifications. Which design criteria is to be used?

Response:

Design criteria shall meet the requirements of the Florida Building Code, Fifth Edition (2014), alternately design criteria Design Wind Loads: Wind Loads for Category II structure must meet or exceed 180 miles per hour.

Question:

Is "Florida Product Approval Requirement", a requirement of the S-type Metal Building?

Response:

Florida Product Approval Requirement or Miami-Dade County Notice of Acceptance (NOA) are required.

The mandatory pre-bid meeting for the above reference project was held at the Richard A. Heymen Environmental Protection Facility, on December 4, 2015.

Attached: Pre-bid Sign In Sheet

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 2 by acknowledging Addendum in their proposal or by submitting the addendum with their proposal. Proposals submitted without acknowledgement or without this Addendum may be considered non-responsive.

Signature

Name of Business

EMAIL	u.	41 douight nearshare & belsouth. net 46	7 Brad @ begronstruction inet	9 Paulu @ dukiecins, Com		RANDIO, CULLINS & CHIH, CON	307-872-2200 Cbespedrofalcen. com	Masses @ ekicons struction Co M	o muhitreediporter.com	2 justa Cuityof keywest-A.gov	2505 JRURKETE TAMPABAY, FR. COM
PHONE/FAX	305.304.8406 305-872.8898F	9thht-Zhb-Soe. 1662-162-508	(302) +82-526)	205-797-209	(302)296 5606	(zoz) 407-5040	307-872-3	0662-168 (8)	0056-665-146 0078-866-146	305-909-2902	727-573-3
COMPANY	Seatech, Inc.	Nearshae Electric the.	BURKE CONSTRUCTION GEOUP	DN HICEINS	PINOT	CH2 N	PEDRO FALCON CONTRACTORS	ELCI CONSTRUCTION.	D.C. Parter.	City of key West	PJ archaracher (2 727-573-2505
NAME	Ry on La Chapelle	Dught Devore	BAD MORETTI	Paul Wajars	Pareck Outrean	Ricky Collins	50 R	Molses B. Bratati	Robert Blanchare	John Castro	Jonn Burley

SIGN-IN SHEET ITB 007-16 Pre Engineered Steel Building and Concrete Foundation at Fleming Key

Steel Building & Foundation Invitation to Bid 007-16

- 3 -

Addendum No. 2