

## Natalie Hill

---

**From:** Scott Fraser  
**Sent:** Thursday, January 19, 2017 5:00 PM  
**To:** 'Owen Trepanier'  
**Cc:** Natalie Hill  
**Subject:** DRC Comments Jan. 26, 2045 - Floodplain: 801 Eisenhower Dr.

Floodplain:

- An original of the Elevation Certificate will need to be submitted.
- The elevation measurements on the drawings aren't legible.
- Unable to determine if the building's elevation will change.
- Lattice work covering crawlspace would need to be wooden, not plastic.

*Scott*

Scott Fraser, CFM - FEMA/CRS Coordinator & Floodplain Administrator  
T: 305-809-3810 | [sfraser@cityofkeywest-fl.gov](mailto:sfraser@cityofkeywest-fl.gov) | [www.CityofKeyWest-FL.gov/Flood](http://www.CityofKeyWest-FL.gov/Flood)  
Mailing address: PO Box 1409, Key West, FL 33041-1409  
**OUR OFFICE HAS RELOCATED TO THE NEW CITY HALL...**  
Office address: 1300 White St., Key West, FL 33040-4854