



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3883

ADDENDUM NO. 1

PAVEMENT MARKINGS, STRIPING, & ROADWAY SIGNAGE

April 5, 2017

ITB 17-014

This addendum is issued as supplemental information to the bid package for clarification of certain matters of both a general and a technical nature. The referenced Invitation to Bid (ITB) package is hereby amended in accordance with the following items:

Pre-Bid Request for Information:

- 1.) Please advise if the Thermoplastic is of 70 Mils or 90 Mils, my supplier said that the 70 Mil does not exist on FDOT approved products. Please confirm.

Response: Disregard "70 Mil" in the description of all thermoplastic bid items. This includes FDOT Item Numbers 0711-11121, 0711-11123, 0711-11124, 0711-11125, 0711-11160, 0711-11170, 0711-11221, 0711-11223, 0711-11224, 0711-11421, & 0711-11460. Use thickness approved by FDOT for each Bid Item Number.

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 with Attachment by submitting the addendum with their proposal. Proposals submitted without acknowledgement or without this Addendum may be considered non-responsive.

Signature

Name of Business