



Historic Architectural Review Commission Staff Report for Item 5

To: Chairman Bryan Green and Historic Architectural Review
Commission Members

From: Enid Torregrosa, MSHP
Historic Preservation Planner

Meeting Date: October 23, 2018

Applicant: Juan Contin, Architect

Application Number: H17-01-0058

Address: #1317 Grinnell Street

Description of Work

New one-story accessory structure and conversion of rear portion of house into a covered patio.

Site Facts

The building in review is a one and a half-story frame house not listed in the surveys. According to the Property Appraisers records, the house was built in 1963. The Monroe County Library does not have any photographs of the property. City records evidences that the one- story addition located on the north side of the house was an open deck; in 2007, a one-story roof over the deck was built under permit number 07-5290. Under Certificate of Appropriateness 13-01-0127, a request to enclose the cover porch received approval and plans were executed under permit number 13-691. One-story houses surrounds the house in questions.

Guidelines Cited on Review

- New construction (pages 38a-38q); specifically guideline 1, 2, 3, 11, 13, 14, 18, and 23.
- Outbuildings (pages 40-41); specifically guidelines 1, 3, and 9.

Staff Analysis

The Certificate of Appropriateness application in review includes the replacement of an existing accessory frame structure with a new one. The design also includes partial removal of north and east exiting walls in order to create a rear-covered patio.

The new proposed accessory structure will be one-story frame with a hipped roof extending approximately 14' from grade. The structure will be rectangular in footprint and will have board and batten siding, aluminum windows and doors, and metal v-crimp roofing. The structure will be located at the rear yard and behind the existing main house.

The plan also includes the removal of exterior walls of a latter addition in order to create an open patio. This will be at the northeast portion of the house, which faces the rear yard.

Consistency with Guidelines

It is staff's opinion that the proposed design is consistent with the cited guidelines. The new accessory structure will be lower than the main house and is similar in massing and scale with accessory structures found within the surrounding neighborhood. Staff also finds that the opening of the rear portion of the house to create a covered patio will not have any effect on the main house or its historic context.

APPLICATION

Revision

HARC MAJOR PROJECTS CERTIFICATE OF APPROPRIATENESS

\$400 NON-REFUNDABLE BASE APPLICATION FEE - OTHER FEES MAY BE APPLICABLE



City of Key West

1300 WHITE STREET
KEY WEST, FLORIDA 33040

HARC COA # 17-03-58	REVISION #	INITIAL & DATE
FLOOD ZONE	ZONING DISTRICT	BLDG PERMIT #

A PRE-APPLICATION MEETING WITH HARC STAFF IS REQUIRED PRIOR TO SUBMITTAL

ADDRESS OF PROPOSED PROJECT:

NAME ON DEED:

OWNER'S MAILING ADDRESS:

APPLICANT NAME:

APPLICANT'S ADDRESS:

APPLICANT'S SIGNATURE:

1317 Grinnell St. Key West Florida	
Leohr Leslie SR 2002 Trust	PHONE NUMBER 330-416-0500
2247 Rollingwood Dr.	EMAIL dleohr@prideone.cc
Medina Oh 44256	or lleohr@prideone.cc
Doug Leohr / Juan Contin.	PHONE NUMBER 330 416 0500
2247 Rollingwood Dr.	EMAIL dleohr@prideone.cc
Medina Oh 44256	
	DATE

ANY PERSON THAT MAKES CHANGES TO AN APPROVED CERTIFICATE OF APPROPRIATENESS MUST SUBMIT A NEW APPLICATION.

FLORIDA STATUTE 837.06: WHOEVER KNOWINGLY MAKES A FALSE STATEMENT IN WRITING AND WITH THE INTENT TO MISLEAD A PUBLIC SERVANT IN THE PERFORMANCE OF HIS OR HER OFFICIAL DUTY SHALL BE GUILTY OF A MISDEMEANOR OF THE SECOND DEGREE PUNISHABLE PER SECTION 775.082 OR 775.083. THE APPLICANT FURTHER HEREBY ACKNOWLEDGES THAT THE SCOPE OF WORK AS DESCRIBED IN THE APPLICATION SHALL BE THE SCOPE OF WORK THAT IS CONTEMPLATED BY THE APPLICANT AND THE CITY. THE APPLICANT FURTHER STIPULATES THAT SHOULD FURTHER ACTION BE TAKEN BY THE CITY FOR EXCEEDING THE SCOPE OF THE DESCRIPTION OF WORK, AS DESCRIBED HEREIN, AND IF THERE IS CONFLICTING INFORMATION BETWEEN THE DESCRIPTION OF WORK AND THE SUBMITTED PLANS, THE AFOREMENTIONED DESCRIPTION OF WORK SHALL BE CONTROLLING.

PROJECT INCLUDES: REPLACEMENT OF WINDOWS ☐ RELOCATION OF A STRUCTURE ☐ ELEVATION OF A STRUCTURE ☐

PROJECT INVOLVES A CONTRIBUTING STRUCTURE: YES ☐ NO ☒ INVOLVES A HISTORIC STRUCTURE: YES ☐ NO ☒

PROJECT INVOLVES A STRUCTURE THAT IS INDIVIDUALLY LISTED ON THE NATIONAL REGISTER: YES ☐ NO ☒

DETAILED PROJECT DESCRIPTION INCLUDING MATERIALS, HEIGHT, DIMENSIONS, SQUARE FOOTAGE, LOCATION, ETC.

GENERAL: • Renovating and interior for outdoor covered porch
• Demolition of existing cabana at the rear of the building
• Construction of proposed structure at rear of building
(Please refer to submitted plans for specific details)

MAIN BUILDING:

Renovating and interior for outdoor covered porch

DEMOLITION (PLEASE FILL OUT AND ATTACH DEMOLITION APPENDIX):

demolition of existing cabana at rear of building

APPLICATIONS MUST BE SUBMITTED IN PERSON WITH HARD COPIES BY 3PM ON THE SCHEDULED DEADLINE
PLEASE SEND AN ELECTRONIC COPY OF ALL DOCUMENTS TO HARC@CITYOFKEYWEST-FL.GOV

ACCESSORY STRUCTURE(S):

Construction of proposed accessory structure at rear of main building

PAVERS:

FENCES:

DECKS:

PAINTING:

renovate d structure and newly constructed structure will be painted to match main building

SITE (INCLUDING GRADING, FILL, TREES, ETC.):

POOLS (INCLUDING EQUIPMENT):

ACCESSORY EQUIPMENT (GAS, A/C, VENTS, ETC.):

OTHER:

OFFICIAL USE ONLY:

HARC COMMISSION REVIEW

EXPIRES ON:

MEETING DATE:	___ APPROVED ___ NOT APPROVED ___ DEFERRED FOR FUTURE CONSIDERATION	INITIAL:
MEETING DATE:	___ APPROVED ___ NOT APPROVED ___ DEFERRED FOR FUTURE CONSIDERATION	INITIAL:
MEETING DATE:	___ APPROVED ___ NOT APPROVED ___ DEFERRED FOR FUTURE CONSIDERATION	INITIAL:

REASONS OR CONDITIONS:

STAFF REVIEW COMMENTS:

Non historic structures.

FIRST READING FOR DEMO:

SECOND READING FOR DEMO:

HARC STAFF SIGNATURE AND DATE:

HARC CHAIRPERSON SIGNATURE AND DATE:

THIS APPLICATION MAY BE REVIEWED BY PLANNING DEPARTMENT STAFF.

HARC Certificate of Appropriateness: Demolition Appendix



City of Key West

1300 WHITE STREET

KEY WEST, FLORIDA 33040

HARC COA #	INITIAL & DATE
17-03-58	
ZONING DISTRICT	BLDG PERMIT #

ADDRESS OF PROPOSED PROJECT:

1317 Grinnell St Key West FL

PROPERTY OWNER'S NAME:

Lehr Leshe SR 2002 Trust

APPLICANT NAME:

Leslie Lehr

I hereby certify I am the owner of record and that the work shall conform to all applicable laws of this jurisdiction. By receiving a Certificate of Appropriateness, I realize that this project will require a Building Permit approval **PRIOR to proceeding with the work outlined above** and that a final inspection is required under this application. I also understand that **any changes to an approved Certificate of Appropriateness must be submitted for review.**

 PROPERTY OWNER'S SIGNATURE	9/7/18 Leslie Lehr DATE AND PRINT NAME
---	---

DETAILED PROJECT DESCRIPTION OF DEMOLITION

Demolition of existing cabana at rear of main building.

CRITERIA FOR DEMOLITION OF CONTRIBUTING OR HISTORIC STRUCTURES:

Before any Certificate of Appropriateness may be issued for a demolition request, the Historic Architectural Review Commission must find that the following requirements are met (please review and comment on each criterion that applies);

(1) If the subject of the application is a contributing or historic building or structure, then it should not be demolished unless its condition is irrevocably compromised by extreme deterioration or it does not meet any of the following criteria:

(a) The existing condition of the building or structure is irrevocably compromised by extreme deterioration.

(2) Or explain how the building or structure meets the criteria below:

(a) Embodies no distinctive characteristics of a type, period, or method of construction of aesthetic or historic significance in the city and is not a significant and distinguishable building entity whose components may lack individual distinction.

Nothing in this application is intended to alter the authority of the Building Official to condemn for demolition dangerous buildings, as provided in Section 102-218 of the Land Development Regulations and Chapter 14 of the Code of Ordinances.

(b) Is not specifically associated with events that have made a significant contribution to local, state, or national history.

(c) Has no significant character, interest, or value as part of the development, heritage, or cultural characteristics of the city, state or nation, and is not associated with the life of a person significant in the past.

(d) Is not the site of a historic event with significant effect upon society.

(e) Does not exemplify the cultural, political, economic, social, or historic heritage of the city.

(f) Does not portray the environment in an era of history characterized by a distinctive architectural style.

(g) If a part of or related to a square, park, or other distinctive area, nevertheless should not be developed or preserved according to a plan based on the area's historic, cultural, natural, or architectural motif.

(h) Does not have a unique location or singular physical characteristic which represents an established and familiar visual feature of its neighborhood or of the city, and does not exemplify the best remaining architectural type in a neighborhood.

Nothing in this application is intended to alter the authority of the Building Official to condemn for demolition dangerous buildings, as provided in Section 102-218 of the Land Development Regulations and Chapter 14 of the Code of Ordinances.

(i) Has not yielded, and is not likely to yield, information important in history.

CRITERIA FOR DEMOLITION OF NON-CONTRIBUTING OR NON-HISTORIC STRUCTURES:

The following criteria will also be reviewed by the Historic Architectural Review Commission for proposed demolitions. The Commission shall not issue a Certificate of Appropriateness that would result in the following conditions (please review and comment on each criterion that applies);

(1) Removing buildings or structures that are important in defining the overall historic character of a district or neighborhood so that the character is diminished.

Existing cabana is not visible from Grinnell Street, and minimally visible looking through neighbor's backyard on Seminary Street. Therefore, removal of existing cabana would not seem to impact character of neighborhood.

(2) Removing historic buildings or structures and thus destroying the historic relationship between buildings or structures and open space.

Existing cabana is not historic. Removal of cabana would not change historic relationship.

(3) Removing an historic building or structure in a complex; or removing a building facade; or removing a significant later addition that is important in defining the historic character of a site or the surrounding district or neighborhood.

Existing cabana is not important to the historic character of the surrounding neighborhood.

(4) Removing buildings or structures that would otherwise qualify as contributing.

Existing cabana is not a contributing factor to the historic character of the surrounding neighborhood.


SANBORN MAPS



1962 Sanborn Map



PROJECT PHOTOS



Aerial photograph circa 1930.











PROPOSED DESIGN



REAR ELEVATION OF MAIN HOUSE

SCALE : NTS



REAR ELEVATION OF MAIN HOUSE

SCALE : NTS




SOUTH ELEVATION OF EXISTING GAZEBO

SCALE : NTS





WEST ELEVATION OF EXISTING GAZEBO

SCALE : NTS



BUILDING LOCATION MAP

SCALE : NTS



BUILDING LOCATION

SCALE : 1/4" = 1'-0"

GENERAL NOTES:

These drawings have a local state and federal copyright. Juan Contin, Architect, and are property of the. They are not to be used on other projects or extension of this project, except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED: _____

DRAWN BY: _____ JC

CHECKED BY: _____ JC

REVISIONS:

△	_____
△	_____
△	_____
△	_____
△	_____

SCALE/NORTH POINT:

AS SHOWN

DRAWING TITLE

LOCATION PLAN

DRAWING STATUS:

DRAWING NUMBER:

C-02

NOTES


THIS PLANTING PLAN REFLECTS THE EXISTING PLANTS THAT ARE WITHIN CLOSE PROXIMITY OF THE BUILDING FOOT PRINT.PLEASE BE AWARE THAT ALL PLANS WILL REMAIN AND PROTECTED FROM BECOMING DAMAGED.

Plant List

KEY	QTY	BOTANICAL NAME	COMMON NAME	REMARKS
TP	2	Ravenella madagascariensis	Travellers Palm	10'-12' o.a./ full,dense crown/ single head (no suckers)
AM	3	Adonia merillii	Christmas Palm	10'-12' o.a./ full, dense heads/ SINGLE trunk
FP	2	-	-	EXISTING FLOWER POT
EX	1	-	-	EXISTING UNKNOWN TREE TO REMAIN

GENERAL NOTES


1. Contractor shall field verify all site conditions prior to initiating planting installation. All existing planting shall remain intact and undisturbed unless otherwise noted on the plans.
2. Contractor shall familiarize himself/herself with existing site conditions prior to initiating planting. All existing site furnishings, paving, landscape and other elements to remain shall be protected from any damage unless otherwise noted.
3. Report any discrepancies between the construction drawings and field conditions to the owner / architect, Inc. immediately.




NOTES:

1. THE HEIGHT OF THE GREEN FENCE FABRIC SHALL BE MINIMUM 6 FEET.
2. THE FILTER FABRIC SHALL BE PURCHASED IN A CONTINUOUS ROLL CUT TO THE LENGTH OF THE BARRIER TO AVOID THE USE OF JOINTS.
3. POSTS SHALL BE SPACED A MAXIMUM OF 8 FEET APART AT THE BARRIER LOCATION AND DRIVEN SECURELY INTO THE GROUND A MINIMUM OF 24 INCHES WHEN EXTRA STRENGTH FABRIC IS USED WITHOUT THE WIRE SUPPORT FENCE, POST SPACING SHALL NOT EXCEED 6 FEET (1.8 M).
4. A TRENCH SHALL BE EXCAVATED APPROXIMATELY 4 INCHES (10 CM) WIDE AND 4 INCHES (10 CM) DEEP ALONG THE LINE OF POSTS AND UPSLOPE FROM THE BARRIER.
5. WHEN STANDARD STRENGTH FILTER FABRIC IS USED, A WIRE MESH SUPPORT FENCE SHALL BE FASTENED SECURELY TO THE UPSLOPE SIDE OF THE POSTS USING HEAVY DUTY WIRE STAPLES AT LEAST 1 INCH (25 MM) LONG, TIE WIRES, OR HOG RINGS. THE WIRE SHALL EXTEND INTO THE TRENCH A MINIMUM OF 2 INCHES (5 CM) AND SHALL NOT EXTEND MORE THAN 36 INCHES (90 CM) ABOVE THE ORIGINAL GROUND SURFACE.
6. THE STANDARD STRENGTH FILTER FABRIC SHALL BE STAPLED OR WIRED TO THE FENCE, AND 8 INCHES (20 CM) OF THE FABRIC SHALL BE EXTENDED INTO THE TRENCH. THE FABRIC SHALL NOT EXTEND MORE THAN 36 INCHES (90 CM) ABOVE THE ORIGINAL GROUND SURFACE.
7. THE TRENCH SHALL BE BACKFILLED AND THE SOIL COMPACTED OVER THE FILTER FABRIC.
8. ALL PROJECTS REQUIRE SUBMITTAL OF POLLUTION PREVENTION PLAN (PPP).
9. ALL PROJECTS 1 AC. OR MORE MUST SUBMIT NOTICE OF INTENT (NOI) TO FDEP.

GREEN FENCE INSTALLATION DETAIL
Sheet 1 of 2





GREEN FENCE SECTION
NOT TO SCALE



ATTACHING TWO GREEN FENCES
NOT TO SCALE

GREEN FENCE INSTALLATION DETAIL
Sheet 2 of 2



TREE PROTECTION PLAN

SCALE : 1/8" = 1'-0"

GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the. They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

1.
2.
3.
4.
5.

SCALE/NORTH POINT:

AS SHOWN

DRAWING TITLE

TREE PROTECTION PLAN

DRAWING STATUS:

DRAWING NUMBER:

L-01

GENERAL NOTES -FBC 2017

1.

THE CONTRACTOR IS RESPONSIBLE FOR CONTACTING ANY GOVERNMENTAL AGENCIES NECESSARY IN ORDER TO ESTABLISH ANY UTILITY EASEMENTS OR LINES PRESENT WITHIN THE PROPERTY PRIOR TO PERFORMING ANY WORK.
2.

CONCRETE SHALL HAVE 3,000 PSI COMPRESSIVE STRENGTH AT 28 DAYS, UNLESS OTHERWISE NOTED (U.O.N.)
3.

ALL REINFORCING STEEL SHALL BE DEFORMED BARS, AND SHALL HAVE A MINIMUM YIELD STRENGTH OF 60,000 PSI GRADE 60, AND MEET ASTM A-36 SPECS. (OR IF OTHERWISE SPECIFIED)
4.

ALL STRUCTURAL STEEL SHALL HAVE A MINIMUM YIELD STRENGTH OF 36,000 PSI, AND MEET ASTM A-36 SPECS.
5.

ALL DETAILING, FABRICATION AND PLACING OF REINFORCING BARS MUST FOLLOW THE ACI "MANUAL OF STANDARD PRACTICE FOR DETAILING REINFORCED CONCRETE STRUCTURES", U.O.N..
6.

STRUCTURAL DRAWINGS SHALL BE WORKED TOGETHER WITH ARCHITECTURAL, A/C, ELECTRICAL AND MECHANICAL DWGS., TO LOCATE OPENINGS, DRAINS, SLEEVES, SLOPES, DEPRESSED SLABS, BOLTS, CURBS, ETC.
7.

ALL CONCRETE WORK SHALL BE IN ACCORDANCE WITH ACI-301ETC. "SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDINGS."
8.

REMOVAL OF FORMWORK SHALL BE IN ACCORDANCE WITH ACI-347 RECOMMENDED PRACTICE FOR CONCRETE FORMWORK."
9.

DO NOT SCALE DRAWINGS; DIMENSIONS GOVERN.
10.

REBARS SHOWN ON SECTIONS ARE FOR PLACEMENT DETAIL ONLY, SIZE AND AMOUNT OF REBARS ARE AS PER SCHEDULES.
11.

NO TIE BEAMS SHALL BE FORMED/ POURED PRIOR TO TRUSS SHOP DRAWINGS APPROVAL.
12.

WINDOW MANUFACTURER TO VERIFY ALL WINDOW OPENINGS AT FIELD PRIOR TO WINDOW PLACEMENT.
13.

ARCHITECT/INTERIOR DESIGN ENGINEER'S VISITS AT THE SITE DURING CONSTRUCTION SHALL BE SCHEDULED WITH CONTRACTOR BEFORE COMMENCING OF WORK AND DURING CONSTRUCTION SHALL BE COORDINATED WITHIN 48 HOURS IN ADVANCE PRIOR TO INSPECTION.
14.

VERIFY ALL DIMENSIONS ON DRAWINGS AND CONDITIONS AT JOB SITE PRIOR TO COMMENCING WORK. NOTIFY ARCHITECT OR OWNER REPRESENTATIVE OF ANY DISCREPANCIES AND SECURE AN INTERPRETATION OR DECISION FROM THE ARCHITECT BEFORE PROCEEDING WITH THE WORK. DO NOT SCALE DRAWINGS, DIMENSIONS GOVERN.
15.

OBTAIN THE LATEST SET OF DRAWINGS, INCLUDING ANY REVISIONS, BEFORE COMMENCING WORK. NO CHANGES OR SUBSTITUTIONS SHALL BE MADE WITHOUT THE WRITTEN PERMISSION OF THE OWNER/ARCHITECT/INTERIOR DESIGNER.
16.

ALL CONSTRUCTION SHALL BE IN ACCORDANCE WITH APPLICABLE REQUIREMENTS OF THE "FLORIDA BUILDING CODE 2017", CURRENT EDITION. NOTE: ALL LOCAL CODES SHALL PREVAIL.
17.

THE ARCHITECT DOES NOT ACCEPT RESPONSIBILITY FOR THE MISINTERPRETATION OF THESE PLANS BY OTHERS, THE REVIEW AND APPROVAL OF SHOP DRAWINGS PRODUCT CONTROL APPROVAL BY OTHERS.
18.

THE CONTRACTOR IS FULLY RESPONSIBLE FOR ANY ITEMS PURCHASED BY THE OWNER AND GIVEN TO HIM FOR INSTALLATION.
19.

THE CONTRACTOR SHALL NOT PROCEED WITH ANY ADDITIONAL SERVICES OR WORK WITHOUT PRIOR NOTIFICATION TO THE OWNER, FOLLOWED BY A CHANGE ORDER.
20.

THE CONTRACTOR SHALL MAKE REQUIRED ARRANGEMENTS, SECURE AND PAY FOR ALL SANITARY FACILITIES, BARRICADES, ENCLOSURES, AND FENCING AS NEEDED FOR AND DURING THE PROGRESS OF CONSTRUCTION. CONTRACTOR SHALL PROTECT ADJACENT PROPERTIES.
21.

DO NOT SUBSTITUTE MATERIALS, EQUIPMENTS OR METHODS OF CONSTRUCTION UNLESS SUCH SUBSTITUTIONS OR CHANGES HAVE BEEN APPROVED IN WRITING BY THE OWNER/ARCHITECT/ENGINEER.
22.

THE ARCHITECT/INTERIOR DESIGNER/OWNER HAS THE RIGHT TO REFUSE ANY MATERIAL AND WORKMANSHIP THAT DOES NOT MEET HIGH QUALITY STANDARDS OF THE VARIOUS TRADES INVOLVED.
23.

CONTRACTOR SHALL MAINTAIN AN ACCURATE RECORD OF CHANGE ORDERS AND VARIATIONS THROUGHOUT THE PROGRESS OF THE WORK. USE ONE SET OF DOCUMENTS EXCLUSIVELY FOR THIS JOB.
24.

CONTRACTOR SHALL DELIVER THE ANNOTATED JOB RECORD SET TO THE OWNER UPON COMPLETION OF THE WORK, AS A CONDITION OF ACCEPTANCE.
25.

CLEANING AND DEBRIS REMOVAL. THE OWNER SHALL RECEIVE THE PROPERTY FREE FROM DUST, ALL GLASS SURFACES SHALL BE CLEAN AND DEBRIS SHALL BE REMOVED FROM THE SITE. THE CONTRACTOR SHALL MAKE EFFORT TO MAINTAIN THE FLOOR CLEAN DURING CONSTRUCTION PROGRESS. LEFTOVERS FROM MEALS CONSUMED ON PREMISES SHALL BE DEPOSITED IN SEALED CONTAINERS.
26.

THE CONTRACTOR IS SOLELY RESPONSIBLE FOR MEANS AND METHODS OF CONSTRUCTION, AND FOR THE SEQUENCES AND PROCEDURES TO BE USED.
27.

THE ARCHITECTURAL AND STRUCTURAL DRAWINGS SHALL GOVERN THE LOCATIONS OF THE INSTALLATIONS OF THE MECHANICAL AND ELECTRICAL SYSTEM. CONTRACTOR MUST INFORM THE ARCHITECT BEFORE FORMING ANY CONCRETE BEAM IF INTERFERING WITH A/C DUCT OR PLUMBING FIXTURES EXACT LOCATION. ANY DEVIATION FROM THE MECHANICAL/ELECTRICAL PLANS TO ACCOMMODATE THE ABOVE CONDITIONS SHALL BE MADE WITHOUT ADDITIONAL COST TO THE OWNER.
28.

THE CONTRACTOR SHALL PRODUCE, BY MEANS OF SHOP DRAWINGS, ALL ADDITIONAL DETAILS WHICH ARE INFERABLE FROM THESE PLANS AND WHICH ARE NECESSARY FOR THE EXECUTION AND COMPLETION OF THE CONSTRUCTION.
29.

THE CONTRACTOR MUST FURNISH ALL LABOR, TOOLS, MATERIALS AND EQUIPMENT NECESSARY TO EXECUTE THE CONSTRUCTION OF THIS JOB.
30.

UPON ACCEPTANCE AS SUBSTANTIALLY COMPLETE, THE ARCHITECT SHALL ISSUE THE CONTRACTOR A "PUNCHLIST", INDICATING THE OBSERVED DEFICIENCIES IN THE WORK. THE CONTRACTOR SHALL MAKE SUCH CORRECTIONS AND ACHIEVE FINAL COMPLETION WITHIN 14 CALENDAR WORKING DAYS.
31.

ANY OMISSION OF EQUIPMENT INSTALLATIONS AND MATERIALS SHALL BE PROMPTLY RECTIFIED. BY CONTRACTOR UPON NOTIFICATION BY ARCHITECT/ENGINEER/OWNER.
32.

ANY OTHER SERVICES NECESSARY FOR THE COMPLETION OF THIS JOB THAT MAY BE INVOLUNTARY UNDER THE JURISDICTION OF THE FLORIDA BUILDING CODE AND NOT SPECIFIED IN THE "GENERAL NOTES AND OR SPECIFICATIONS" ARE THE CONTRACTOR'S SOLE RESPONSIBILITY.
33.

CONTRACTOR SHALL SUBMIT TO ARCHITECT/ENGINEER & BUILDING DEPARTMENT ALL REQUIRED SHOP DRAWINGS FOR REVIEW AND APPROVAL AS REQUIRED.
34.

ALL GLASS SHOWER AND TUB ENCLOSURES SHALL RECEIVE CATEGORY II. SAFETY GLAZING.
35.

ALL FIXED GLASS SHALL BE 1/4" THICK (U.O.N.)
36.

ALL CEILINGS SHALL BE SEALED SO THAT AIR FLOW FROM SHAFTS, WALL CHASES, CAVITIES AND BETWEEN CONDITIONED AND UNCONDITIONED ATTIC SPACE IS STOPPED.
37.

USE ONLY HIGH HAT LIGHTS WITH SEALED CANS OR SEAL THEM FROM THE ATTIC DRYWALL SO THAT COLD AIR DOES NOT GET INTO THE ATTIC.
38.

ALL DIFFUSERS AND GRILLS SHALL HAVE GASKETTS AND THE FIBERGLASS BOOT CONNECTIONS SHALL BE TIGHT IN ORDER TO PREVENT COLD AIR TO LEAK OUT THROUGHT THE DRYWALL OPENINGS ALLOWING CONDENSATION TO FORM.
39.

DRAFT STOPS SHALL BE SEALED AROUND PIPES AND CONDUITS AT THE TOPS OF ALL INTERIOR PARTITION WALLS SO THAT AIR CANNOT PENETRATE DOWN INTO THE WALLS.
40.

SEAL ALL CEILING SPACES BETWEEN THE CONDITIONED FLOORS FROM OUTSIDE AIR.
41.

PROVIDE THE ABSOLUTE MINIMUM ATTIC VENTILATION, LOCATE THE NECESSARY SOFFIT VENTS ON THE EXPOSURE AWAY FROM THE LOCAL PREVAILING BREEZE.
42.

INSURE THAT ALL INSULATION IS PROPERLY DISTRIBUTED AND INSTALLED WITHOUT GAPS OR IN CONTACT WITH SURFACES THAT TRANSFER AIR.
43.

DO NOT VENTILATE THE ATTIC BY FORCED VENTILATION.
44.

ASSURE THAT ALL FIREPLACE DAMPERS ARE TIGHTLY CLOSED.
45.

INSURE THAT THERE IS NO DUCT LEAKAGE.
46.

KEEP ALL DUCTWORK SEPARATE FROM ALL OTHER DUCTWORK, ATTIC INSULATION, AND BUILDING CONSTRUCTION MATERIALS.
47.

SLABS OVER CRAWLSPACES, UNCONDITIONED SPACES SHALL BE SEALED AND INSULATED UNDERNEATH.
48.

MAINTAIN CONDITIONS IN ATTIC SUCH THAT THE DEW POINT OF THE ATTIC AIR IS HIGHER THAN THE SKIN TEMPERATURE OF THE DUCTWORK AT ALL TIMES.
49.

EXTERIOR AND ADJACENT WALLS SHALL BE SEALED AT THE FOLLOWING LOCATIONS AS PER FLORIDA BUILDING CODE, LATEST EDITION.
- 1.1.a.

BETWEEN WINDOWS AND DOORS AND THEIR FRAMES.
- 1.1.b.

BETWEEN WINDOWS AND DOOR FRAMES AND THE SURROUNDING WALL,
- 1.1.c.

BETWEEN THE FOUNDATION AND WALL ASSEMBLY SILL-PLATES.
- 1.1.d.

JOINTS BETWEEN EXTERIOR WALL PANELS AT CHANGES IN PLANE, SUCH AS WITH EXTERIOR SHEATHING AT CORNERS AND CHANGES IN ORIENTATION.
- 1.1.e.

OPENINGS AND CRACKS AROUND ALL PENETRATIONS THROUGH THE WALL ENVELOPE SUCH AS UTILITY SERVICES AND PLUMBING.
- 1.1.f.

BETWEEN THE WALL PANELS AND TOP AND BOTTOM PLATES IN EXTERIOR AND ADJACENT WALLS. IN FRAME CONSTRUCTION, THE CRACK BETWEEN EXTERIOR AND ADJACENT WALL BOTTOM PLATES AND FLOORS SHALL BE SEALED WITH CAULKING OR GASKET MATERIAL. GYPSUM BOARD OR OTHER WALL PANELING ON THE INTERIOR SURFACE OF XTERIOR AND ADJACENT WALL SHALL BE SEALED TO THE FLOOR, AND (WHEN APPLICABLE)
- 1.1.g.

BETWEEN WALLS AND FLOOR WHERE THE FLOOR PENETRATES THE WALL

GENERAL NOTES:

These drawings have a local state and federal copyright. Juan Contin, Architect. and are property of the. They are not to be used on other projects or extension of this project, except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.




REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC.

CHECKED BY: JC.

REVISIONS:

- △
- △
- △
- △
- △

SCALE/NORTH POINT:

AS SHOWN

DRAWING TITLE

GENERAL NOTES

DRAWING STATUS:


DRAWING NUMBER:

A-00

SCOPE OF WORK

1. THE SCOPE OF WORK IS AS FOLLOW:
- A. DEMOLITION OF THE EXISTING CABANA AS SHOWN IN PLAN AND REPLACE WITH NEW CABANA.
- B. CREATE A COVERED PORCH ON MAIN HOUSE BY UTILIZING PORTION OF THE EXISTING LIVING ROOM AS SHOWN IN PLANS.
2. ALL WORK SHALL BE IN STRICT ACCORDANCE WITH ALL APPLICABLE CODES HAVING JURISDICTION. INCLUDING BUT NOT LIMITED TO:
- STANDARD BUILDING CODE, 2017 EDITION
 - STANDARD MECHANICAL CODE, 2017 EDITION
 - STANDARD PLUMBING CODE, 2017 EDITION
 - NATIONAL ELECTRICAL CODE, 2017 EDITION
 - MONROE COUNTY 2017
- THE CONTRACT DOCUMENTS INCLUDE ARCHITECTURAL, STRUCTURAL, PLUMBING, MECHANICAL, AND ELECTRICAL DRAWINGS. NO PORTION BY ITSELF PROVIDES ALL THE INFORMATION REQUIRED TO PROPERLY COMPLETE THE PROJECT. THEREFORE IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR AND ALL OF HIS SUBCONTRACTORS TO THOROUGHLY FAMILIARIZE THEMSELVES WITH THESE DRAWINGS AND TO COORDINATE THE INFORMATION CONTAINED THEREIN TO PROPERLY AND SUCCESSFULLY CONSTRUCT THE PROJECT.

KEY




SITE DATA TABLE

ZONE	SINGLE FAMILY RESIDENTIAL DISTRICT (SF)		
	REQUIRED	EXISTING	PROPOSED
LOT SIZE	6,000 SF (MIN.)		7,507 SF
BUILDING COVERAGE	35% (MAX) 2,627 SF	2,465 SF	2,537 SF
PERVIOUS VS IMPERVIOUS			
TOTAL IMPERVIOUS AREA	50% (MAX) 3,753 SF	3,305 SF	3,411 SF
MAIN HOUSE			
BUILDING COVERAGE		2,391 SF	2,391 SF
FRONT SETBACK	30' OR AVG. WITHIN 100' NOT LESS THAN 20'	29'	
SIDE SETBACK (WEST)	5'	13'-9"	
SIDE SETBACK (EAST)	5'	6'-6"	
REAR SETBACK	25'	28'-7"	
BUILDING HEIGHT	25' MAXIMUM	23'-7"	
ACCESSORY STRUCTURE			
BUILDING COVERAGE		203 SF	276 SF
FRONT SETBACK		71'-10"	69'-2"
SIDE SETBACK (WEST)	5'	7'-0"	5'
SIDE SETBACK (EAST)	5'	63'-0"	62'-6"
REAR SETBACK	5'	5'	5'
BUILDING HEIGHT	25' MAXIMUM	12'-0"	12'-0"
OTHER IMPERVIOUS AREA			
WALKWAY		116 SF	140 SF
POOL DECK		595 SF	595 SF
A/C PAD			9 SF

LEGAL DESCRIPTION-

On the Island of Key West and known on William A. Whitehead's map of said Island delineated in February, A.D. 1829, as Part of the Tract Eighteen (18), but better known as Part of Lots Four (4) and Five (5), in Square Seven (7) of said Tract Eighteen (18), according to the Plat of Webb Realty Company recorded In Plat Book One (1) on Page Forty-two (42), Monroe County, Florida Records. Commencing at a point Fifty-two (52) feet and Six (6) inches from the corner of South and Grinnell Streets and run thence in a Northeasterly direction Ninety-two (92) feet, thence at right angles in a Northwesterly direction Eighty-one (81) feet; thence at right angles in a Southeasterly direction Eighty-one (81) feet and Tree (3) Inches to the Point of Beginning



GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the. They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

1 7-24-2018

2 9-7-2018

SCALE/NORTH POINT:

AS SHOWN


DRAWING TITLE

SITE PLAN

DRAWING STATUS:

DRAWING NUMBER:

A-01



SITE PLAN

SCALE : 1/8" = 1'-0"

NOTES



- 1. G.C TO COORDINATE DEMOLITION WITH THE OWNER REGARDING ITEMS TO BE SALVAGED.
- 2. G.C TO COORDINATE WITH ARCHITECT IF EXISTING CONDITIONS REQUIRE WORK NOT SHOWN OR NOT VISIBLE, CONTRACTOR IS TO CONTACT THE ENGINEER/OWNER PRIOR TO CONTINUING.
- 3. G.C TO FIELD VERIFY ALL DIMENSION AFTER DEMOLITION WITH REGARDS TO THE PROPOSED PLANS.
- 4. ALL REPLACEMENT FINISHES SUCH AS BUT NOT LIMITED TO FLOORING, WALLS AND CEILING TO MATCH EXISTING.

GENERAL DEMOLITION NOTES

- 1. ALL WORK SHALL BE PERFORMED IN STRICT ACCORDANCE WITH ALL APPLICABLE CODES HAVING JURISDICTION.
- 2. THE INTENT OF THE SCOPE OF WORK IS TO REMOVE THE SELECTIVE INTERIOR AND EXTERIOR WALLS DOWN TO ORIGINAL BUILDING SUBSTRATE. ALL OTHER EXTERIOR WALL, INTERIOR FINISHES, CEILING AND FLOORS TO REMAIN AND PROTECTED FROM BECOMING DAMAGED. ALL EXISTING MECHANICAL AND ELECTRICAL LINES, SYSTEMS EQUIPMENT BEING UTILIZED ARE TO REMAIN.
- 3. ADDITIONAL DEMOLITION INCLUDES BUT IS NOT LIMITED TO SELECTIVE REMOVAL AND SUBSEQUENT DISPOSAL OF THE FOLLOWING:
 - KITCHEN CABINETS, KITCHEN EQUIPMENTS, SHELVES.
 - REMOVAL OF DOORS AND FRAMES.
 - REMOVAL OF PLUMBING FIXTURES AND ABANDONED PIPING ONLY.
 - CUT AND CAP ELECTRICAL AND MECHANICAL WIRES AND A.C DEFUSE PER PROPOSED PLAN.
- COORDINATE DEMOLITION WITH ALL TRADES TO ASSURE COMPLETE REMOVAL OF ITEMS TO BE DEMOLISHED AND COMPLETE PROTECTION OF AREAS NOT IN DEMOLITION.
- G.C SHALL BE RESPONSIBLE TO PROVIDE TEMPORARY STRUCTURAL SUPPORT TO ROOF/FLOOR STRUCTURE DURING CONSTRUCTION.
- PROTECT FROM DAMAGE EXISTING WORK THAT IS TO REMAIN IN PLACE AND BECOMES EXPOSED DURING DEMOLITION OPERATIONS.
- FEDERAL AND STATE REGULATIONS STATE THAT ALL BUILDINGS SCHEDULED FOR DEMOLITION BE INSPECTED BY THE PALM BEACH COUNTY OFFICE OF ENVIRONMENTAL CONTROL FOR FRIABLE ASBESTOS. IN ADDITION TO THE REQUIRED INSPECTION, A WRITTEN NOTICE OF INTENT TO DEMOLISH MUST BE FILED WITH THE APPROPRIATE REGULATORY AGENCY. THIS NOTIFICATION IS REQUIRED EVEN IF THE BUILDING IS FREE OF ASBESTOS. NOTIFICATION AS OUTLINED BY THE NATIONAL EMISSION STANDARDS OF HAZARDOUS AIR POLLUTANTS, ASBESTOS NOTIFICATIONS REQUIREMENTS, BUILDING DEMOLITION/RENOVATION MUST BE COMPLETED BY THE CONTRACTOR.
- ALL ELECTRICAL AND MECHANICAL EQUIPMENT AND SYSTEMS SHALL BE OPERATED IN THE PRESENCE OF REPRESENTATIVES OF THE CONTRACTOR AND REPRESENTATIVES OF THE OWNER PRIOR TO ANY DEMOLITION, OR PRIOR TO DISCONNECTING ANY ELECTRICAL WIRING IN ORDER TO ESTABLISH THAT ALL SYSTEMS ARE IN PROPER WORKING ORDER AT THE START OF THE PROJECT. THIS WOULD ESTABLISH THE DEGREE OF RESPONSIBILITY THAT THE CONTRACTOR WILL HAVE WHEN HE IS REQUIRED TO PLACE THESE SYSTEMS BACK IN WORKING ORDER AT THE END OF THE PROJECT. IF UNANTICIPATED MECHANICAL, ELECTRICAL, OR STRUCTURAL ELEMENTS WHICH CONFLICT WITH THE INTENDED FUNCTION OR DESIGN ARE ENCOUNTERED, INVESTIGATE AND MEASURE BOTH NATURE AND EXTENT OF THE CONFLICT AND NOTIFY THE OWNER'S REPRESENTATIVE, ARCHITECT OR RESPECTIVE ENGINEER FOR DIRECTIVE. PROTECT ALL ACTIVE PLUMBING, ELECTRICAL, MECHANICAL LINES AND SYSTEMS TO REMAIN OPERATIVE AND EXPOSED INTO VIEW.
- REMOVE ALL ABANDONED PLUMBING, ELECTRICAL AND MECHANICAL LINES NOT IN USE. MAINTAIN EXISTING FIRE SEPARATION SEALANT AND CAULKING AT ALL FLOOR, CEILING AND WALL PENETRATIONS INTO ADJACENT OCCUPIED SPACES.

DEMOLITION LEGEND			
	EXISTING FRAME WALLS TO REMAIN		EXISTING AREA TO BE PROTECTED FROM BECOMING DAMAGE
	EXISTING FRAME WALLS TO BE REMOVED		
	EXISTING DOORS TO BE REMOVED AND REUSED WHERE NOTED		
	EXISTING DOORS TO REMAIN		

- 1WOODS & PLASTIC
- 1.1 REMOVE WOOD SIDING AND STRUCTURE DOWN TO FLOORING.
G.C SHALL BE RESPONSIBLE TO TEMPORARY SUPPORT STRUCTURE DURING CONSTRUCTION.
- 2DOORS & WINDOWS
- 2.1 REMOVE AND RELOCATE DOOR AS PER PROPOSED PLAN
- 2.2 REMOVE AND RELOCATE WINDOW AS PER PROPOSED PLAN
- 2.3 REMOVE AND PROPERLY STORE WINDOW FOR FUTURE USE



EXISTING LEVEL 1 FLOOR PLAN

SCALE : 1/4" = 1'-0"

GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

- 1
- 2
- 3
- 4
- 5

SCALE/NORTH POINT:

AS SHOWN



DRAWING TITLE

EXISTING FLOOR PLAN

DRAWING STATUS:

DRAWING NUMBER:

A-02



GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.




REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:	
△	
△	
△	
△	
△	

SCALE/NORTH POINT:

AS SHOWN

DRAWING TITLE

EXISTING ELEVATION

DRAWING STATUS:


DRAWING NUMBER:

A-03

DOOR SCHEDULE									
MARK	DOOR SIZE	ROUGH OPEN.	MAT'L	TYPE	GLASS	HARDWARE		NOTES	
						LEVER	HINGE		
D1	4'-6" X 7'-0"	SEE MANUFACTURER	AL	SW	-	-	-	REUSED EXISTING.	
D2	2'-6" X 7'-0"	SEE MANUFACTURER	AL	SW	-	-	-		
D3	6'-0" X 7'-0"	SEE MANUFACTURER	AL	SL	-	-	-		
D4	2'-8" X 7'-0"	SEE MANUFACTURER	HW	SW	-	-	-		
D5	2'-8" X 7'-0"	SEE MANUFACTURER	HW	SW	-	-	-		
LEGEND: AL ALUMINUM AL/GL ALUMINUM & GLASS HM HOLLOW METAL WD WOOD (SOLID CORE) HW WOOD (HOLLOW CORE)									
DOOR NOTES: 1. EXTERIOR H.M. DOORS SHALL BE GALV. STEEL 2. EXTERIOR H.M. DOORS TO A/C SPACES SHALL BE INSULATED									
DOOR TYPES									

WINDOW SCHEDULE									
MARK	QTY.	WINDOW SIZE WIDTH X HEIGHT	ROUGH OPENING WIDTH X HEIGHT	DESCRIPTION			TYPE	REMARKS	
				ELEV.	MAT'L	GLASS			
W-101	1	4'-0" X 4'-0"	SEE MANUFACTURER		AL	8'-0"	C		
W-102	1	3'-10" X 4'-0"	SEE MANUFACTURER		AL	8'-0"	C		
W-103	1	2'-0" X 2'-10"	SEE MANUFACTURER		AL	8'-0"	SH		
W-104	1	3'-4" X 2'-10"	SEE MANUFACTURER		AL	8'-0"	SH		
W-105							C	REUSED EXISTING.	
W-106							C	REUSED EXISTING.	
WINDOW TYPES									

BUILDING SQUARE FOOTAGE		
MAIN HOUSE		
DESCRIPTION:	UNDER AIR	NOT UNDER AIR
FIRST & SECOND FLOOR	2,205	
PORCH AND TERRACE		814 SQ. FT.
TOTAL		3,019 SQ. FT.
CABANA		
DESCRIPTION:	UNDER AIR	NOT UNDER AIR
CABANA	276 SQ. FT.	
PORCH		114 SQ. FT.
TOTAL		390 SQ. FT.



PROPOSED LEVEL 1 FLOOR PLAN
SCALE : 1/4" = 1'-0"


GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the. They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.



REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN
FL LICENSE # AR94935
826 S. FEDERAL HIGHWAY
LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET
KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

- △
- △
- △
- △
- △

SCALE/NORTH POINT:

AS SHOWN

DRAWING TITLE

PROPOSED FLOOR PLAN

DRAWING STATUS:

DRAWING NUMBER:

A-04



M A I N H O U S E & C A B A N A F R O N T E L E V A T I O N (S O U T H)

SCALE : 1/4" = 1'-0"



M A I N H O U S E & C A B A N A S I D E E L E V A T I O N (W E S T)

SCALE : 1/4" = 1'-0"

GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

- △
- △
- △
- △
- △

SCALE/NORTH POINT:

AS SHOWN


DRAWING TITLE

PROPOSED ELEVATION

DRAWING STATUS:

DRAWING NUMBER:

A-05



ACCESSORY STRUCTURE (EAST)

SCALE : 1/4" = 1'-0"



MAIN HOUSE & CABANA REAR ELEVATION (NORTH)

SCALE : 1/4" = 1'-0"

GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

△	
△	
△	
△	
△	

SCALE/NORTH POINT:

AS SHOWN





DRAWING TITLE

PROPOSED ELEVATION

DRAWING STATUS:

DRAWING NUMBER:

A-5.1



STRUCTURAL PLAN

SCALE : 1/4" = 1'-0"

GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA


DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:



SCALE/NORTH POINT:

AS SHOWN


DRAWING TITLE

PROPOSED FRAMING PLAN

DRAWING STATUS:


DRAWING NUMBER:

S-01




1
S-02 SECTION DETAIL

SCALE : 1/2" = 1'-0"



2
S-02 SECTION DETAIL

SCALE : 1/2" = 1'-0"




3
S-02 SECTION DETAIL

SCALE : 1/2" = 1'-0"

GENERAL NOTES:
These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.



REGISTERED ARCHITECT:
JUAN CRISTOBAL CONTIN
FL LICENSE # AR94935
826 S. FEDERAL HIGHWAY
LAKE WORTH, FL 33460



CLIENT:
LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:
1317 GRINNELL STREET

PROJECT ADDRESS:
1317 GRINNELL STREET
KEY WEST, FLORIDA

DATE: 16 JULY, 2018
ISSUED:
DRAWN BY: JC
CHECKED BY: JC

REVISIONS:	
△	
△	
△	
△	
△	

SCALE/NORTH POINT:
AS SHOWN

DRAWING TITLE
WALL SECTION DETAIL

DRAWING STATUS:

DRAWING NUMBER:
S-02

STRUCTURAL DESIGN CRITERIA & CODES

THIS STRUCTURE HAS BEEN DESIGNED IN ACCORDANCE WITH THE FLORIDA BUILDING CODE FBC 2017.

WIND LOADS ARE BASED ON THE ANSI/ASCE 7-10 MINIMUM DESIGN LOADS FOR BUILDINGS AND OTHER STRUCTURES. ALL PRIMARY FRAMING AND EXTERIOR ENVELOPE COMPONENTS AND CLADDING SHALL BE DESIGNED AND CONSTRUCTED TO RESIST THE LOADS AND FORCES DERIVED FROM THIS STANDARD.

GRAVITY DESIGN LOADINGS FOR THIS PROJECT ARE AS FOLLOWS:



STAIR DEAD LOAD,	100	PSF	FLOOR DEAD LOAD:	20PSF
STAIR LIVE LOAD,	100	PSF	FLOOR LIVE LOAD:	50PSF
TERRACE DEAD LOAD,	20	PSF	ROOF DEAD LOAD:	20PSF
TERRACE LIVE LOAD,	50	PSF	ROOF LIVE LOAD:	30PSF

WIND DESIGN CRITERIA
ULTIMATE DESIGN WIND SPEED, Vult: 170MPH (3-SECD GUST)
NOMINAL DESIGN WIND SPEED, Vest: 132MPH (3-SECD GUST)
RISK CATEGORY: II
EXPOSURE: C
IMPORTANCE FACTOR: 1=1.0
EDGE ZONE DIMENSION: A=4'



ACTUAL PRESSURES FOR SPECIFIC COMPONENTS AND CLADDING MATERIALS SHALL BE CALCULATED BASED ON THE SPECIFIC TRIBUTARY AREA (IN SQ. FT.) CONSIDERED.

MAIN BUILDING
BASIC VELOCITY PRESSURE: 32.03 PSF
INT. PRESSURE COEFFICIENT: +0.18
"a" DIMENSION: 4.0'

COMPONENTS AND CLADDING								
ZONE								
	1 S.F.	2-10	11-20	21-30	31-40	41-50	51-50	>100
ROOF 1	+21.78 -34.59							
ROOF 2/2 O.H	+21.78 -70.78							
ROOF 3/3 O.H	+21.78 -118.51							
WALLS 4	+34.84 -38.04	+34.84 -38.04	+34.84 -38.04	+34.84 -38.04	+34.39 -37.59	+33.84 -37.04	+32.14 -35.34	+32.14 -35.34
WALLS 5	+34.84 -44.69	+34.84 -44.69	+34.84 -44.69	+34.84 -44.69	+34.84 -43.80	+34.39 -42.70	+33.84 -39.29	+32.14 -39.29



TYPICAL ROOF ZONE



GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

△	
△	
△	
△	
△	

SCALE/NORTH POINT:

AS SHOWN











DRAWING TITLE

ROOF FRAMING PLAN

DRAWING STATUS:

DRAWING NUMBER:

S-03

							
1	— N.T.S.	2	— N.T.S.	3	— N.T.S.	4	HEAD DETAIL (WINDOW) N.T.S.
6	— N.T.S.	7	— N.T.S.	8	— N.T.S.	9	— N.T.S.
							
11	End Wall N.T.S.	12	COLUMN AND BEAM ATTACHEMENT N.T.S.	13	COLUMN BASE ATTACHMENT N.T.S.	14	HEAD/JAMB DETAIL (DOOR) N.T.S.
							
16	EAVE FLASHING N.T.S.	17	PIPE BOOT DETAIL N.T.S.	19	PORCH RAIL DETAIL N.T.S.	20	WINDOW DETAIL (TYP.) SCALE = 1/2" = 1'-0"

GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

- △
- △
- △
- △
- △

SCALE/NORTH POINT:

AS SHOWN

DRAWING TITLE

STRUCTURAL DETAILS


DRAWING STATUS:

DRAWING NUMBER:

S-04


PLUMBING NOTES

- 1. INSTALLATION SHALL BE IN ACCORDANCE WITH THE FLORIDA BUILDING CODE 2017, AND ALL LOCAL CODES.
- 2. ALL MATERIALS SHALL BE NEW AND CODE APPROVED.
- 3. VERIFY ALL EXISTING SANITARY AND WATER CONDITIONS IN THE BUILDING. ALL NEW DOMESTIC WATER PIPING SHALL BE COPPER. ALL NEW SANITARY PIPING SHALL HUBLESS C.J. OR PVC. AS REQUIRED TO INTEGRATE WITH EXISTING PIPING.
- 4. THE PLUMBING SUB-CONTRACTOR SHALL FURNISH A WRITTEN GUARANTEE THAT PLUMBING WORK IS FREE FROM DEFECTS IN MATERIALS AND WORKMANSHIP FOR A PERIOD OF ONE YEAR FROM THE DATE OF ACCEPTANCE BY OWNER. REPAIR OR REPLACE ALL WORK WHICH BECOMES DEFECTIVE AT NO COST TO OWNER.
- 5. PLUMBING SUB-CONTRACTOR SHALL PROVIDE REQUIRED PERMITS.
- 6. INSTALL PLUMBING FIXTURES AS INDICATED ON THESE PLANS. COMPLETE SYSTEM, FIXTURES AND DEVICES SHALL BE GIVEN AN IN-SERVICE TEST AFTER COMPLETION OF INSTALLATION.
- 7. ALL EXCAVATION AND BACKFILL AS REQUIRED FOR THIS PHASE OF CONSTRUCTION, SHALL BE PART OF THIS CONTRACT.
- 8. BUILDING DRAINAGE SYSTEM IS BASED ON 1/8" / FT. MIN. FALL. ALL DEVIATIONS SHALL BE APPROVED BY THE ARCHITECT / ENGINEER. 2 1/2" AND SMALLER PIPE SHALL PITCH AT 1/4" PER FOOT.
- 9. DO NOT SCALE FOR THE EXACT FIXTURES, PIPING , EQUIPMENT ETC.
- 10. ALL WORK SHALL BE COORDINATED WITH OTHER TRADES TO AVOID INTERFERENCE WITH PROGRESS OF CONSTRUCTION.
- 11. WATER PIPING SHALL BE TYPE "L" COPPER WITH WROUGHT SOLDER FITTINGS. UNDERGROUND PIPING MAY BE TYPE "M" WITH PROPER SLEEVING AND NO JOINTS BELOW SLAB.
- 12. FURNISH AND INSTALL APPROVED SHOCK ABSORBERS AND SHUTOFF VALVES WITH ACCESS PANELS AT EACH FIXTURE GROUP.
- 13. PLUMBING SUB-CONTRACTOR SHALL PROVIDE ACCURATE RED-LINE (OR BETTER) AS-BUILT DRAWINGS TO ARCHITECT / OWNER PRIOR TO FINAL SIGNING-OFF OF PROJECT.
- 14. THESE PLANS ARE BASED ON AVAILABLE INFORMATION. VERIFY EXACT LOCATION OF EXISTING WATER AND SEWER PROVISIONS.
- 15. COORDINATE TIE-IN OF GAS PIPING WITH GAS SUPPLIER.



SANITARY RISER DIAGRAM

SCALE : NTS




POTABLE WATER RISER

PLUMBING NOTE: WATER HAMMER ARRESTORS ARE TO BE INSTALLED ACCORDING TO MANUP. INSTRUCTIONS AND WH-PAI-201

--- COLD WATER

--- HOT WATER

NOTE: PROVIDE APPROPRIATELY SIZED SHUT-OFF VALVES AT ALL FIXTURES AND EQUIPMENT



PLUMBING PLAN

SCALE : 1/4" = 1'-0"

LEGEND:

- SANITARY LINE
- DRAIN
- VENT
- P(X) PLUMBING FIXTURE
- COLD WATER LINE
- HOT WATER LINE
- HB HOSE BIBB
- C.O. CLEAN OUT
- GAS HOT WATER HEATER

PLUMBING FIXTURE SCHEDULE				
MARK	DESCRIPTION	MANUFACTURER	MODEL #	DESCRIPTION
P1	LAVATORY	-	-	FINAL SELECTION BY OWNER
P2	TOILET	-	-	FINAL SELECTION BY OWNER
P3	BUILT IN SHOWER	-	-	FINAL SELECTION BY OWNER
P4	KITCHEN SINK	-	-	PLEASE NOTE THAT BOTH SANITARY AND POTABLE WATER LINE EXISTING FINAL SELECTION OF BY OWNER

* BASIS OF DESIGN - COORDINATE ALL FINAL SELECTIONS W/ OWNER & G.C.

GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

- △
- △
- △
- △
- △

SCALE/NORTH POINT:

AS SHOWN

DRAWING TITLE

PLUMBING PLAN


DRAWING STATUS:

DRAWING NUMBER:


P-01

2
EQUIPMENT SCHEDULE & LEGEND

- 3
GENERAL TYPING NOTES



EQUIPMENT SCHEDULE & LEGEND



FIRST FLOOR HVAC PLAN

Scale: $1/4" = 1'-0"$

M.1

GENERAL NOTES:

These drawings have a local state and federal copyright Juan Contin, Architect. and are property of the They are not to be used on other projects or extension of this project except by written agreements with Juan Contin, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contin, Architect.

CONTIN
ARCHITECTURE + DESIGN


REGISTERED ARCHITECT:

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

826 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



CLIENT:

LEOHR LESLIE S R 2002 TRUST

PROJECT TITLE:

1317 GRINNELL STREET

PROJECT ADDRESS:

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED:

DRAWN BY: JC

CHECKED BY: JC

REVISIONS:

△	
△	
△	
△	
△	

SCALE/NORTH POINT:

AS SHOWN

DRAWING TITLE



ELECTRICAL PLAN

DRAWING STATUS:

DRAWING NUMBER:

E-01

ELECTRIC SYMBOL LEGEND			
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	FLUORESCENT LIGHT FIXTURE		EXHAUST FAN (DUCTED) WITH LIGHT
	SWITCHED WALL OUTLET		SURFACE MOUNTED LIGHT FIXTURE w/ VAPOR BARRIER
	GROUND FAULT INTERRUPTER WALL OUTLET		EYEBALL
	WATER PROOF WALL OUTLET		RECESSED LIGHT FIXTURE (HI HAT)
	WALL OUTLET		SURFACE MOUNTED INCANDESCENT FIXTURE
	20A, 120V SINGLE RECEPTACLE GROUNDING TYPE U.O.N. MOUNTED 18" AFF		LED TASK LIGHT
	220 WALL OUTLET		SURFACE MOUNTED INCANDESCENT FIXTURE
	240 WALL OUTLET & SPECIAL PURPOSE RECEPTACLE		WALL MOUNTED INCANDESCENT FIXTURE
	WALL OUTLET BOX & SINGLE POLE SWITCH - 20 AMP		EXTERIOR LED UP LIGHTS
	WALL OUTLET BOX & 3-WAY SWITCH - 20 AMP		SMOKE DETECTOR
	WALL OUTLET BOX & 4-WAY SWITCH - 20 AMP		TELEPHONE JACK
	CEILING MOUNTED PREWIRED GARAGE DOOR OUTLET		WALL HUNG TELEPHONE JACK
	SWITCH WITH CONVENIENCE OUTLET		T.V. OUTLET - COORDINATE W/ LOCAL CABLE COMPANY
	REOSTAT (DIMMER SWITCH)		PUSH BUTTON
	DISCONNECT		CHIMES
	ELECTRIC METER		GARAGE DOOR OPENER
	ELECTRIC PANEL		
	CEILING FAN JUNCTION BOX		



ELECTRICAL PLAN

SCALE : 1/4" = 1'-0"

1. COOLING AND HEATING LOADS ARE NOT CONCURRENT.
2. PROVIDE ALL FINAL CONNECTIONS TO ALL EQUIPMENT AND APPLIANCES.
3. PROVIDE ALL A/C CONTROL IN SEPARATE 1/2" AS REQUIRED BY A/C DRAWINGS OR MANUFACTURER DIAGRAMS.
4. ALL LAVATORIES AND KITCHEN RECEPTACLES TO BE GFI TYPE.
5. TERRACE RECEPTACLES TO BE GFI TYPE.
6. COORDINATE LOCATION OF ALL DISCONNECT SWITCHES WITH OTHER TRADES TO ALLOW N.E.C. REQUIREMENTS CLEARANCES.
7. CIRCUIT WIRING REQUIRED TO BE AS FOLLOWS: 120V-2 WIRE (L-N); 120/240V - 3 WIRE (LL-N); 240V - 2 WIRE (L-L) WHEN EQUIPMENT GROUND IS REQUIRED INCREASE CIRCUIT SIZE AS REQUIRED.
8. ALL WIRING TO BE COPPER, THHN/THWN TYPE RUN IN METALLIC CONDUIT OR ROMEX CABLE IF AHJ APPROVED.
9. ALL COUNTER RECEPTACLES AND SWITCHES TO BE MOUNTED +6" ABOVE COUNTER (TO BOTTOM OF PLATE). UNLESS OTHERWISE NOTED DIFFERENT ON PLANS.
10. REFRIGERATOR RECEPTACLE TO BE MOUNTED +60" A.F.F.
11. ALL LAVATORY RECEPTACLES TO BE MOUNTED +42" A.F.F. UNLESS OTHERWISE NOTED DIFFERENT ON PLANS.
12. COORDINATE LOCATION OF AIR CONDITIONER (INDOOR UNIT) DISCONNECT SWITCH WITH A/C CONTRACTOR TO KEEP N.E.C. REQUIRED CLEARANCE.
13. KITCHEN TELEPHONE OUTLET TO BE MOUNTED +60" A.F.F.
14. ALL DUPLEX RECEPTACLES IN EXTERIOR AREAS TO BE OF WP, GFI TYPE
15. PROVIDE EMPTY CONDUITS AS REQUIRED FOR TELEPHONE AND TV. SYSTEMS.
16. OUTDOOR UNDERGROUND CONDUITS SHALL BE SCHEDULE 40 PVC UNDER PAVED AREAS IT SHALL BE ENCASED IN CONCRETE. MINIMUM COVER SHALL BE 24 INCHES. A GROUNDING CONDUCTOR PROPERLY SIZED MUST BE INSTALLED AS PER N.E.C. 250 IF PVC IS USED.
17. OUTLET BOXES SHALL BE PRESSED STEEL IN DRY LOCATIONS CAST ALLOY W/THREADED HUBS IN WET OR DAMP LOCATIONS AND SPECIAL ENCLOSURES FOR OTHER CLASSIFIED AREAS.
18. MOTOR STARTERS SHALL BE MANUAL OR MAGNETIC, WITH OVERLOAD RELAYS IN EACH HOT LEG.
19. ELECTRICAL SYSTEM SHALL BE COMPLETELY & EFFECTIVELY GROUNDED AS REQUIRED BY THE LATEST EDITION OF THE N.E.C. PROVIDE PROPER SIZE AND TYPE OF PROTECTION DEVICES TO MATCH EQUIPMENT SERVED.
20. MINIMUM WIRE SIZE SHALL BE #12 THHN/THWN.
21. ALL CONDUCTORS SHALL BE COPPER.
22. CONDUIT IN FINISHED AREAS SHALL BE CONCEALED.
23. CONDUIT IN UNFINISHED AREAS SHALL BE EXPOSED.
24. FUSES SHALL BE DUAL ELEMENT, TIME DELAY TYPE.
25. INSTALL NYLON PULL STRINGS IN ALL EMPTY CONDUITS FOR FUTURE USE.
26. ALL MATERIALS SHALL BE U.L. APPROVED.
27. WORKMANSHIP SHALL BE TO BEST RESIDENTIAL PRACTICE.
28. ALL LIGHT FIXTURES TO BE SELECTED BY OWNER/ARCHITECT AND INSTALLED BY CONTRACTOR
29. RECESSED LIGHT FIXTURES OVER BATHTUB OR SHOWER SHALL BE COMPLETELY ENCLOSED AND VAPOR PROOF SUITABLE FOR WET LOCATIONS.
30. ALL LUMINAIRES SHALL BE PROPERLY SUPPORTED IN ACCORDANCE WITH THE CEILING SYSTEM MANUFACTURER RECOMMENDATIONS AND LOCAL CODES AND REQUIREMENTS.

- RESIDENTIAL ELECTRICAL CODE NOTES:

1. LIGHTING FIXTURES AND COLORS AS SELECTED BY ARCHITECT/ OWNER
2. E.C. TO PROVIDE COUNTER SPACE RECTANGLES 6ft AS PER 210.52C.1 @ 48" O.C (TYP).
3. ALL APPLIANCES DISCONNECTS TO BE ACCESSIBLE AS PER NEC 422 (TYP)
COORDINATE WITH OTHER TRADES TO PROVIDE CLEARANCES AS REQUIRED.
4. VERIFY ALL ELECTRICAL OUTLETS, PHONE AND DATA LOCATIONS WITH ARCHITECT PRIOR TO INSULATION.
5. LIGHTING FIXTURES IN CLOSETS TO COMPLY W/ NEC 410.8 (TYP).
6. E.C. TO PROVIDE ALL RECEPTACLE SPACING AS PER NEC 210.52 (TYP).
7. PROVIDE AFCI BREAKERS FOR BEDROOMS AS REQUIRED BY NEC 210.12 (TYP).
8. BRACE J. BOX FOR CEILING FAN NEC 422. 18 (TYP)
9. COORDINATE LOCATION OF AHU DISCONNECT SWITCH WITH A/C CONTRACTOR TO KEEP
NEC REQUIRED CLEARANCE. PROVIDE ALL A/C CONTROLS IN SEPARATE CONDUITS AS REQUIRED.
10. COORDINATE ALL 240V LOCATIONS IN FIELD AND ALL MECHANICAL DRAWINGS.
SEE A/C SCHEDULE FOR ELECTRICAL INFORMATION.
11. ALL EXTERIOR OUTLETS TO HAVE WP "IN USE" COVERS

ITEM	PANEL A WATTS	PANEL B WATTS	PANEL C WATTS
SQ. FT	3,019		390
GENERAL LIGHTING (3W/S.F.)	9,057	0	1,170
SMALL APPLIANCES	1,500	1,500	800
RANGE	5,000		
REFRIGERATOR 1	1,000		
GARAGE DOOR			
WASHER	1,500		
NEW LIGHTING CIRCUITS			
HOT WATER			
GARAGE OUTLES	1,500		
HYDROMASSAGE			
BATHROOM OUTLETS	1,500		800
DISPOSAL	750		
DISHWASHER	1,200		
DRYER	5,000		
KITCHEN OUTLETS	3,000		
HOOD	800		
SMOKE DETECTOR	1,000		
BEDROOM OUTLETS			
COFFEE MAKER			
WINE COOLER			
MICROWAVE	1,000		
OVEN	6,000		
POOL PUMP		3,000	
POOL LTS		800	
PANEL C	2,770		
LTS. AND RECEPTS.		960	
CONNECTED LOAD: (LESS A/C)	42,577	6,260	2,770
FIRST 10KW @ 100%	10,000	10,000	10,000
BAL. @40%	13,031	-1,496	-2,892
A/C OR HTG. @ 100%	10,000	0	5,000
DEMAND LOAD:	33,031	8,504	12,108
AMPS @ 240/120V. 1PH	138	35	50
BREAKER SIZE	200	100	50
NEUTRAL LOAD	PANEL A WATTS	PANEL B WATTS	PANEL C WATTS
LIGHTING, WASHER, SMALL APPLIANCES	12,057	1,500	1,970
3KW @ 100%	3,000	3,000	3,000
BALANCE @ 35%	3,170	-525	-361
RANGE @ 70%	3,500	0	0
DRYER @ 70%	3,500	0	0
EXTERIOR LIGHTING & RECEPTACLES	0	0	0
GATE	0	0	0
BATHROOM (GFI)	1,500	0	800
DISPOSAL	750	0	0
DISHWASHER	1,200	0	0
JACUZZI (GFI)	0	0	0
120V. APPLIANCES	1,600	1,600	1,600
TOTAL NEUTRAL W.:	18,220	4,075	5,040
NEUTRAL AMPS (N.W./240)	76	17	21


These drawings have a local state and federal copyright Juan Contín, Architect. and are property of the. They are not to be used on other projects or extension of this project except by written agreements with Juan Contín, Architect. No design changes which alter the intent of the drawings or specifications are to be made without obtaining written permission from Juan Contín, Architect.

JUAN CRISTOBAL CONTIN

FL LICENSE # AR94935

B26 S. FEDERAL HIGHWAY

LAKE WORTH, FL 33460



LEOHR LESLIE S R 2002 TRUST

1317 GRINNELL STREET

1317 GRINNELL STREET

KEY WEST, FLORIDA

DATE: 16 JULY, 2018

ISSUED: _____

DRAWN BY: JC


CHECKED BY: JC

[illegible]

AS SHOWN

ELECTRICAL PLAN

E-02



TYPE LOAD CENTER		PANEL "00"										MAIN BUS 50	
SERVICE 16 3W		CABANA										NEUTRAL 50 FULL	
VOLTAGE 120/240		NEMA 3R										MAIN 50 MLO	
MOUNTING FLUSH												LOCATION CABANA	
POLES 12												SEE PLAN	
LOAD	COND	WIRE	TRIP	DESCRIPTION	C K T	C K T	DESCRIPTION	TRIP	WIRE	COND	LOAD		
6500	3/4	6	60	CU 1	1	2	BATHROOM RECEPTACLE	15	14	1/2	800		
			└	└	3	4	AIR HANDLER 1	60	6	3/4	10000		
800	1/2	12	20	SMALL APPLIANCES G.F.I.	5	6	└	└	└				
				FUTURE	7	8	FUTURE						
				└	9	10							
					11	12	└						

▲ DENOTES COOLING AND HEATING LOAD ARE NON CON-CURRENT

* DENOTES CKTS TO BE PROVIDED
WITH GFI TYPE CKT, BREAKER

ELECTRICAL RISER

SCALE : $1/4'' = 1'-0''$

NOTICING

Public Meeting Notice

The Historic Architectural Review Commission will hold a public meeting at **5:30 p.m., October 23, 2018** at **City Hall, 1300 White Street**, Key West, Florida. The purpose of the hearing will be to consider a request for:

NEW ONE-STORY ACCESSORY STRUCTURE AND CONVERSION OF REAR PORTION OF HOUSE INTO A COVERED PATIO. DEMOLITION OF NON-HISTORIC ACCESSORY STRUCTURE AND PARTIAL DEMOLITION OF EAST AND NORTH EXTERIOR WALLS OF MAIN HOUSE.

#1317 GRINNELL STREET

Applicant – Juan Contin, Architects Application #H17-03-0058

If you wish to see the application or have any questions, you may visit the Planning Department during regular office hours at 1300 White Street, call 305-809-3973 or visit our website at www.cityofkeywest-fl.gov.

THIS NOTICE CAN NOT BE REMOVED FROM THE SITE UNTIL HARC FINAL DETERMINATION

ADA ASSISTANCE: It is the policy of the City of Key West to comply with all requirements of the Americans with Disabilities Act (ADA). Please call the TTY number at 800-955-8771 or 800-955-8770 (Voice) or the ADA Coordinator at 305-809-3811 at least five business days in advance for sign language interpreters, assistive listening devices, or materials in accessible format.

PROPERTY APPRAISER INFORMATION



Disclaimer

The Monroe County Property Appraiser's office maintains data on property within the County solely for the purpose of fulfilling its responsibility to secure a just valuation for ad valorem tax purposes of all property within the County. The Monroe County Property Appraiser's office cannot guarantee its accuracy for any other purpose. Likewise, data provided regarding one tax year may not be applicable in prior or subsequent years. By requesting such data, you hereby understand and agree that the data is intended for ad valorem tax purposes only and should not be relied on for any other purpose.

By continuing into this site you assert that you have read and agree to the above statement.

Summary

Parcel ID 00039320-000000
Account # 1040061
Property ID 1040061
Millage Group 10KW
Location 1317 GRINNELL ST, KEY WEST
Address
Legal KW WEBB REALTY CO SUB PB1-42 PT LOTS 4-5 SQR 7 TR 18 OR302-59/60 OR466-19/20 OR477-263 OR821-335 OR877-1595 OR896-981 OR1143-1831/32R/S OR2284-961/62 OR2327-955/56 OR2373-777 OR2799-2367/68
Description
 (Note: Not to be used on legal documents)
Neighborhood 6131
Property Class SINGLE FAMILY RESID (0100)
Subdivision The Webb Realty Co
Sec/Twp/Rng 05/68/25
Affordable No
Housing



Owner

LEOHR LESLIE S R 2002 TRUST
 C/O LEOHR DOUGLAS C TRUSTEE
 2247 ROLLINGWOOD DR
 MEDINA OH 44256

Valuation

	2017	2016	2015	2014
+ Market Improvement Value	\$1,002,076	\$307,233	\$305,383	\$290,501
+ Market Misc Value	\$57,898	\$61,690	\$54,056	\$50,552
+ Market Land Value	\$620,612	\$1,088,035	\$962,556	\$818,299
= Just Market Value	\$1,680,586	\$1,456,958	\$1,321,995	\$1,159,352
= Total Assessed Value	\$1,680,586	\$720,205	\$715,199	\$709,523
- School Exempt Value	\$0	(\$25,000)	(\$25,000)	(\$25,000)
= School Taxable Value	\$1,680,586	\$695,205	\$690,199	\$684,523

Land

Land Use	Number of Units	Unit Type	Frontage	Depth
RES SUPERIOR DRY (01SD)	7,475.00	Square Foot	81.25	92

Buildings

Building ID 3082
Style 2 STORY ELEV FOUNDATION
Building Type S.F.R. - R1 / R1
Gross Sq Ft 3121
Finished Sq Ft 2017
Stories 2 Floor
Condition GOOD
Perimeter 316
Functional Obs 0
Economic Obs 0
Depreciation % 8
Interior Walls WALL BD/WD WAL
Exterior Walls CUSTOM
Year Built 1963
EffectiveYearBuilt 2008
Foundation WD CONC PADS
Roof Type GABLE/HIP
Roof Coverage METAL
Flooring Type CONC S/B GRND
Heating Type FCD/AIR DUCTED with 0% NONE
Bedrooms 3
Full Bathrooms 3
Half Bathrooms 0
Grade 700
Number of Fire Pl 0

Code	Description	Sketch Area	Finished Area	Perimeter
OPX	EXC OPEN PORCH	678	0	0

Code	Description	Sketch Area	Finished Area	Perimeter
FLA	FLOOR LIV AREA	2,017	2,017	0
OPU	OP PR UNFIN LL	76	0	0
OUU	OP PR UNFIN UL	350	0	0
TOTAL		3,121	2,017	0

Yard Items

Description	Year Built	Roll Year	Quantity	Units	Grade
FENCES	2008	2009	1	2088 SF	5
WOOD DECK	2008	2009	1	295 SF	4
RES POOL	2008	2009	1	456 SF	2
DET CABANA	2008	2009	1	150 SF	4


Sales

Sale Date	Sale Price	Instrument	Instrument Number	Deed Book	Deed Page	Sale Qualification	Vacant or Improved
6/2/2016	\$1,985,000	Warranty Deed		2799	2367	01 - Qualified	Improved
3/29/2007	\$950,000	Warranty Deed		2284	961	Q - Qualified	Improved
9/1/1990	\$256,000	Warranty Deed		1143	1831	Q - Qualified	Improved
10/1/1983	\$50,000	Warranty Deed		896	981	Q - Qualified	Vacant
11/1/1980	\$32,500	Warranty Deed		821	335	Q - Qualified	Vacant
2/1/1970	\$4,210	Conversion Code		477	263	Q - Qualified	Vacant

Permits

Number ⬆	Date Issued ⬆	Date Completed ⬆	Amount ⬆	Permit Type ⬆	Notes ⬆
13-0958	3/13/2013		\$4,500	Residential	INSTALL 1 18,000 BTU MITSUBISHI MINI-SPLIT UNIT NO OUTSIDE LINES, CONDENSER UNIT ON SLAB. 10' FROM PROPERTY LINE. UNIT WILL BE OVER CONCRETE SLAB & MUST BE AT LEAST 5' SETBACK FROM PROPERTY LINES. NO EXTERIOR LINES.
13-0691	2/27/2013		\$40,000	Residential	INFILL EXISITNG ROOFED PORCH ADD WINDOW
13-0692	2/27/2013		\$1,000	Residential	ADD SEVEN (7) RECEPTACLES & ONE LIGHT, ONE (1) SWITCH.
8-865	3/27/2008	12/31/2008	\$1,000		SET 120 DFAL TANK ON PAD
08-0225	1/30/2008	12/31/2008	\$2,400	Residential	REPLACE A-FRAME ROOF WITH SHED ROOF
8-225	1/30/2008	12/31/2008	\$2,400		REPLACE A FRAME ROOF WITH SHED ROOF
07-4620	12/10/2007	12/31/2008	\$6,300	Residential	WIRE & HOOKUP THE POOL EQUIPMENT, ONE POOL LIGHT, TWO MOTORS, AND 1 HEATER, INSTALL 100 AMP SUB-PANEL FOR POOL EQUIPMENT
07-5290	12/10/2007	12/31/2008	\$258,000	Residential	REMOVE EXISTING V-CRIMP AND REPLACE WITH SAME 1800 SF, ELECTRICAL INTERIOR RENOVATION, INSTALL TV AND PHONE CABLE, PLUMBING ROUGH & SET PLUMBING FIXTURES & APPLIANCES, INSTALL 2-3 TON CENTRAL AIR 13 OUTLETS, 300 SF ADD TO COVER DECK, ADD ENCLOSED SPACE 70SF , CERMIC TILE 300SF,REPLACE WINDOWS, DOORS, KITCHEN CABINETS,ADD 3 6X6 POSTS ON SOUTH ELEVATION.
07-5112	11/27/2007	12/31/2008	\$4,500	Residential	CONSTRUCT TWO PERGOLAS ONE 168 SF AND ONE 126 SF
07-4884	11/6/2007	11/15/2007	\$1,800	Residential	REPLACE ALL PERIMETER PLUMBING DUE TO BREAKAGE BY LANDSCAPER
7-4800	10/22/2007	12/31/2008	\$10,000		CONSTRUCT POOL DECK ON GRADE
7-4425	9/21/2007	12/31/2008	\$3,800		UPGRADE SVC FROM 150 TO 200 AMP HOOK UP AC UNIT RELO W/D R/R OUTLETS,RECEPTACLES,SWITCHES, TV JACKS
7-4324	9/19/2007	12/31/2008	\$20,000		CONSTRUCT WOOD PRIVACY FENCE-TOTAL OF 348LF 4'H WITH 2'H LOUVRE
7-3315	7/5/2007	10/1/2007	\$200		CAP EXISTING SEWER & WATER TO ALLOW HOME TO BE DEMO'D
01-4071	1/3/2002	9/5/2002	\$1	Residential	ROOFING

Sketches (click to enlarge)



Map



No data available for the following modules: Commercial Buildings, Mobile Home Buildings, Exemptions.

The Monroe County Property Appraiser's office maintains data on property within the County solely for the purpose of fulfilling its responsibility to secure a just valuation for ad valorem tax purposes of all property within the County. The Monroe County Property Appraiser's office cannot guarantee its accuracy for any other purpose. Likewise, data provided regarding one tax year may not be applicable in prior or subsequent years. By requesting such data, you hereby understand and agree that the

Last Data Upload Data: 1/16/2018 3:27:39 AM



Developed by
The Schneider
Corporation