



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

---

Development Review Committee  
September 26, 2019  
Utilities Comments

**300 Petronia Street**  
**Conditional Use**  
Sanitary Sewer

Pursuant to the Florida Building Code: Plumbing, Chapter 10, Section 1003, a grease interceptor is required for the commercial kitchen operations. Please provide location and capacity of the grease interceptor.

**1217 Varela Street, 1221 Varela Street, & 1127 United Street**  
**Conditional Use**  
No comments.

**291 Front Street**  
**Conditional Use**  
No comments.

**1026 James Street**  
**Easement**  
No comments.

**1021 Margaret Street**  
**Easement**  
No comments.

**1200 Whitehead Street**  
**Easement**  
No comments.