



PORT & MARINE SERVICES

201 William Street
Key West, FL
33040

ADDENDUM NO. 3

MOBILE GENERATOR INSTALLTION KEY WEST BIGHT FERRY TERMINAL ITB #20-004

The information contained in this Addendum adds information to be included in the Bid and is hereby made a part of the Contract Documents. The referenced bid package is hereby addended in accordance with the following items:

CLARIFICATION

1. Requests for alternate generator use must be submitted for review no later than 12:00pm, Friday November 1, 2019.
2. Maximum height of generator on the trailer cannot exceed 94" high (including tires at full pressure).

SPECIFICATIONS

Section 16230 - 9 – STANDBY DIESEL GENERATOR

Change:

Minimum Generator Size: **230 kw***

To:

Minimum Generator Size: **200 kw***

All other elements of the Contract and Bid documents, including the Bid Date shall remain unchanged.

All Bidders shall acknowledge receipt and acceptance of this **Addendum No. 3** by submitting the addendum with their proposal. Proposals submitted without acknowledgement or without this Addendum may be considered non-responsive.

Signature

Name of Business