



Permit Details

City of Key West

PERMIT NUMBER
2018-00002764

Description:

Type: MECHANICAL HVAC	Subtype: RESIDENTIAL	Status: INFORMATION REQUIRED	Applied: 6/22/2018 KEYWJK
Parcel No: 00064860-000000	Site Address: 2713 FLAGLER AVE KEY WEST,FL 33040		Approved:
Subdivision:	Block: SF	Lot:	Issued:
Lot Sq Ft:	Building Sq Ft:	Zoning:	Finalized:
Valuation: \$37,756.00	Occupancy Type:	Construction Type:	Expired:
No. Buildings:	No. Stories:	No. Unites:	

Details: **June 22, 2018 8:41:29 AM keywjky. New install MITSUBISHI condenser MXZ8C48NA a/h mszg124nau1 *****N.O.C REQUIRED*******

ADDITIONAL INFO/CLARIFICATION SHEET: THIS IS A BOUNDARY SURVEY REQUESTED BY MELISSA PAUL LETO IN REGUARDS TO A BUILDING PERMIT APPLICATION. GH

N.O.C. RECV'D 10/24/18. GH

Permit in call back over one year

Work was performed can not be canceled CEB Letter issued

Process Summary

ADDITIONAL SITES

CHRONOLOGY

CHRONOLOGY TYPE	STAFF NAME	ACTION DATE	COMPLETION DATE	NOTES
REQUEST FOR ADDITIONAL INFORMATION	Gerzale Hill	10/24/2018		PROVIDING N.O.C. & PROPERTY SURVEY. GH

CONDITIONS

CONTACTS

NAME TYPE	NAME	ADDRESS1	CITY	STATE	ZIP	PHONE	FAX	EMAIL
APPLICANT	ISLAND REFRIGERATION & A/C INC	PO BOX 2238	KEY WEST	FL	33045	(305)294-7246		
CONTRACTOR	ISLAND REFRIGERATION & A/C INC	PO BOX 2238	KEY WEST	FL	33045	(305)294-7246		
OWNER	GRACE LUTHERAN CHURCH U A C	2713 FLAGLER AVENUE	KEY WEST	FL	33040			



Permit Details

City of Key West

PERMIT NUMBER
2018-00002764

CONTACTS

NAME TYPE	NAME	ADDRESS1	CITY	STATE	ZIP	PHONE	FAX	EMAIL
QUALIFIER	ISLAND REFRIGERATION & A/C INC	PO BOX 2238	KEY WEST	FL	33045	(305)294-7246		

FINANCIAL INFORMATION

DESCRIPTION	ACCOUNT	QTY	AMOUNT	PAID	PAID DATE	RECEIPT #	CHECK #	METHOD	PAID BY	CLTD BY
APPLICATION FEE MECH NEW	0010000 3220000		\$40.00	\$40.00	6/22/18	201800002 764001645 9	22184	CHECK		
Total Paid for APPLICATION FEE MECH NEW:			\$40.00	\$40.00						
AFTER THE FACT	00100003220000	0	\$912.00	\$0.00						
BUILDING PLAN REVIEW	00100003220000	0	\$37.76	\$0.00						
DBPR-BCAIB-468	00100002080200	0	\$13.65	\$0.00						
DEO-FBC-553	00100002080200	0	\$9.10	\$0.00						
EDUCATION FEE	00100003220000	0	\$2.00	\$0.00						
Total Paid for ADMINISTRATION:			\$974.51	\$0.00						
MECHANICAL HOOD & HVAC	00100003220000	0	\$872.00	\$0.00						
Total Paid for MECHANICAL PERMIT:			\$872.00	\$0.00						
TOTALS:			\$1,886.51	\$40.00						

INSPECTIONS

PARENT PROJECTS

REVIEWS

REVIEW TYPE	REVIEWER	SENT DATE	DUE DATE	RETURNED DATE	STATUS	REMARKS	NOTES
-------------	----------	-----------	----------	---------------	--------	---------	-------



Permit Details

City of Key West

PERMIT NUMBER
2018-00002764

01-PERMIT TECHNICIAN	JACKIE YINGLING	6/22/2018	6/25/2018	6/22/2018	APP FORWARDED FOR REVIEW		
02-PLANNING	Melissa Paul Leto	6/22/2018	11/2/2018	11/2/2018	APPROVED		August 17, 2018 11:56:50 AM keywmpl. need boundary survey , draw the proposed location and indicate the setback from the edge of the condensor to the nearest lot line.
							the additional information currently has the ac units outside of the boundary line. need to revise and show true locations and setbacks.
							please clarify on the survey the location of the proposed ac units in a darker pen and scratch out the 3ft notes.
04-URBAN FORESTRY	KAREN DEMARIA	6/22/2018	7/12/2018	8/14/2018	APPROVED		
11-MECHANICAL	Terry Richardson	6/22/2018	7/12/2018	11/5/2018	CORRECTIONS NEEDED	Ventilation needed.	Contractor to show ventilation and load calculations on a approved drawing. Drawing should be preformed by a design professional.

BOND INFORMATION

ATTACHMENTS

Attachment Type	CREATED	OWNER	DESCRIPTION	PATHNAME	SUBDIR	ETRAKIT ENABLED
DOC	10/25/2018	Gerzale Hill	Add_Info 2713 FLAGLER AVE-18-2764.pdf	2713 FLAGLER AVE-18-2764.pdf		0




Permit Details

City of Key West

PERMIT NUMBER
BLD2018-0956

Description:			
Type: MECHANICAL HVAC	Subtype: COMMERCIAL HARC	Status: PERMIT PRINTED	Applied: 10/25/2018 GH
Parcel No: 00005630-000000	Site Address: 909 FLEMING ST KEY WEST, FL 33040		Approved: 1/2/2019 MB
Subdivision:	Block:	Lot:	Issued: 1/2/2019 MB
Lot Sq Ft: 0	Building Sq Ft: 0	Zoning:	Finalized:
Valuation: \$11,960.00	Occupancy Type:	Construction Type:	Expired: 12/22/2020 MB
No. Buildings: 0	No. Stories: 0	No. Unites: 0	
Details: REPLACE 2 4-TON CONDENSER RA1448JNA A/A RBHP24J11SH4. N.O.C. W/APPLICATION. HARC INSP. REQUIRED. GH			
NoA tie downs Additional information			

Process Summary



69 Applied to Approved
0 Approved to Issued

ADDITIONAL SITES

CHRONOLOGY

CONDITIONS

CONTACTS

NAME TYPE	NAME	ADDRESS1	CITY	STATE	ZIP	PHONE	FAX	EMAIL
APPLICANT	ISLAND REFRIGERATION & A/C INC	3201 FLAGLER AVE 510	KEY WEST	FL	33040	(305)294-7246		licensetochill1@aol.com
CONTRACTOR	ISLAND REFRIGERATION & A/C INC	3201 FLAGLER AVE 510	KEY WEST	FL	33040	(305)294-7246		licensetochill1@aol.com
OWNER	KEY WEST LODGE NO64 FREE AND ACCEPTED MASONS OF FL	PO Box 1248	Key West	FL	33041	(305)294-7246		
QUALIFIER	ISLAND REFRIGERATION & A/C INC	3201 FLAGLER AVE 510	KEY WEST	FL	33040	(305)294-7246		licensetochill1@aol.com

FINANCIAL INFORMATION



Permit Details

City of Key West

PERMIT NUMBER
BLD2018-0956

DESCRIPTION	ACCOUNT	QTY	AMOUNT	PAID	PAID DATE	RECEIPT #	CHECK #	METHOD	PAID BY	CLTD BY
BUILDING PLAN REVIEW	00100003220000	0	\$11.96	\$0.00						
DBPR SURCHARGE	00100003220000	0	\$4.20	\$0.00						
DEO SURCHARGE	00100003220000	0	\$6.30	\$0.00						
EDUCATION FEE	00100003220000	0	\$2.00	\$0.00						
Total Paid for ADMINISTRATION:			\$24.46	\$0.00						
HARC APPLICATION FEE	00100003220000	0	\$50.00	\$0.00						
HARC INSPECTION FEE	00100003220000	0	\$25.00	\$0.00						
HARC REVIEW FEE	00100003220000	0	\$50.00	\$50.00	10/26/18	R5237	022788	CHECK	ISLAND REFRIGERATION & A/C INC	GH
Total Paid for HARC:			\$125.00	\$50.00						
AIR CONDITIONING AND OR HEAT PUMP SYSTEMS	00100003220000	0	\$288.00	\$0.00						
MECHANICAL PLAN REVIEW FEE	00100003220000	0	\$60.00	\$0.00						
Total Paid for MECHANICAL PERMIT:			\$348.00	\$0.00						
PERMIT APPLICATION FEE	00100003220000	1	\$50.00	\$50.00	10/26/18	R5237	022788	CHECK	ISLAND REFRIGERATION & A/C INC	GH
Total Paid for PERMIT APPLICATION FEE:			\$50.00	\$50.00						
TOTALS:			\$547.46	\$100.00						

INSPECTIONS

PARENT PROJECTS

REVIEWS



Permit Details

City of Key West

PERMIT NUMBER
BLD2018-0956

REVIEW TYPE	REVIEWER	SENT DATE	DUE DATE	RETURNED DATE	STATUS	REMARKS	NOTES
01-PERMIT TECH							
08-HARC	Kelly Perkins	10/25/2018	10/26/2018	10/29/2018	APPROVED		
MECHANICAL	Building Review	10/25/2018	10/25/2018	10/31/2018	CORRECTIONS NEEDED	Needs NOA's.	NOA's needed for unit tie down and stands since the units and stand have not been inspected, ever. No previous permits taken out for A/c. Anchoring to be 3" from the edge of slab.
MECHANICAL	Terry Richardson	12/31/2018	12/31/2018	12/31/2018	APPROVED		

BOND INFORMATION

ATTACHMENTS