



**PORT & MARINE SERVICES**

201 William Street  
Key West, FL 33040

**ADDENDUM NO. 2**

**KINGFISH PIER REPLACEMENT – HURRICANE IRMA DAMAGE  
CITY MARINA @ GARRISON BIGHT  
ITB #20-006**

The information contained in this Addendum adds information to be included in the Bid and is hereby made a part of the Contract Documents. The referenced bid package is hereby addended in accordance with the following items:

**QUESTIONS & CLARIFICATIONS:**

1. Are we replacing the Marine Power pedestals with new?

**Yes, all Marine Power pedestals shall be replaced with new.**

2. Is the existing ground fault monitoring system to also be replaced?

**No, the new circuits being added to the existing panel will require ground fault protection. It is not replacement of the existing ground fault monitoring system.**

All other elements of the Contract and Bid documents, including the Bid Date shall remain unchanged.

All Bidders shall acknowledge receipt and acceptance of this **Addendum No. 2** by submitting the addendum with their proposal. Proposals submitted without acknowledgement or without this Addendum may be considered non-responsive.

---

Signature

---

Name of Business