



Legislation Details (With Text)

**File #:** 16-9699      **Version:** 1      **Name:** .  
**Type:** Code Violations      **Status:** Passed  
**File created:** 6/3/2016      **In control:** Code Enforcement Hearing  
**On agenda:** 6/29/2016      **Final action:** 6/29/2016  
**Title:** Case # 16-320  
Ralph Filannino  
1613 Bahama Drive  
FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured fuel tank, propane - within a flood zone, below flood level  
Officer Scott Fraser  
Certified Service: 3-31-2016  
Initial Hearing: 6-29-2016

In compliance June 17, 2016, request dismissal

Count 1: The 100-gallon propane tank rests unsecured.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:**

Date	Ver.	Action By	Action	Result
6/29/2016	1	Code Enforcement Hearing	Dismissed	

**Case # 16-320**  
Ralph Filannino  
1613 Bahama Drive  
FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured fuel tank, propane - within a flood zone, below flood level  
Officer Scott Fraser  
Certified Service: 3-31-2016  
Initial Hearing: 6-29-2016

**In compliance June 17, 2016, request dismissal**

**Count 1:** The 100-gallon propane tank rests unsecured.