



Legislation Details (With Text)

File #: 18-2529 **Version:** 1 **Name:**
Type: Code Violations **Status:** Passed
File created: 6/26/2018 **In control:** Code Enforcement Hearing
On agenda: 7/25/2018 **Final action:** 7/25/2018

Title: Case # 16-1336
Douglas Whitman - Owner
Suburban Propane
1317 Newton Street
Sec. 14-31 Adopted construction codes
Officer Beau Langford
Certified Service: 5-30-2018 - Owner
Certified Service: 5-30-2018 - Suburban Propane
Initial Hearing: 7-25-2018

In compliance 8 Jun 2018; request dismissal

Count 1: Failure to secure propane tank against buoyancy in a FEMA designated AE-6 flood zone.

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
7/25/2018	1	Code Enforcement Hearing	Dismissed	

Case # 16-1336

Douglas Whitman - Owner
Suburban Propane
1317 Newton Street
Sec. 14-31 Adopted construction codes
Officer Beau Langford
Certified Service: 5-30-2018 - Owner
Certified Service: 5-30-2018 - Suburban Propane
Initial Hearing: 7-25-2018

In compliance 8 Jun 2018; request dismissal

Count 1: Failure to secure propane tank against buoyancy in a FEMA designated AE-6 flood zone.