



## Legislation Details

---

**File #:** 18-2529      **Version:** 1      **Name:**  
**Type:** Code Violations      **Status:** Passed  
**File created:** 6/26/2018      **In control:** Code Enforcement Hearing  
**On agenda:** 7/25/2018      **Final action:** 7/25/2018

**Title:** Case # 16-1336  
Douglas Whitman - Owner  
Suburban Propane  
1317 Newton Street  
Sec. 14-31 Adopted construction codes  
Officer Beau Langford  
Certified Service: 5-30-2018 - Owner  
Certified Service: 5-30-2018 - Suburban Propane  
Initial Hearing: 7-25-2018

In compliance 8 Jun 2018; request dismissal

Count 1: Failure to secure propane tank against buoyancy in a FEMA designated AE-6 flood zone.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:**

Date	Ver.	Action By	Action	Result
7/25/2018	1	Code Enforcement Hearing	Dismissed	