



Legislation Text

File #: 16-9699, **Version:** 1

Case # 16-320

Ralph Filannino

1613 Bahama Drive

FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured fuel tank, propane - within a flood zone, below flood level

Officer Scott Fraser

Certified Service: 3-31-2016

Initial Hearing: 6-29-2016

In compliance June 17, 2016, request dismissal

Count 1: The 100-gallon propane tank rests unsecured.