



Legislation Details (With Text)

File #: 14-7039 **Version:** 1 **Name:**
Type: Code Violations **Status:** Passed
File created: 1/5/2015 **In control:** Code Compliance Hearing
On agenda: 1/28/2015 **Final action:** 4/29/2015
Title: Case # 14-1631
Theresa Cioffi
3222 Riviera Drive
a/k/a 1600 Riviera Street
FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured Fuel tank, propane, within a flood zone,
below flood level
Officer Scott Fraser
Certified Service: 12-20-2014
Initial Hearing: 1-28-2015

In compliance April 9, 2015, request dismissal

Count 1: For failure to obtain a fuel gas permit and properly secure the tank against buoyancy in
accordance with the International Building Code.

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
4/29/2015	1	Code Compliance Hearing	Dismissed	
3/20/2015	1	Code Compliance Hearing	Continuance	
2/25/2015	1	Code Compliance Hearing	Continuance	
1/28/2015	1	Code Compliance Hearing	Continuance	

Case # 14-1631

Theresa Cioffi
3222 Riviera Drive
a/k/a 1600 Riviera Street
FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured Fuel tank, propane, within a flood zone,
below flood level
Officer Scott Fraser
Certified Service: 12-20-2014
Initial Hearing: 1-28-2015

In compliance April 9, 2015, request dismissal

Count 1: For failure to obtain a fuel gas permit and properly secure the tank against buoyancy in
accordance with the International Building Code.