



Legislation Details (With Text)

File #: 16-9699 **Version:** 1 **Name:** .
Type: Code Violations **Status:** Passed
File created: 6/3/2016 **In control:** Code Compliance Hearing
On agenda: 6/29/2016 **Final action:** 6/29/2016
Title: Case # 16-320
Ralph Filannino
1613 Bahama Drive
FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured fuel tank, propane - within a flood zone, below flood level
Officer Scott Fraser
Certified Service: 3-31-2016
Initial Hearing: 6-29-2016

In compliance June 17, 2016, request dismissal

Count 1: The 100-gallon propane tank rests unsecured.

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
6/29/2016	1	Code Compliance Hearing	Dismissed	

Case # 16-320

Ralph Filannino
1613 Bahama Drive
FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured fuel tank, propane - within a flood zone, below flood level
Officer Scott Fraser
Certified Service: 3-31-2016
Initial Hearing: 6-29-2016

In compliance June 17, 2016, request dismissal

Count 1: The 100-gallon propane tank rests unsecured.