



## Legislation Details

**File #:** 2017-96      **Version:** 1      **Name:**  
**Type:** Code Violations      **Status:** Passed  
**File created:** 12/30/2016      **In control:** Code Compliance Hearing  
**On agenda:** 1/25/2017      **Final action:** 4/26/2017  
**Title:** Case # 16-667  
Daniel J. Dingeman  
6 Sunset Key Drive  
Sec. 122-990(6)(b) Dimensional requirements  
Sec. 14-37 Building permits; professional plans; display of permits; address; exceptions.  
Sec. 14-327 Inspection.  
Officer Kenneth JW Waite  
Certified Service: 12-12-2016  
Initial Hearing: 1-25-2017

In compliance April 25, 2017, request dismissal

Count 1: Failure to obtain an after-the-fact permit or an after-the-fact variance as the location of pool pump to the dividing fence is 8 inches and the required minimum setback is 2.5 feet. Count 2: Failure to apply for permits to relocate the pool pump. Count 3: Failure to obtain a mechanical inspection for the pool pump from the City of Key West Building Department.

### Sponsors:

### Indexes:

### Code sections:

### Attachments:

Date	Ver.	Action By	Action	Result
4/26/2017	1	Code Compliance Hearing	Dismissed	
3/29/2017	1	Code Compliance Hearing	Continuance	
1/25/2017	1	Code Compliance Hearing	Continuance	