

City of Key West, FL

City Hall 1300 White Street Key West FL 33040

Legislation Text

File #: 2017-6, Version: 1

Case # 16-1398

Suzana Dragacevac

68 Seaside North Court

FBC 1612.4 [ASCE 24-05] Unprotected Enclosed Structures Below Design Flood Elevation

Sec. 14-37 Building permits; professional plans; display of permits; address; exceptions -

Mechanical

Sec. 14-37 Building permits; professional plans; display of permits; address; exceptions - Plumbing

Sec. 14-37 Building permits; professional plans; display of permits; address; exceptions - Electrical

Sec. 14-262 Requests for inspection, required

Sec. 66-87 Business tax receipt required

FBC 1612 & ASCE 24-05 [Sections 7.2, 7.3 & &.4] Plumbing/Electrical/Mechanical

Installed/Constructed Below Flood

Officer Scott Fraser Hand Served: 1-9-2017 Initial Hearing: 12-21-2016

In compliance April 10, 2017, fees still due

Count 1: Within a FEMA designated AE-8 flood zone, open area has been enclosed, contrary to flood damage prevention provisions. Count 2: Within a FEMA designated AE-8 flood zone, Respondent did install or allow to be installed, electronic devices/appliances below established flood safety levels. Count 3: Within a FEMA designated AE-8 flood zone, Respondent did install or allow to be installed, plumbing connections and fixtures below established flood safety levels. Count 4: Within a FEMA designated AE-8 flood zone, Respondent did install or allow to be installed, electrical wiring, outlets and fixtures below established flood safety levels. Count 5: Within a FEMA designated AE-8 flood zone, Respondent did energize or allow to be energized, electrical wiring, electrical outlets and fixtures absent the required safety inspections having been requested nor performed, contrary to law and the safety of the general public. Count 6: For failure to obtain a business receipt to rent the second dwelling. Count 7: Within a FEMA designated AE-8 flood zone, Respondent did install or allow to be installed, electrical wiring, outlets, receptacles and plumbing fixtures below established flood safety levels, contrary to the safety of the general public.