



Legislation Text

File #: 18-2529, **Version:** 1

Case # 16-1336

Douglas Whitman - Owner

Suburban Propane

1317 Newton Street

Sec. 14-31 Adopted construction codes

Officer Beau Langford

Certified Service: 5-30-2018 - Owner

Certified Service: 5-30-2018 - Suburban Propane

Initial Hearing: 7-25-2018

In compliance 8 Jun 2018; request dismissal

Count 1: Failure to secure propane tank against buoyancy in a FEMA designated AE-6 flood zone.