



**OPERATIONS MANAGEMENT INTERNATIONAL, INC.**

P.O. Box 4998  
 Key West, Florida 33041-4998  
 Phone: 305-292-5110  
 Fax: 305-292-5130

Sample #	Description	Collection Time	Date	Fecal Coliform	Enterococcus
NS1112-0329	Steam Plant Grate	11:05	11/06/2012	>600	>600
NS1112-0330	Grinnell 1	11:10	11/06/2012	10	<10
NS1112-0331	Grinnell 2	11:10	11/06/2012	70	<10
NS1112-0332A	Steam Plant Grate	8:45	11/08/2012	<10**	90
NS1112-0332	Grinnell 1	9:00	11/08/2012	420	10
NS1112-0333	Grinnell 2	9:10	11/08/2012	<10**	10

\* All results are expressed as cfu per 100 ml unless otherwise noted.  
 \*\*Confluent Growth – non fecal.

Methods Used: Standard Methods 9222 D 20<sup>th</sup> Edition & EPA 1600  
 Florida Department of Health Bureau of Laboratories  
 Certification #E55389

These results are certified and meet all requirements of NELAC.

Approved By: Rick Cleaver (Laboratory Director)