



ADDENDUM #3- ITB # 21-001

PROJECT: Cable Huts Stabilization and Repair Mallory Square

DATE: 10.26.2020

1. RFI- 45- Section 1/A8.0 shows the TPO roof with no insulation. Section 2/A5.0 shows roof with insulation. Please Clarify.
Answer: No insulation is required in the roof so the cost can be removed from the scope of work.

2. RFI- 46- The Proposal Form references a pre itemized schedule of values located in part 4 of the documents. I can't find this pre-itemized schedule of values. Please clarify.
Answer: No schedule of Values was provided in part 4, please strike the below paragraph from the PROPOSAL FORM.

“Provided in Part 4 of these documents is a pre-itemized Schedule of Values broken down by trade and type of work, Bidders are to provide the cost of all LABOR & MATERIALS for use as a basis for payment. “

3. RFI- 47 Clarification on Winch- Please remove the cleaning of the historic winch and replacement cost for locating the historic winch on the roof from the scope of work.

END OF ADDENDUM # 3