

# **GENERAL:**

В

- 1. THE CONTRACTOR IS ADVISED THAT THE SPECIFICATIONS FORM A PART OF THE CONTRACT DOCUMENTS AND ALL WORK SHALL BE PERFORMED IN ACCORDANCE WITH THE SPECIFICATIONS AND DRAWINGS. THE CONTRACTOR SHALL KEEP A COPY OF THE DRAWINGS AND THE SPECIFICATIONS ON SITE AT ALL TIMES DURING PERFORMANCE OF THE WORK.
- 2. ELEVATIONS ARE IN FEET BASED ON MEAN LOWER LOW WATER (MLLW) PROJECT DATUM FOR THE 1983-2001 TIDAL EPOCH.
- 3 ALL NORTH ARROWS SHOWN ARE GRID NORTH BASED ON FLORIDA FAST ZONE
- DIMENSIONS AND DETAILS OF THE EXISTING ELEMENTS ARE BASED ON ARCHIVE DRAWINGS FURNISHED BY THE GOVERNMENT. WORK RELATED DIMENSIONS AND DETAILS OF THE EXISTING ELEMENTS SHALL BE FIELD VERIFIED BY THE CONTRACTOR, DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE CONTRACTING OFFICER AND OR ADJUSTED BEFORE ORDERING MATERIALS AND PROCEEDING WITH THE WORK
- 5. THE EXACT SIZE AND LOCATION OF ALL EXISTING UTILITIES SHALL BE FIELD VERIFIED BY THE CONTRACTOR PRIOR TO START OF CONSTRUCTION. ALL CONSTRUCTION SHALL BE COORDINATED WITH THE CONTRACTING OFFICER
- 6. IT IS THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE CONSTRUCTION PROCEDURES AND SEQUENCE TO ENSURE THE SAFETY OF THE FACILITIES. THE CONTRACTOR IS RESPONSIBLE TO ERECT, MAINTAIN AND REMOVE TEMPORARY ERECTION MATERIALS AND EQUIPMENT. ALL PROPOSED STAGING AREAS SHALL BE COORDINATED WITH THE CONTRACTING OFFICER BEFORE STARTING THE WORK
- 7. CONTRACTOR SHALL MAINTAIN ADEQUATE SURVEY CONTROL AT ALL TIMES TO ESTABLISH AND MAINTAIN ALL LINES AND ELEVATIONS.
- 8. THE CONTRACTOR IS RESPONSIBLE FOR ALL DAMAGE DONE TO STRUCTURES AND VESSELS OR INJURIES TO THE PUBLIC AS A RESULT OF PERFORMING THE WORK.
- THE CONTRACTOR SHALL PROVIDE AND MAINTAIN ENVIRONMENTAL CONTROLS AS REQUIRED BY FEDERAL, STATE AND MUNICIPAL REGULATIONS AND PERMITS. ENVIRONMENTAL CONTROLS SHALL INCLUDE BUT NOT BE LIMITED TO EROSION, TURBIDITY AND DUST.
- 10. THE CONTRACTOR SHALL FOLLOW ALL APPLICABLE FEDERAL, STATE AND MUNICIPAL REGULATIONS, INCLUDING THE FEDERAL DEPARTMENT OF LABOR SAFETY, HEALTH ACT, U.S. ARMY CORPS OF ENGINEERS, STATE/LOCAL WETLANDS
- 11. THE CONTRACTOR SHALL SCHEDULE AND COORDINATE ALL WORK, INCLUDING ALLOWABLE WORK WINDOWS, WITH FACILITY PERSONNEL, AND SHALL MAINTAIN THE WORK SITE TO THE SATISFACTION OF THE CONTRACTING OFFICER.
- 12. STORAGE, FUELING AND LUBRICATION OF EQUIPMENT AND MOTOR VEHICLES SHALL BE CONDUCTED IN A MANNER THAT AFFORDS THE MAXIMUM PROTECTION AGAINST SPILL AND EVAPORATION. FUEL, LUBRICANTS AND OIL SHALL BE MANAGED AND STORED IN ACCORDANCE WITH ALL FEDERAL, STATE, REGIONAL, AND LOCAL LAWS AND REGULATIONS. THERE SHALL BE NO STORAGE OF FUEL ON THE PROJECT SITE. FUEL MUST BE BROUGHT TO THE PROJECT SITE AS NEEDED. EQUIPMENT OPERATION, ACTIVITIES, OR PROCESSES PERFORMED BY THE CONTRACTOR SHALL IN ACCORDANCE WITH ALL FEDERAL AND STATE AIR EMISSION AND PERFORMANCE LAWS AND STANDARDS.
- 13. CONTRACTOR SHALL MAINTAIN TRAFFIC ALONG ROADWAYS AND GATES AT ALL TIMES AND PROVIDE NECESSARY TRAFFIC CONTROL SIGNS AND BARRICADES WHEN WORKING WITHIN ROADWAYS
- 14. THE USE OF EXPLOSIVES OR BLASTING SHALL NOT BE PERMITTED.
- 15. SILT BARRIERS SHALL BE PROVIDED AROUND ALL DEMOLITION OPERATIONS TAKING PLACE IN THE WATER AS NECESSARY TO MEET AND MAINTAIN STATE WATER QUALITY STANDARDS. WHERE DEMOLITION OPERATIONS ON SHORE WILL RESULT IN SURFACE RUNOFF OR HAZARDOUS SUBSTANCES ENTERING A BODY OF WATER. SILT BARRIERS SHALL BE PROVIDED TO ENCLOSE THE POINT OF ENTRY INTO THE BODY OF WATER TO PREVENT THE CONTAMINANTS FROM DISPERSING.
- 16. ALL ITEMS INDICATED TO BE DEMOLISHED SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED FROM GOVERNMENT PROPERTY, UNLESS
- 17. THE CONTRACTOR SHALL MAINTAIN AN ACCESS ROUTE FOR VEHICLES TO THE OUTER MOLE AT ALL TIMES.
- 18. EXITING MANHOLES WITHIN PROJECT AREA ARE LIKELY FILLED WITH WATER AND SHALL BE PUMPED DRY BY THE CONTRACTOR PRIOR TO UTILITY WORK.

# SURVEY:

1. UTILITIES SHOWN ARE APPROXIMATE, CONSULT WITH THE PROPER AUTHORITIES FOR LOCATION AND INFORMATION. CONTRACTOR SHALL ASSUME THAT ACTIVE AND
ABANDONED UTILITIES, ADDITIONAL TO THOSE SHOWN IN THE DRAWINGS, EXIST AND SHALL BE SUPPORTED OR CUT AND CAPPED AT THE DIRECTION OF THE CONTRACTING OFFICER.

#### DEMOLITION:

- 1. THE CONTRACTOR SHALL PROVIDE CONTROL MEASURES AS REQUIRED BY ENVIRONMENTAL REGULATIONS AND AS REQUIRED TO PREVENT DEBRIS FROM ENTERING THE WATER, UNDERWATER INSPECTIONS MAY BE CONDUCTED BY THE GOVERNMENT TO ENSURE THE CONTRACTOR HAS REMOVED ALL DEMOLITION AND CONSTRUCTION DEBRIS FROM THE WATER.
- 2. PREVENT THE SPREAD OF DUST AND DEBRIS AND AVOID THE CREATION OF A NUISANCE OR HAZARD IN THE SURROUNDING AREA. DO NOT USE WATER IF I' RESULTS IN HAZARDOUS OR OBJECTIONABLE CONDITIONS SUCH AS. BUT NOT LIMITED TO, FLOODING OR POLLUTION.
- 3. WHERE PEDESTRIAN AND DRIVER SAFETY IS ENDANGERED IN THE AREA OF REMOVAL WORK, USE TRAFFIC BARRICADES WITH FLASHING LIGHTS. ANCHOR BARRICADES IN A MANNER TO PREVENT DISPLACEMENT BY WIND. NOTIFY FACILITY PERSONNEL PRIOR TO BEGINNING SUCH WORK.
- 4. THE CONTRACTOR SHALL OBTAIN PERMISSION FROM THE FACILITY EACH DAY BEFORE WELDING OR TORCH CUTTING WORK IS PERFORMED.
- 5. ALL MATERIAL REMOVED AND NOT REUSED SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED DAILY FROM THE GOVERNMENT'S PROPERTY OR PROPERLY STORED IN AN APPROVED LOCATION ON SITE. REMOVED MATERIAL SHALL BE DISPOSED OF IN ACCORDANCE WITH ALL LOCAL, STATE, AND FFDERAL LAWS.
- CONTRACTOR SHALL PROTECT EXISTING UTILITIES AND WORK WHICH ARE TO REMAIN IN PLACE, BE REUSED, OR REMAIN THE PROPERTY OF THE GOVERNMENT.
- 7. CONTRACTOR SHALL NOT OBSTRUCT ACCESS TO NAVY VESSELS/CRUISE SHIPS AND BUILDINGS DURING PERFORMANCE OF THE WORK.
- WHERE REMOVALS LEAVE HOLES AND DAMAGED SURFACES EXPOSED IN THE FINISHED WORK, PATCH AND REPAIR THESE HOLES AND DAMAGED SURFACES TO MATCH ADJACENT FINISHED SURFACES. FINISHED SURFACES OF PATCHED AREA SHALL BE FLUSH WITH ADJACENT EXISTING SURFACE AND SHALL MATCH THE EXISTING ADJACENT SURFACE AS CLOSELY AS POSSIBLE AS TO TEXTURE AND FINISH. APPLY PATCHING MATERIAL IN ACCORDANCE WITH THE MANUFACTURER'S PRINTED INSTRUCTIONS.
- 9. REMOVE MARINE GROWTH AND OTHER BOND INHIBITING SUBSTANCES FROM ALL SURFACES IN CONTACT WITH REPAIR WORK USING HIGH PRESSURE WATER SPRAY OR OTHER APPROVED METHODS.

# STEEL:

- 1. ALL STRUCTURAL STEEL CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF THE AMERICAN INSTITUTE OF STEEL CONSTRUCTION (AISC) STEEL CONSTRUCTION MANUAL
- 2. ALL STRUCTURAL STEEL SHAPES AND PLATES SHALL BE ASTM A36 OR A-572, UNLESS OTHERWISE NOTED.
- BOLTS SHALL CONFORM TO ASTM A-307 LATEST EDITION. NUTS SHALL CONFORM TO ASTM A-572, LATEST EDITION.
- 4. ALL WELDING SHALL BE IN ACCORDANCE WITH THE STRUCTURAL WELDING CODE, D1.1 AND D3.6 OF THE AWS. ELECTRODES SHALL BE E70XX LOW HYDROGEN IN ACCORDANCE WITH AWS SPECIFICATIONS.
- ALL EXISTING STEEL SHEET PILING TO BE CONCRETE ENCAPSULATED AND STEEL SHEET PILING TO RECEIVE WELDING SHALL BE CLEANED TO REMOVE ALL LOOSE SCALE, RUST AND MARINE GROWTH DOWN TO BARE METAL.

# TIDAL DATUMS

ESTIMATED 100-YEAR FLOOD ELEVATION (STILLWATER)	8.4' 3.7'
HIGHEST OBSERVED WATER LEVEL (9/8/1965)	• • • •
MEAN HIGHER HIGH WATER (MHHW)	1.8'
NORTH AMERICAN VERTICAL DATUM — 1988 (NAVD)	1.8'
MEAN HIGH WATER (MHW)	1.5'
MEAN LOW WATER (MLW)	0.2
MEAN LOWER LOW WATER (MLLW)	0.0'
LOWEST OBSERVED WATER LEVEL (2/19/1928)	-1.7'

NOAA/NOS STATION #8724580 KEY WEST, FLORIDA (1983-2001 TIDAL EPOCH)

# CONCRETE:

- 1. ALL CONCRETE CONSTRUCTION AND DETAILING SHALL CONFORM TO SECTION 03 31 29 MARINE CONCRETE.
- 2. MATERIALS SHALL CONFORM TO THE FOLLOWING: 28 DAY COMPRESSION STRENGTH OF 5,000 PSI MAXIMUM WATER TO CEMENT RATIO OF 0.40 28 DAY PERMEABILITY VALUE OF BELOW 2,000 COULOMBS
- 3. EXPOSED CONCRETE EDGES SHALL HAVE A 1" CHAMFER.
- 4. CONCRETE SHALL BE MOIST CURED FOR A PERIOD OF 7 DAYS. CURING SHALL BEGIN IMMEDIATELY AFTER FINISHING.
- 5 REINFORCING STEEL SHALL BE EPOXY COATED AND CONFORM TO ASTM A615, GRADE 60 IN ACCORDANCE WITH THE SPECIFICATIONS.
- MAINTAIN 3" OF CLEAR COVER TO ALL REINFORCING STEEL, UNLESS OTHERWISE NOTED.
- 7. ALL REINFORCING SHALL BE FULLY SUPPORTED ON APPROVED PLASTIC CHAIRS AND BARS.
- 8. ALL HOOKS SHALL BE STANDARD 90 DEGREE HOOKS. LAPS AND SPLICES SHALL BE CLASS A IN ACCORDANCE WITH ACI 318-08. 9. CONTRACTOR SHALL SUBMIT DETAILED REINFORCING DRAWINGS INCLUDING
- AND APPROVAL PRIOR TO DELIVERY OF ANY REINFORCING STEEL. 10. WHERE "DRILL AND GROUT" IS CALLED FOR IN THE DRAWING SET, GROUT


BAR AND BENDING SCHEDULES TO THE CONTRACTING OFFICER FOR REVIEW

- SHALL CONFORM TO THOSE LISTED ON THE FLORIDA DEPARTMENT OF TRANSPORTATION QUALIFIED PRODUCTS LIST FOR FAST SETTING GROUT FOR ANCHOR BOLTS OR APPROVED FOULVALENT 11. CONSTRUCTION JOINTS OTHER THAN THOSE SHOWN ON THE DRAWINGS
- MAY BE PROVIDED WITH WRITTEN APPROVAL FROM THE CONTRACTING 12. DETAILS OF CONCRETE NOT SHOWN SHALL CONFORM TO ACI 318-08.

# STEEL SHEET PILES

- 1. ALL STEEL SHEET PILING SHALL CONFORM TO ASTM A572,
- UNLESS OTHERWISE NOTED, ANY SUBSTITUTION OF STRUCTURAL SHAPES SHALL BE SUBMITTED FOR REVIEW AND ACCEPTANCE BY THE CONTRACTING OFFICER IN WRITING PRIOR TO USE.
- THE CONTRACTOR SHALL PROVIDE DETAILS OF PILE DRIVING EQUIPMENT. THE DRIVING EQUIPMENT AND METHOD SHALL BE APPROVED BY THE CONTRACTING OFFICER. NO JETTING WILL BE PERMITTED, EXCEPT AS MAY BE NEEDED TO REMOVE OBSTRUCTIONS. JETTING SHALL BE APPROVED BY THE CONTRACTING
- ALL SHEET PILES SHALL BE MARKED AT A GIVEN DISTANCE FROM THE BOTTOM. WHICH WILL SHOW ABOVE THE WATERLINE AFTER DRIVING, SO THAT THE BOTTOM ELEVATION OF EACH SHEET AND ITS RELATION WITH ADJACENT SHEETS CAN BE
- SHEET PILES SPLICES SHALL NOT BE PERMITTED WITHOUT SPECIAL AUTHORIZATION FROM THE CONTRACTING OFFICER.
- DO NOT DRIVE SHEETING WITHIN 50 FEET OF CONCRETE LESS THAN 72 HOURS
- CUT OFF PORTIONS OF SHEET PILES SHALL BE REMOVED AND DISPOSED OF OFF-SITE BY THE CONTRACTOR.
- DRIVE SHEET PILES TO THE MINIMUM ELEVATIONS AS SHOWN ON THE DRAWINGS OR REFUSAL AT THE APPROVAL OF THE CONTRACTING OFFICER.
- SHEET PILES SHALL BE DRIVEN PLUMB AND TRUE TO LINE. PILINGS SHALL BE PLACED PLUMB WITH OUT-OF-PLUMBNESS NOT EXCEEDING &" PER FOOT OF LENGTH AND TRUE TO LINE. TOP OF PILE AT ELEVATION OF CUT-OFF SHALL BE WITHIN 3" HORIZONTALLY AND 1" VERTICALLY OF THE LOCATION INDICATED.
- 10. SQUARE CUT THE TOPS OF SHEET PILES AT THE ELEVATION SHOWN ON THE
- 11. SHEET PILES WHICH ARE DAMAGED, MISLOCATED, OR DRIVEN OUT OF VERTICAL ALIGNMENT SHALL BE WITHDRAWN AND REPLACED BY NEW PILES AT NO ADDITIONAL COST TO THE GOVERNMENT.
- 12. SHEET PILES SHALL BE DRIVEN WITHIN APPROVED FALSE WORK OR APPROVED TEMPLATES.
- 13. STEEL SHEET PILES SHALL BE COATED ON BOTH SIDES WITH A COAL TAR EPOXY POLYAMIDE WITH A MINIMUM DRY FILM THICKNESS OF 16 MILS IN ACCORDANCE WITH SPECIFICATION SECTION 09 97 13.26.

Marin nc. Appledore Ma Engineering I





OR COMMANDER NAVFAC / B.L.T.L.

ATISFACTORY TO DATE DES · DRW ·

CHIEF ENG/ARCH (CORE)

SOUTHEAST EAST COAST


KEY REPAIRS 497


В


HE NAVY
FACILITIES ENGINEERING COMMAND
DIAGONAL BULKHEAD MENT OF TH


SCALE PROJECT NO. onstr. contr. no. N62473-06-D-3004


100054<u>79</u> G-002












































# TRUMAN HARBOR REPAIRS



# NAVAL AIR FACILITY KEY WEST, FLORIDA



CONSTRUCTION CONTRACT NO. N62467-03-C-0154 SPECIFICATION NO. 06-03-0154



SCALE: 1" = 1/2 MILE

PROJECT VICINITY

FLORIDA MAP NOT TO SCALE

SCALE: 1" = 1/2 MILE

GRAPHIC SCALE

1 MARCH 2005

G-1

RECORD

DRAWING

HARBOR REPAIRS

TRUMAN

Naval Facilities Engineering Command

REDUCED DRAWING - VERIFY SCALE REPRESENTATIONS

/2\	OFNEDAL DE		INDEX OF DRAWINGS
NAVFAC	GENERAL DE	RAWINGS	
DWG. NO. 5429422 5429423 5429424 5429425 5429426 5429427 5429428 5429429 5429430 5429431 5429432 5429433	SHEET NO.  G-1 G-2 G-3 G-4 G-5 G-6 G-7 G-8 G-9 G-10 G-11 G-12	SHEET TITLE  COVER SHEET INDEX OF DRAWINGS LEGEND ABBREVIATIONS GENERAL NOTES LOCATION PLAN AND SHEET LAYOUT RECORD DRAWING SOIL BORINGS AND LAB TEST DATA RECORD DRAWING SOIL BORINGS AND LAB TEST DATA RECORD DRAWING SOIL BORINGS AND LAB TEST DATA RECORD DRAWING SOIL BORINGS WALL THICKNESS DATA — 2002 PHASING PLAN AND NOTES OUTER MOLE BERTHED VESSEL ACTIVITY AREA	
	CIVIL DRAWI	<u>NGS</u>	
5429434 5429435 5429436 5429437 5429438 5429443 5429440 5429441 5429442 5429443	C-1 C-2 C-10 C-11 C-12 C-13 C-14 C-15 C-20 C-21	DEMOLITION LOCATION PLAN SOUTH MOLE WATERFRONT PHOTOGRAPHS NORTH MOLE DEMOLITION CENTRAL MOLE DEMOLITION SOUTH MOLE DEMOLITION SHORE DEMOLITION PIER 8 DEMOLITION DEMOLITION NOTES SECTIONS AND DETAILS SHORE AREA PAVEMENT REPAIR	
	UTILITY DRA	<u>WINGS</u>	
5429444 5429445 5429446 5429447 5429448 5429449 5429450 5429451 5429452 5429453 5429454 5429455 5429456 5429457 5429458 5429458	U-1 U-2 U-3 U-4 U-5 U-6 U-7 U-8 U-9 U-10 U-11 U-12 U-13 U-14 U-15 U-16	UTILITY LOCATION PLAN UTILITY SITE PLAN DEMOLITION/EXISTING UTILITY FLOW DIAGRAM DEMOLITION/EXISTING UTILITY FLOW DIAGRAM UTILITY FLOW DIAGRAM UTILITY FLOW DIAGRAM NORTH MOLE UTILITY PLAN CENTRAL MOLE UTILITY PLAN PIER 8 UTILITY PLAN AND SECTION MOLE UTILITY PLAN AND SECTIONS MOLE UTILITY PLAN AND SECTIONS MOLE UTILITY PLAN AND SECTIONS PIER 8 UTILITY STATION PLAN AND SECTIONS MOLE SEWAGE LIFT STATION SITE PIER 8 SECTIONS AND DETAILS NEW WATER MAIN PLAN AND DETAILS LIFT STATION PLAN AND SECTION	
	ELECTRICAL	DRAWINGS	
5429460 5429461 5429463 5429464 5429465 5429466 5429467 5429470 5429470 5429471 5429473 5429474 5429475 5429475 5429477 5429478 5429478 5429480 5429481 5429481 5429482 5429483 5429484 5429485 5429487 5429489 5429489 5429489 5429489 5429490 5429491 5429491 5429492 5429493 5429496 5429498 5429497 5429498 5429497 5429498 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499 5429499	E-0 E-1 E-2 E-3 E-4 E-5 E-6 E-7 E-8 E-9 E-10 E-11 E-12 E-13 E-14A E-15A E-15B E-16A E-15B E-16A E-19B E-19C E-20B E-21 E-22 E-23 E-24 E-25 E-29 E-30 E-31 E-32 E-34 E-33A E-33A E-33A E-33A E-33A E-33A E-340 E-41	ABBREVIATIONS AND LEGEND ELECTRICAL LOCATION PLAN PRIMARY ONE LINE DIAGRAM SECONDARY ONE LINE DIAGRAM—SUBSTATION #1 SECONDARY ONE LINE DIAGRAM—SUBSTATION #2 SECONDARY ONE LINE DIAGRAM—SUBSTATION #3 SECONDARY ONE LINE DIAGRAM—SUBSTATION #4 SYSTEM TIME—CURRENT COORDINATION CURVES SCHEMATIC WIRING DIAGRAMS KEY NOTES FOR DRAWINGS E—10 THROUGH E—13 ELECTRICAL PLAN NORTH MOLE ELECTRICAL PLAN SOUTH MOLE ELECTRICAL PLAN SOUTH MOLE ELECTRICAL PLAN SHORE SUBSTATIONS #1 AND #2 DETAILS—SHEET 1 OF 2 SUBSTATIONS #1 AND #2 DETAILS—SHEET 2 OF 2 SUBSTATION #3 DETAILS—SHEET 1 OF 2 SUBSTATION #4 DETAILS—SHEET 1 OF 4 SUBSTA	


<u>/2</u>	STRUCTURAL	DRAWINGS		
NAVFAC DWG. NO. 5429502 5429503 5429504 5429506 5429507 5429508 5429510 5429511 5429512 5429513 5429515 5429516 5429515 5429518 5429518 5429520 5429520 5429520 5429520 5429521 5429520 5429521 5429520 5429523 5429524 5429525 5429526 5429526 5429527 5429528 5429528 5429529 5429530 5429531 5429531 5429533 5429533	S - 28 S - 29 S - 30 S - 31 S - 32 S - 33 S - 34 S - 35 S - 36 S - 37 S - 38 S - 39	SHEET TITLE  STRUCTURAL LOCATION PLAN NORTH MOLE TIP EXISTING WALLS NORTH MOLE TIP REMOVAL DETAILS NORTH MOLE NEW WALL PLAN NORTH MOLE NEW WALL DETAILS NORTH MOLE NEW WALL DETAILS NORTH MOLE REPAIRS CENTRAL MOLE REPAIRS SOUTH MOLE REPAIRS OUTER MOLE BERTH REPAIR DETAILS OUTER MOLE BERTH REPAIR DETAILS OUTER MOLE BERTH REPAIRS SOUTH AND CENTRAL MOLE WALL CAP REPAIRS MOORING PLAN BREASTING DOLPHIN STRUCTURE DRILLED SHAFT DETAILS ELECTRICAL UTILITY STRUCTURES DETAILS ELECTRICAL UTILITY STRUCTURES DETAILS ELECTRICAL UTILITY STRUCTURES DETAILS FENDER SYSTEM DETAILS PIER 8 REPAIRS — BOTTOM PLAN PIER 8 REPAIRS — BOTTOM PLAN PIER 8 REPAIRS — BOTTOM PLAN PIER 8 REPAIRS — RECORD DRAWING PIER 8 REPAIRS — PILE JACKET DETAILS  LIFT STATION STRUCTURAL DETAILS		
	SOUTH Q	UAY WALL DRAWINGS - BID OPTION		
5429536 5429537 5429538 5429540 5429541 5429542 5429543 5429545 5429546 5429546 5429549 5429549 5429550 5429551 5429552 5429553 5429554 5429555 5429555 5429557 5429558 5429558 5429559 5429559 5429559 5429559 5429559 5429559 5429559	XG-1 XC-2 XC-3 XC-4 XC-5 XC-6 XC-7 XC-8 XC-9 XC-11 XC-12 XC-13 XC-14 XM-1 XM-2 XM-3 XE-1 XS-1 XS-2 XS-3 XS-4 XS-5 XS-6 XS-7	SOUTH QUAY WALL LOCATION PLAN SOUTH QUAY WALL DEMOLITION SOUTH QUAY WALL DEMOLITION SOUTH QUAY WALL DEMOLITION NOTES SOUTH QUAY WALL CIVIL SITE PLAN SOUTH QUAY WALL CIVIL SITE PLAN SOUTH QUAY WALL BULKHEAD SECTIONS AND DETAILS SOUTH QUAY WALL BORING LOCATIONS SOUTH QUAY WALL DEMOLITION & DUCT BANK REPLACEMENT SOUTH QUAY WALL DEMOLITION DETAILS SOUTH QUAY WALL FENCE DETAILS SOUTH QUAY WALL FENCE DETAILS SOUTH QUAY WALL FENCE DETAILS SOUTH QUAY WALL MECHANICAL PLAN SOUTH QUAY WALL MECHANICAL PLAN SOUTH QUAY WALL STRUCTURAL PLAN SOUTH QUAY WALL BULKHEAD DETAILS SOUTH QUAY WALL BULKHEAD DETAILS SOUTH QUAY WALL BULKHEAD DECTIONS AND DETAILS SOUTH QUAY WALL BULKHEAD SECTIONS AND DETAILS SOUTH QUAY WALL DETAILS		


 $\bigwedge$ 


URS Group, Inc. 7650 West Courtey Compbell Causeway Tonno., Ft. 33607	DSGN ZICHLIN DR Z	FKW 03/01/05 CRS SUPV WALKER CH ENGR WALKER	SUBMITTED BY: DATE	TECHNICAL BRANCH	FPE
DRAWING REVISIONS Rev. Description Prep By Date Apprvd.		2 CORRECTED TO AS-BUILT FKW 03/C			
NAVAL AIR FACILITY KEY WEST, FLORIDA	SOLAGIO OCCUPANTION	INCIMAIN DANDON NETAINS		INDEX OF DRAWINGS	APPROVED DATE EFD FOR COMMANDER, NAVFAC
Naval Facilities Engineering Command		Southern Division		Charleston, South Carolina	

RECORD DRAWING

RECORD DRAWING DATE
1 MARCH 2005
CODE I.D. NO. 80091
DRAWING SIZE: D
SPEC.NO. 06-03-0154
CONSTRN. CONTR. NO.
N62467-03-C-0154
NAVFAC DRAWING NO.
5429423
SHEET 2 OF







KNOWN CONCRETE PAVEMENT AREAS BEHIND SOUTH MOLE WALL ARE INDICATED ON DRAWINGS. CONTRACTOR SHALL ANTICIPATE ENCOUNTERING ASPHALT PAVEMENT, STRUCTURES, OR ASPHALT MIXED WITH LIMEROCK OR SOIL IN ALL OTHER AREAS TO BE DEMOLISHED OR EXCAVATED DURING WALL REPAIR.

#### UTILITY DEMOLITION Λ

OLIAY WALL

REMOVE ALL LIFT STATION COMPONENTS INCLUDING WET WELL, LIFT STATION VALVE VAULT, OIL WATER SEPARATOR, BILGE WATER VALVE PIT, BURIED 4000 GALLON CAPACITY FIBERGLASS WASTE OIL TANK AND ASSOCIATED APPURTENANCES INCLUDING ALL FOUNDATIONS, STRUCTURES, PIPING, TANKS AND SUPPORT ITEMS. CAP AND PROTECT HORIZONTAL UNDERGROUND UTILITIES FOR REUSE TO SUPPORT NEW CONSTRUCTION (COORDINATE UTILITY DEMOLITION WITH U-DRAWINGS).

U2 CUT AND REMOVE SANITARY, BILGE, DIESEL OIL AND POTABLE WATER UTILITY STATION COMPONENTS INCLUDING ALL FOUNDATIONS, STRUCTURES, PIPING, AND SUPPORT ITEMS. CAP AND PROTECT HORIZONTAL UNDERGROUND UTILITIES FOR REUSE TO SUPPORT NEW CONSTRUCTION (COORDINATE UTILITY CUTS AND DEMOLITION WITH U-DRAWINGS).

REMOVE ALL EXISTING SANITARY, BILGE AND POTABLE WATER COMPONENTS ABOVE AND BELOW DECK. COMPONENTS INCLUDE FRP, PVC AND CS PIPING, VALVES, METERS, SUPPORTS, COUPLINGS, AND ASSOCIATED APPURTENANCES. CAP AND PROTECT HORIZONTAL PIPING TO REMAIN. MODIFY EXISTING CURBING AND FOUNDATIONS AS REQUIRED. COORDINATE UTILITY REMOVAL AND NEW WORK WITH U-DRAWINGS.

# **AMENDMENT 0005**

1.ADD THE FOLLOWING AT THE ENDS OF ELECTRICAL DEMOLITION NOTES E6 AND E14: "THE BASE PUBLIC WORKS DEPARTMENT HAS REPORTED THAT THE UNIT SUBSTATION AND PAD MOUNT STYLE OIL FILLED TRANSFORMERS HAVE BEEN TESTED FOR PCB'S AND HAVE BEEN FOUND TO QUALIFY AS NON-PCB CONTAMINATED. HOWEVER, ALL TRANSFORMERS SPECIFIED TO BE HANDLED AND/OR DISPOSED OF MUST HAVE RECENT CERTIFICATION AS NON-PCB CONTAMINATED AND THEREFORE MUST BE RETESTED. PROVIDE FOR RETESTING AND RECERTIFICATION OF TRANSFORMERS AS NON-PCB CONTAMINATED PRIOR TO HANDLING AND/OR DISPOSAL."

2.ADD THE FOLLOWING AT THE ENDS OF ELECTRICAL DEMOLITION NOTES E1, E4, E5 AND E18: "THE CONTRACTOR SHALL ASSUME THAT THE MEDIUM-VOLTAGE CABLES ASSOCIATED WITH EACH PRIMARY CIRCUIT MAKE ONE COMPLETE LOOP AROUND THE INSIDE OF EACH PRIMARY MANHOLE, AND THAT THE PORTIONS OF EACH MEDIUM-VOLTAGE CABLE EXPOSED INSIDE EACH PRIMARY MANHOLE ARE INDIVIDUALLY WRAPPED ALONG THEIR ENTIRE LENGTHS WITH ASBESTOS CONTAINING FIREPROOFING TAPE. PROVIDE FOR THE PROPER HANDLING, TESTING, AND DISPOSAL OF THE SEGMENTS OF MEDIUM-VOLTAGE CABLE WRAPPED WITH ASBESTOS CONTAINING FIREPROOFING TAPE."

3.ADD THE FOLLOWING AT THE ENDS OF ELECTRICAL DEMOLITION NOTES E15. E28 AND E29: "THE CONTRACTOR SHALL ASSUME THAT LUMINAIRE BALLASTS ARE PCB CONTAMINATED. PROVIDE FOR THE PROPER HANDLING AND DISPOSAL OF THESE BALLASTS.'

# DEMOLITION NOTES

(LOCATIONS INDICATED ON SHEETS C-10 THROUGH C-14)

# **ELECTRICAL DEMOLITION**

(E1) DE-ENERGIZE, DISCONNECT AND REMOVE 3-350kcmil MEDIUM VOLTAGE CABLES FROM 4"

(E2) DE-ENERGIZE, DISCONNECT AND REMOVE SECONDARY WIRING SERVING EACH MINIPOWER ZONE COMBINATION TRANSFORMER/PANELBOARD INSTALLATION

(E3) DISCONNECT AND REMOVE COMMUNICATIONS CABLING SERVING EACH COMMUNICATIONS PEDESTAL FROM 2-4" PVC CONDUITS. DO NOT REMOVE TELEPHONE TRUNK LINE IF TELEPHONE SERVICE PROVIDER DETERMINES IT CAN BE REUSED. COORDINATE WORK WITH TELEPHONE SERVICE PROVIDER.

(E4) DE-ENERGIZE, DISCONNECT AND REMOVE 3-350kcmil MEDIUM VOLTAGE CABLES BACK THROUGH MANHOLE NOS. 56, 55, 21, 20 AND 22, TO UPSTREAM MEDIUM VOLTAGE CIRCUIT BREAKER IN EXISTING MEDIUM VOLTAGE SUBSTATION

(E5) DE-ENERGIZE, DISCONNECT AND REMOVE 3-250kcmil MEDIUM VOLTAGE CABLES BACK TO UPSTREAM SPLICE IN MANHOLE NO. 56

(E6) DE-ENERGIZE AND REMOVE UNIT SUBSTATION CONSISTING OF A 15kV MEDIUM VOLTAGE METAL ENCLOSED LOAD INTERRUPTER SWITCH, A 3,000kVA OA / 4,200kVA FFA RATED, 13.8kV DELTA PRI., 480V DELTA SEC., 3PH. OIL FILLED SUBSTATION STYLE TRANSFORMER; AND A 5,000A, 480V, 3PH. SWITCHBOARD CONTAINING FOUR (4) 1600A AND ONE 200A DRAWOUT CIRCUIT BREAKERS, METERING COMPARTMENT, BATTERY CHARGER SYSTEM COMPARTMENT AND APPURTENANCES. REMOVE CONCRETE PAD. PROTECT HORIZONTAL PORTIONS OF UNDERGROUND CONDUITS FOR EXTENSION UP INTO NEW CONCRETE PAD.

(E7) DE-ENERGIZE, DISCONNECT AND REMOVE 3-500kcmil PH. AND 1-#3 GND FROM EACH OF 4-4" PVC CONDUITS. TWO (2) OF THE 4" PVC CONDUITS ALSO CONTAIN A 9C/#12 CONTROL CABLE IN ADDITION TO THE FEEDER WIRES.

(E8) DE-ENERGIZE, DISCONNECT AND REMOVE IGLOO CONSISTING OF EIGHT (8) 500A, 480V, 3PH. RECEPTACLES, TWO (2) CONTROL PANELS, REINFORCED CONCRETE STRUCTURE, STEEL STRUCTURAL MEMBERS AND STEEL MOUNTING PLATES.

(E9) DE-ENERGIZE, DISCONNECT AND REMOVE MOLE SECONDARY POWER DISTRIBUTION EQUIPMENT CONSISTING OF A 225A, 480/277V, 3PH., 4W. PANELBOARD, 60A, 480V, 3P SEWAGE LIFT STATION DISCONNECT SWITCH, 60A, 480V, 3P ENCLOSED LIGHTING CONTACTOR AND STRUCTURAL STEEL RACK. DE-ENERGIZE, DISCONNECT AND REMOVE 3-4/0 PH., 1-4/0 NEUT. AND 1-#2 GND FROM 3" PVC CONDUIT BETWEEN 150kVA, 480/277V, 3 PH., OIL FILLED PAD MOUNTED TRANSFORMER AND MOLE SECONDARY POWER DISTRIBUTION EQUIPMENT. DE-ENERGIZE AND DISCONNECT 150kVA, 480/277V, 3 PH., OIL FILLED PAD MOUNTED TRANSFORMER, SECURE AND PROTECT TRANSFORMER WHICH IS TO BE RE-ENERGIZED UNDER THE NEW ELECTRICAL WORK PORTION OF THIS PROJECT.

(E10) DE-ENERGIZE, DISCONNECT AND REMOVE EXISTING 15kVA, 480V 1PH. PRI., 120/240V 1PH. 3W. SEC. MINIPOWER ZONE COMBINATION TRANSFORMER/LOAD CENTER, FIBER GLASS HOUSING AND CONCRETE FOUNDATION. PROTECT HORIZONTAL PORTIONS OF UNDERGROUND CONDUITS FOR EXTENSTION UP INTO NEW LC/TELECOMM. OUTLET ASSEMBLY

DE-ENERGIZE, DISCONNECT AND REMOVE 2-#6 PH. AND 1-#10 GND FROM 2" PVC CONDUIT. REMOVE FEEDER WIRES BACK TO MOLE SECONDARY POWER DISTRIBUTION PANELBOARD.

(E12) DISCONNECT AND REMOVE COMMUNICATIONS PEDESTAL CONSISTING OF A TWO (2) 30"H.x 30"W. x 8" D. NEMA TYPE 3R CABINETS, TWO (2) VERTICAL STRUCTURAL STEEL SUPPORT POSTS AND CONCRETE FOUNDATION. PROTECT HORIZONTAL PORTIONS OF UNDERGROUND CONDUIT FOR EXTENSION UP INTO NEW LC/TELECOMM. OUTLET ASSEMBLY.

DISCONNECT AND REMOVE COMMUNICATIONS CABLING FROM 4" PVC CONDUIT. DO NOT REMOVE TELEPHONE TRUNK LINE IF TELEPHONE SERVICE PROVIDER DETERMINES IT CAN BE REUSED. COORDINATE WORK WITH TELEPHONE SERVICE PROVIDER.

(E14) DE-ENERGIZE AND REMOVE UNIT SUBSTATION CONSISTING OF A 15kV MEDIUM VOLTAGE METAL ENCLOSED LOAD INTERRUPTER SWITCH, A 750kVA, 13.8kV DELTA PRI., 480V DELTA SEC., 3PH. OIL FILLED SUBSTATION STYLE TRANSFORMER; AND A 2,000A, 480V, 3PH. SWITCHBOARD CONTAINING SEVEN (7) 400A DRAWOUT CIRCUIT BREAKERS, METERING COMPARTMENT, BATTERY CHARGER SYSTEM COMPARTMENT AND APPURTENANCES. REMOVE CONCRETE PAD. PROTECT HORIZONTAL PORTIONS OF UNDERGROUND CONDUITS FOR EXTENSION UP INTO NEW CONCRETE PAD. DE-ENERGIZE, DISCONNECT AND REMOVE 300kVA, 208/120V, 3 PH., OIL FILLED PAD MOUNTED TRANSFORMER, AND DELIVER TO NAFKW ELECTRICAL DEPARTMENT MATERIAL STORAGE YARD ON BOCA CHICA.

(E15) DE-ENERGIZE, DISCONNECT AND REMOVE 40'-0" TALL GALVANIZED STEEL LIGHT POLE AND FLOOD LIGHT TYPE LUMINAIRES INSTALLED THEREON.

/1\

1

(E16) DE-ENERGIZE, DISCONNECT AND REMOVE 3-#8 PH., 1-#8 NEUT. AND 1-#6 GND FROM 2" CRGS CONDUIT. CONCRETE FOUNDATION AND CONDUIT IS TO REMAIN INTACT FOR REUSE UNDER THE NEW ELECTRICAL WORK PORTION OF THIS PROJECT. REMOVE LIGHTING CIRCUIT WIRES BACK TO MOLE SECONDARY POWER DISTRIBUTION LIGHTING CONTACTOR.

(£17) REMOVE RADIO REPORTING TYPE MANUAL FIRE ALARM PULL STATION POLE, CONCRETE FOUNDATION AND FOUR (4) CONCRETE FILLED PIPE BOLLARDS.

(E18) DE-ENERGIZE, DISCONNECT AND REMOVE 3-250kcmil MEDIUM VOLTAGE CABLES FROM 4" PVC CONDUIT.

(E19) DE-ENERGIZE, DISCONNECT AND REMOVE 3-600kcmil PH. AND 1-#1 GND FROM EACH OF 6-4" PVC CONDUITS. DE-ENERGIZE, DISCONNECT AND REMOVE SIX (6) SETS OF MULTIPLE #12 CONTROL WIRES FROM A 4" PVC CONDUIT.

(E20) DISCONNECT AND REMOVE COMMUNICATIONS CABLING FROM 2-2" PVC CONDUITS. DO NOT REMOVE TELEPHONE TRUNK LINE IF TELEPHONE SERVICE PROVIDER DETERMINES IT CAN BE REUSED. COORDINATE WORK WITH TELEPHONE SERVICE PROVIDER

ELECTRICAL DEMOLITION (CONTINUED)

(E21) DE-ENERGIZE, DISCONNECT AND REMOVE PIER POWER STATION CONSISTING OF A 500A, 480V, 3PH. RECEPTACLE, CONTROL PANEL AND HEAVY DUTY A GALVANIZED STEEL ENCLOSURE.

(E22) DE-ENERGIZE, DISCONNECT AND REMOVE 3-600kcmil PH. AND 1-#1 GND FROM 4" PVC CONDUITS. DE-ENERGIZE, DISCONNECT AND REMOVE MULTIPLE #12 CONTROL WIRES FROM A 2" PVC CONDUIT.

(E23) DE-ENERGIZE, DISCONNECT AND REMOVE 3-600kcmil PH. AND 1-#1 GND FROM EACH OF 4-4" PVC CONDUITS. DE-ENERGIZE, DISCONNECT AND REMOVE FOUR (4) SETS OF MULTIPLE #12 CONTROL WIRES FROM A 4" PVC CONDUIT.

(E24) DE-ENERGIZE, DISCONNECT AND REMOVE PIER POWER STATION CONSISTING OF TWO (2) 500A, 480V, 3PH. RECEPTACLES, TWO (2) CONTROL PANELS AND A HEAVY DUTY GALVANIZED STEEL ENCLOSURE.

(£25) DE-ENERGIZE, DISCONNECT AND REMOVE 3-600kcmil PH. AND 1-#1 GND FROM EACH OF 2-4" PVC CONDUITS. DE-ENERGIZE, DISCONNECT AND REMOVE TWO (2) SETS OF MULTIPLE #12 CONTROL WIRES FROM A 2" PVC CONDUIT.

DE-ENERGIZE, DISCONNECT AND REMOVE ALL CABLING/WIRING FROM MANHOLE.

PREPARE CONDUITS FOR DEMOLITION OF MANHOLE, AND EXTENSION AND TERMINATION TO NEW MANHOLE TO BE CONSTRUCTED UNDER THE NEW WORK PORTION OF THIS PROJECT.

(E27) DE-ENERGIZE, DISCONNECT AND REMOVE TIME SWITCH FROM MANHOLE.

E28 DE-ENERGIZE, DISCONNECT AND REMOVE 30'-0" TALL CONCRETE LIGHT POLE AND FLOOD LIGHT TYPE LUMINAIRE INSTALLED THEREON.

(E29) DE-ENERGIZE, DISCONNECT AND REMOVE 30'-0" TALL GALVANIZED STEEL LIGHT POLE AND FLOOD LIGHT TYPE LUMINAIRE INSTALLED THEREON.

(E30) DE-ENERGIZE, DISCONNECT AND REMOVE 2-#10 PH. AND 1-#10 GND FROM 1 1/4" PVC CONDUIT. REMOVE LIGHTING CIRCUIT WIRES BACK TO TIME SWITCH.

# STRUCTURAL DEMOLITION

REMOVE ALL ARCH FENDERS ALONG OUTER MOLE BERTH, NORTH AND CENTRAL MOLE BERTH AND PIER 8. RETAIN FASTENERS. LEAVE BOLTS IN PLACE.

(S2) REMOVE NORTH END OF OUTER MOLE BEYOND LOCATION OF NEW BULKHEAD WALL FROM EXISTING GROUND SURFACE TO ELEVATION -33.7 MSL, PLUS 2'-0" OVERDREDGE. REMOVAL TO INCLUDE EXISTING STRUCTURES, BOLLARD AND 5' Ø DRILLED SHAFT BOLLARD FOUNDATION, DEBRIS, PAVEMENT, UTILITIES, EARTH AND ROCK.

(S3) REMOVE PORTIONS OF EXISTING BULKHEAD WALLS AS INDICATED TO ALLOW CONSTRUCTION OF NEW BULKHEAD WALL.

(S4) REMOVE SUBMERGED REMAINS OF FOUR TIMBER (19) PILE DOLPHIN CLUSTERS.

(S5) REMOVE SOUTH MOLE AND PORTIONS OF THE CENTRAL MOLE CONCRETE SHEET PILE CAP AND ATTACHMENTS TO WALL AS INDICATED.

/3\ (S6) REMOVE BOLLARD AND PILE CAP TO ACCOMODATE NEW BOLLARD AND FOUNDATION. PILING TO REMAIN IN PLACE DUE TO EXISTING ELECTRICAL DUCT BANK.

(S7) REMOVE AND DISPOSE OF ALL LOW DOUBLE BITTS AND CLEATS FROM OUTER MOLE

(S8) REMOVE COMPLETELY 2 SUBMERGED 14 IN. CONCRETE PILING STUBS — DO NOT CUT PILING.

(S9) REMOVE COMPLETELY 1 SUBMERGED 14 IN. CONCRETE PILING STUB — DO NOT CUT PILE.

(\$10) REMOVE CONCRETE SLAB 38'X4'X5" AND PAVEMENT - PROTECT BUILDING FOUNDATION DURING WALL REPAIRS.

(S11) REMOVE 12" STEEL CRANE RAIL 12' LONG 3" FROM BUILDING FACE. REMOVE 6" STEEL COLUMNS 8' LONG ATTACHED TO SEAWALL. REMOVE 6" STEEL BEAM 8' LONG.

(S12) REMOVE 24" CLEAT ATTACHED TO SEAWALL.

(\$13) REMOVE 24" CLEAT AND CONCRETE SUPPORT ADJOINING SEAWALL.

(\$14) REMOVE REMAINS OF 2' WOOD WALKWAY ATTACHED TO SEAWALL INCLUDING 12"X12" TIMBER BEAM, 2' WOOD WALKWAY, LADDERS AND MISC. ATTACHMENTS.

(\$15) REMOVE 20" DIAMETER TREE.

(\$16) REMOVE WOOD DECK.

(\$17) REMOVE ABANDONED 2" PVC CONDUIT AND WIRING.

(\$18) REMOVE END OF FENCE TEMPORARILY TO CONSTRUCT WALL REPAIR AND RESTORE AFTER COMPLETION OF WALL REPAIR.

(\$19) REMOVE ABANDONED CONCRETE 2'X3.5' UTILITY STRUCTURE.

(\$20) REMOVE BY SAW CUTTING IN NEAT STRAIGHT LINES CONCRETE SLAB AS NECESSARY TO CONSTRUCT NEW CLEATS AND FOUNDATIONS SHOWN ON SHEET S-12. ASSUME EXISTING SLAB IS 8" THICK.

CRS CRS PKW FKW FKW PER CO 7 2 4 Rev. REPAIRS HARBOR TRUMAN E O Division Engineering South

URS Group, Inc.

50 West Courtrey Campbell Couseway
npo., FL 33607
NO. 000000002
ALKER DR ZICHLIN CHK WALKER
ALKER GH ENGR WALKER
ALKER

**RECORD** DRAWING

Southern

Facilities

Naval

RECORD DRAWING DATE 1 MARCH 2005 CODE I.D. NO. 8009 DRAWING SIZE SPEC.NO. 06-03-015 CONSTRN. CONTR. NO N62467-03-C-01 NAVFAC DRAWING NO 542944 SHEET 20 OF

C - 15

REDUCED DRAWING - VERIFY SCALE REPRESENTATIONS

# **GENERAL NOTES:**

- THE GENERAL AND KEY NOTES ON THIS DRAWING APPLY TO DRAWINGS E-10 THROUGH E-13. SEE DRAWING C-15 FOR NOTES GOVERNING ELECTRICAL DEMOLITION WORK.
- EXACT LOCATIONS OF UTILITY POLES PROVIDED BY ELECTRICAL POWER SERVICE PROVIDER, SHALL
  BE DETERMINED BY THE ELECTRICAL POWER SERVICE PROVIDER BASED SYSTEMS ENGINEERING
  PERFORMED BY THE UTILITY SERVICE PROVIDER.
- 3. PREPARE EXISTING AND NEW DUCTS/CONDUITS AND MANHOLES SPECIFIED TO RECEIVE NEW PRIMARY CABLES. DE-WATER AND CLEAN EXISTING MANHOLES IDENTIFIED TO RECEIVE NEW PRIMARY CABLES, OF DIRT, DEBRIS, AND ABANDONED CABLES/WIRES. CLEAN EXISTING DUCTS/CONDUITS IDENTIFIED TO RECEIVE NEW PRIMARY CABLES, BY PULLING A MANDEL THROUGH EACH DUCT/CONDUIT IN EACH DIRECTION, AND THEREAFTER PULLING A STIFF BRISTLE BRUSH WITH SWAB THROUGH THE DUCT/CONDUIT UNTIL DUCT/CONDUIT IS CLEAR OF EARTH, SAND, AND GRAVEL. PROVIDE FOR DE-WATERING OF MANHOLES AS REQUIRED TO COMPLETE INSTALLATION OF NEW PRIMARY CABLES.
- 4. PREPARE EXISTING AND NEW DUCTS/CONDUITS AND MANHOLES SPECIFIED TO RECEIVE NEW SECONDARY WIRES. DE-WATER AND CLEAN EXISTING MANHOLES IDENTIFIED TO RECEIVE NEW SECONDARY WIRES, OF DIRT, DEBRIS, AND ABANDONED CABLES/WIRES. CLEAN EXISTING DUCTS/CONDUITS IDENTIFIED TO RECEIVE NEW SECONDARY WIRES, BY PULLING A MANDREL THROUGH EACH DUCT/CONDUIT IN EACH DIRECTION, AND THEREAFTER PULLING A STIFF BRISTLE BRUSH WITH SWAB THROUGH THE DUCT/CONDUIT UNTIL DUCT/CONDUIT IS CLEAR OF EARTH, SAND, AND GRAVEL. PROVIDE FOR DE-WATERING OF MANHOLES AS REQUIRED TO COMPLETE INSTALLATION OF NEW SECONDARY WIRES.
- 5. PREPARE EXISTING AND NEW DUCTS/CONDUITS AND MANHOLES FOR USE BY TELEPHONE AND CATV SERVICE PROVIDERS. DE-WATER AND CLEAN EXISTING COMMUNICATIONS MANHOLES IDENTIFIED FOR TELEPHONE AND CATV SERVICE PROVIDER USE, OF DIRT, DEBRIS, AND ABANDONED CABLES. EXISTING DUCTS/CONDUITS AND MANHOLES MAY CONTAIN ACTIVE TELEPHONE CABLES. COORDINATE CLEANING ACTIVITIES WITH TELEPHONE SERVICE PROVIDER SO THAT ACTIVE TELEPHONE CABLES ARE IDENTIFIED, PROTECTED, REMAIN UNDAMAGED, AND REMAIN IN SERVICE. CLEAN EXISTING DUCTS/CONDUITS IDENTIFIED FOR TELEPHONE AND CATV SERVICE PROVIDER USE BY PULLING A MANDREL THROUGH EACH DUCT/CONDUIT IN EACH DIRECTION, AND THEREAFTER PULLING A STIFF BRISTLE BRUSH WITH SWAB THROUGH THE DUCT/CONDUIT UNTIL DUCT IS CLEAR OF EARTH, SAND, AND GRAVEL. PROVIDE FOR DE-WATERING OF MANHOLES AS REQUIRED FOR TELEPHONE AND CATV SERVICE PROVIDERS TO COMPLETE THEIR WORK INSIDE THE MANHOLE. PROVIDE PULL ROPES FOR TELEPHONE AND CATV SERVICE PROVIDER USE, IN EACH DUCT/CONDUIT IDENTIFIED FOR TELEPHONE AND CATV SERVICE PROVIDER USE. WHERE CABLE ROUTING HAS BEEN LEFT TO THE DISCRETION OF THE TELEPHONE AND CATV SERVICE PROVIDERS, COORDINATE FINAL CABLE ROUTING IN THE FIELD WITH THE TELEPHONE AND CATV SERVICE PROVIDERS, COORDINATE FINAL CABLE ROUTING IN THE FIELD WITH THE TELEPHONE AND CATV SERVICE PROVIDERS, COORDINATE

### **KEY NOTES:**

- 1 UTILITY EASEMENT SHOWN MAY BE USED BY TELEPHONE AND CATV SERVICE PROVIDERS TO BRING TELEPHONE AND CATV SERVICES TO SITE.
- 2) EXISTING UNDERGROUND UTILITY DUCT BANK CONTAINING COMMUNICATIONS CONDUITS. UTILITY SERVICE PROVIDERS MAY, AT THEIR OPTION AND RISK, USE THESE CONDUITS TO BRING TELEPHONE AND CATV SERVICES TO THE SITE.
- 3 PROPOSED OVERHEAD PRIMARY ELECTRICAL POWER DISTRIBUTION TO BE PROVIDED BY ELECTRICAL POWER UTILITY SERVICE PROVIDER.
- (4) PROPOSED LOCATION FOR UTILITY POLE WITH GUYS AS REQUIRED TO BE PROVIDED BY ELECTRICAL POWER UTILITY SERVICE PROVIDER.
- 5 PROPOSED LOCATION FOR UTILITY POLE WITH PRIMARY METERING, TO BE PROVIDED BY ELECTRICAL POWER UTILITY SERVICE PROVIDER.
- PROPOSED LOCATION FOR UTILITY POLES WITH SERVICE DROPS, TO BE PROVIDED BY ELECTRICAL POWER UTILITY SERVICE PROVIDER.
- PROVIDE DUCT BANK, ONE ACTIVE AND ONE SPARE CONDUIT, BETWEEN UTILTY POLE AND PRIMARY MANHOLE FOR PRIMARY SWITCH "A" SERVICE DROP. PROVIDE PRIMARY SERVICE CABLES IN ACTIVE CONDUIT. STUB ACTIVE CONDUIT UP POLE TO HEIGHT SPECIFIED BO ELECTRIC POWER SERVICE PROVIDER. STUB SPARE CONDUIT UP 6" ABOVE FINAL GRADE, ADJACENT TO UTILITY POLE AND CAP FOR FUTURE USE.
- (8) PROVIDE DUCT BANK, ONE ACTIVE AND ONE SPARE CONDUIT, BETWEEN UTILTY POLE AND PRIMARY MANHOLE FOR PRIMARY SWITCH "B" SERVICE DROP. PROVIDE PRIMARY SERVICE CABLES IN ACTIVE CONDUIT. STUB ACTIVE CONDUIT UP POLE TO HEIGHT SPECIFIED BO ELECTRIC POWER SERVICE PROVIDER. STUB SPARE CONDUIT UP 6" ABOVE FINAL GRADE, ADJACENT TO UTILITY POLE AND CAP FOR FUTURE USE.
- (9A) PROVIDE PRIMARY SWITCHES AS DETAILED.
- (9B) PROVIDE SUBSTATION AS DETAILED.


- $\bigwedge$
- PROVIDE 8'-0" LONG BY 6'-0" WIDE BY 6'-0" HIGH (INSIDE DIMENSIONS) PRECAST CONCRETE MANHOLE WITH 42" CLEAR OPENING DIAMETER HS-20 TRAFFIC LOAD RATED DUCTILE IRON LID/LID FRAME.
- (11) PROVIDE 5'-0" LONG BY 5'-0" WIDE BY 6'-0" HIGH (INSIDE DIMENSIONS) PRECAST CONCRETE MANHOLE WITH 42" CLEAR OPENING DIAMETER HS-20 TRAFFIC LOAD RATED DUCTILE IRON LID/LID FRAMF
- PROVIDE DUCT BANK AS DETAILED. PROVIDE CABLES AND WIRES IN THESE CONDUITS AS
- (13) PROVIDE TWO 4" SCH. 40 PVC CONDUITS BETWEEN UTILITY POLE AND COMMUNICATIONS MANHOLE FOR POSSIBLE USE BY TELEPHONE AND CATY SERVICE PROVIDERS. CONDUITS SHALL BE DIRECT BURIED BELOW GRADE WITH MINIMUM 36" EARTH COVER. STUB CONDUITS UP 6" ABOVE FINAL GRADE ADJACENT TO LITHIUTY POLE AND CAP
- (14) EXISTING UTILITY DUCT BANK CONTAINING VARIOUS COMBINATIONS OF SECONDARY ELECTRICAL POWER AND COMMUNICATIONS CONDUITS. TELEPHONE AND CATV SERVICE PROVIDERS MAY USE THESE CONDUITS TO BRING TELEPHONE AND CATV SERVICES TO PIER COMMUNICATION OUTLET ASSEMBLIES.
- (15) EXISTING UTILITY DUCT BANK CONTAINING VARIOUS COMBINATIONS OF PRIMARY ELECTRICAL POWER, SECONDARY ELECTRICAL POWER AND COMMUNICATIONS CONDUITS. PROVIDE PRIMARY AND SECONDARY ELECTRICAL POWER DISTRIBUTION CABLES AND WIRES IN THESE CONDUITS AS SPECIFIED. TELEPHONE AND CATV SERVICE PROVIDERS SHALL USE THESE CONDUITS TO BRING TELEPHONE AND CATV SERVICES TO PIER COMMUNICATIONS OUTLET ASSEMBLIES.
- (16) EXISTING DUCT BANK CONTAINING TWO 4" PVC CONDUITS, ONE ACTIVE AND ONE SPARE. REWORK EXISTING CONDUITS UP INTO NEW PRIMARY SWITCH AT NEW SUBSTATION. PROVIDE PRIMARY CABLES IN ACTIVE CONDUIT AS SPECIFIED.



- PROVIDE NEW CONCRETE CAP, DIMENSIONS TO MATCH OUTSIDE DIMENSIONS OF EXISTING MANHOLE, AND 42" CLEAR OPENING DIAMETER HS-20 TRAFFIC LOAD RATED DUCTILE IRON LID/LID FRAME ON EXISTING MANHOLE
- $\langle 18 \rangle$  <NOT USED>
- (19) PROVIDE NEW PIER POWER OUTLET IGLOO AS DETAILED TO REPLACE EXISTING IN EXISTING
- EXISTING DUCT BANK CONTAINING EIGHT 4" PVC CONDUITS. REWORK EXISTING CONDUITS UP INTO RECESS BELOW NEW SUBSTATION SECONDARY DISTRIBUTION SECTION AND UP INTO NEW PIER POWER OUTLET IGLOO. PROVIDE SECONDARY WIRES IN EACH CONDUIT AS SPECIFIED.
- (21) PROVIDE NEW PIER POWER OUTLET IGLOO AS DETAILED IN NEW LOCATION.
- $\langle 22 \rangle$  <NOT USED>
- 1
- 23 <NOT USED>
- 24 EXISTING 4" PVC COATED RGS CONDUIT UNDERGROUND. REWORK EXISTING CONDUIT UP INTO NEW LOAD CENTER. EXTEND IN KIND WITH NEW AS REQUIRED. PROVIDE SECONDARY WIRES IN THIS CONDUIT TO SERVE LOAD CENTER AS SPECIFIED.
- PROVIDE NEW PIER LOAD CENTER/TELECOMMUNICATIONS OUTLET ASSEMBLY AS DETAILED TO REPLACE EXISTING.

# KEY NOTES CONT. . .

- EXISTING 4" PVC COATED RGS CONDUIT UNDERGROUND. REWORK EXISTING CONDUIT UP INTO NEW PIER COMMUNICATIONS OUTLET ASSEMBLY. EXTEND EXISTING IN KIND WITH NEW AS REQUIRED. PROVIDE THREE 1¼" OUTDOOR RATED ORANGE INNERDUCT IN THIS CONDUIT, ONE FOR TELEPHONE SERVICE PROVIDER CABLE, ONE FOR CATV SERVICE CABLE, AND ONE FOR BASE COMMUNICATIONS CABLE. EXTEND INNERDUCT UP INTO PIER LC/ TELECOMMUNICATIONS OUTLET ASSEMBLY TO THE RESPECTIVE SERVICE TERMINATION COMPARTMENT. INNERDUCT SHALL BE CONTINUOUS FROM END TO END WITHOUT SPLICE.
- (27) <NOT USED>
- PROVIDE NEW LIGHT POLE ON EXISTING CONCRETE FOUNDATION AS SPECIFIED. FIELD VERIFY BOLT PATTERN BEFORE PLACING ORDER FOR LIGHT POLE.
- EXISTING 2" PVC COATED RGS CONDUIT UNDERGROUND. PROVIDE LIGHTING CIRCUIT WIRES IN THIS CONDUIT AS SPECIFIED.
- (30) <NOT USED>



- PROVIDE TWO 3" PVC COATED RGS CONDUIT UNDERGROUND BETWEEN EXISTING COMMUNICATIONS MANHOLE AND CATV PEDESTAL. CATV SERVICE PROVIDER SHALL USE THIS CONDUIT TO ROUTE CATV CABLES TO/FROM AMPLIFIER.
- 33 PROVIDE RADIO REPORTING TYPE FIRE ALARM MANUAL PULL STATION AS DETAILED.
- (34) PROVIDE MOLE PIER POWER CENTER AS DETAILED.
- PROVIDE PVC COATED RGS CONDUIT UNDERGROUND BETWEEN MOLE PIER POWER CENTER PANEL AND SECONDARY MANHOLE AS FOLLOWS:

2½" FOR SECONDARY WIRES FROM TRANSFORMER T43 AS SPECIFIED.
2" FOR SECONDARY WIRES TO PIER LOAD CENTERS 1A THROUGH 1D AS SPECIFIED.
2" FOR SECONDARY WIRES TO PIER LOAD CENTERS 2A THROUGH 2D AS SPECIFIED.
2" FOR SECONDARY WIRES TO PIER LOAD CENTERS 3A THROUGH 3D AS SPECIFIED.
2" FOR SPARE.

- (36) PROVIDE 1½" PVC COATED RGS CONDUIT UNDERGROUND BETWEEN MOLE PIER POWER CENTER LIGHTING CONTACTOR AND SECONDARY MANHOLE FOR LIGHTING CIRCUIT WIRES AS SPECIFIED.
- (37) PROVIDE 1½" PVC COATED RGS CONDUIT UNDERGROUND BETWEEN MOLE PIER POWER CENTER PANEL AND MOLE LIFT STATION CONTROL PANEL FOR SECONDARY CIRCUIT WIRES.
- (38) PROVIDE 1" PVC COATED RGS CONDUIT UNDERGROUND BETWEEN MOLE PIER POWER CENTER PANEL AND MOLE OWS CONTROL PANEL FOR UNSPECIFIED FUTURE USE. CAP END OF CONDUIT STUBBED UP ABOVE GRADE AT OWS CONTROL PANEL END.
- 739) PROVIDE KWH METER, INCLUDING METER SOCKET, BUSHING MOUNTED CTS, STAINLESS STEEL CT MOUNTING BRACKETS, WIRING AND APPURTENANCES, ON EXISTING TRANSFORMER T43.
  - PROVIDE 1" PVC CONDUIT DIRECT BURIED UNDERGROUND FOR SEWER METER POWER. PROVIDE (1) #12 PH., (1) #12 NEUT. AND (1) #12 GND IN CONDUIT FROM SEWER METER BACK TO PANEL "PRPCP"
  - PROVIDE 17.25" LONG BY 10.5" WIDE BY 12" HIGH (INSIDE DIMENSIONS) PRECAST CONCRETE HANDHOLE WITH H-10 TRAFFIC LOAD RATED CAST IRON LID. LID LEGEND SHALL READ "ELECTRIC".
  - PROVIDE 3" RGS CONDUIT SLEEVE THROUGH WHICH TO INSTALL SEWER METER BRANCH CIRCUIT CONDUIT. INSTALL SLEEVE VIA JACKING METHOD. OPEN SAWCUTTING OR OTHER CONDUIT INSTALLATION METHODS THAT DAMAGE EXISTING PAVEMENT ARE NOT ACCEPTABLE. EXTEND SLEEVE A MINIMUM OF 48" BEYOND FOGE OF PAVEMENT ON FACH SIDE.
  - (43) MAKE BRANCH CIRCUIT CONNECTION TO WATER METER.

# ADENDUM 0005

ADD THE FOLLOWING AT THE END OF KEY NOTE 14: "REMOVE ALL ABANDONED SECONDARY POWER DISTRIBUTION WIRES AND COMMUNICATIONS CABLES FROM CONDUITS CONTAINED WITHIN THIS DUCT BANK. THE CONTRACTOR IS CAUTIONED THAT THERE ARE ACTIVE TELEPHONE CABLES PRESENT THAT THE TELEPHONE SERVICE PROVIDER MAY WISH TO KEEP IN SERVICE. COORDINATE THIS WORK WITH THE TELEPHONE SERVICE PROVIDER."

URS Group, Inc.	7650 West Courtney Campbell Causeway Tampa, FL 33607 NO. 00000002	REVISED PER AMENDMENT 0003 FKW 04/04/03 CRS DSGN KERLY DR KERLY CHK GIANG	PV WALKER CH ENGR WALKER	SMITTED BY : DA	FKW 03/01/05 CRS TECHNICAL BRANCH	ы
	yd.	RS DSC	RS SU	RS SUE	RS TEC	HPE.
	App	103 CI	04 Cl	103 CI	10 S0,	
(0	y Date	04/04/	03/19/	04/11/	03/01/	
SIONS	Prep By	FKW	FKW	FKW	FKW	
REVIS		0003	0000	0005		
DRAWING REVISIONS	Description Prep By Date Apprvd.	REVISED PER AMENDMENT	REVISED PER AMENDMENT 0009 FKW 03/19/04 CRS SUPY WALKER	REVISED PER AMENDMENT 0005 FKW 04/11/03 CRS SUBMITTED BY:	CORRECTED TO AS-BUILT	
	Rev.	-	2	3	4	
KEY WEST, FLORIDA		TRUMAN HARBOR REPAIRS		KEY NOTES FOR DRAWINGS E-10 THROUGH E-13		DATE EFD FOR COMMANDER, NAVFAC
NAVAL AIR FACILITY		YMIIQL	4 E O C C	C L	KEY NOIES FOR	APPROVED
	leering Command	, ;	ern Division		n, South Carolina	

RECORD DRAWING

Facilities

Naval

RECORD DRAWING DATE 1 MARCH 2005
CODE I.D. NO. 80091
DRAWING SIZE: D
SPEC.NO. 06-03-0154
CONSTRN. CONTRN. NO. N62467-03-C-0154
NAVFAC DRAWING NO. 5429469
SHEET 48 OF

E-9

