



ADDENDUM NO. 2
TO THE CONTRACT DOCUMENTS
for the construction of the

Date: April 9, 2014
Project No.: 476166

**NORTH SIMONTON STORMWATER
EMERGENCY OUTFALL**

**CITY OF KEY WEST
KEY WEST, FLORIDA**

To All Planholders and/or Prospective Bidders:

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the construction of the North Simonton Stormwater Emergency Outfall dated March 2014 as fully and completely as if the same were fully set forth therein:

CONTRACTOR QUESTIONS

1. **Question:** In previous storm water projects a combustible gas detector was installed to monitor the wet well atmosphere. Please confirm that no combustible gas detector is required for this project.

Answer: No combustible gas detector is required.

2. **Question:** Drawing E-04 calls for the service entrance disconnect to be 316 stainless steel painted white. The manufacturers do not recommend that 316 stainless steel enclosures be painted because of the problems with the paint adhering to this grade of stainless steel. Please confirm that the main disconnect be painted white.

Answer: The main disconnect is to be painted white.

3. **Question:** The specifications call for the use of Robroy form 8 conduit. Robroy does not make PVC coated conduit. The Robroy brands are Perma-Cote, Plasti-Bond and KorKap. Please confirm that these are acceptable.

Answer: Robroy brands Perma-Cote, Plasti-Bond, and KorKap are acceptable.

4. **Question:** Drawing E-04 calls for a new 400amp generator receptacle to be installed in place of the existing 200amp generator receptacle. There is no mention of replacing the existing 200amp breaker located in the control panel. Please confirm that the existing breaker is to remain and wires to the new 400amp generator receptacle.

Answer: The existing 200 amp breaker will remain and be wired to the new 400 amp generator receptacle.

5. **Question:** We have received RFQ's to supply the generator for the North Simonton Storm Water project. In the current specification, only Detroit Diesel is listed as an approved manufacturer. I would like to see if it is possible to get Kohler approved and please let me know what documentation you would require to do this.

Answer: Detroit Diesel is the only approved generator.

PART 3 – SPECIFICATIONS

Section 26 05 01, Electrical

1. Page 6; paragraph 2.05.A.5 DELETE in its entirety and REPLACE with the following:

“5. Robroy brands Perma-Cote, Plasti-Bond, and KorKap, no substitutions allowed”.

All Bidders shall acknowledge receipt of Addendum No. 2 in the Bid Form. Bids submitted without this acknowledgement will be considered informal.

CH2M HILL

Sean Mc Coy, P.E.

END OF ADDENDUM