



**THE CITY OF KEY WEST**  
3140 Flagler St,  
Key West, Florida 33040

**ADDENDUM #4**  
**Replacement of Tarpon Pier**  
**Invitation to Bid: 12-030**  
**14 September 2012**

This Addendum is issued as supplemental information to the bid package for clarification of certain matters of both a general and a technical nature. The referenced bid package is amended in accordance with the following items:

- Clarification: Sheet 6/9 Hans Wilson & Assoc. Plans. Note on right side of sheet states that the piles to remain are “18” sq mooring piles”. Existing piles to remain are 12” square.
- Clarification TS-6.0: After the epoxy coating has cured per the manufacturers specifications, the epoxy coating pile shall be painted with two coats of a Two-Part Linear Polyurethane (PL) Coat with gray pigmentation from the Mean High Water mark to the top of the pile.
- Domestically Produced Seamless Steel Piling: In the event that the contractor can provide documentation that domestically produced pilings are not available, the City will consider other sources in compliance with Supplementary Condition 6.03.D.2
- Clarification: A portion of Addendum 2 provided clarification on Insurance. Delete this paragraph in addendum 2 and note the following:
  - That Contractors shall provide insurance that complies with the requirements of Paragraph 5.04 of the Supplementary Conditions
  - That additional endorsements covering requirements by USLH and Jones acts shall be provided. Specifically
    1. Longshore and Harbor Workers’ Compensation Act Coverage Endorsement (WC 00 01 06 A)
    2. Maritime Coverage Endorsement (WC 00 02 01 A)
- No Change to the Bid Due Date is a result of this Addendum

All Bidders shall acknowledge receipt and acceptance of this Addendum No 5 by acknowledging Addendum in their proposal or by submitting the addendum with the bid package. Bids submitted without acknowledgement or without this Addendum may be considered non-responsive

---

Signature

---

Name Of Business