



**ADDENDUM 2:
ITB #11-015 RETROFIT LOCAL PARK BALL FIELD LIGHTING**

To all general contract bidders of record on the Work titled:

**RETROFIT LOCAL PARK BALL FIELD LIGHTING
KEY WEST, FLORIDA**

This addendum is issued as supplemental information to the ITB # 11-015 package for clarification of certain matters of both a general and a technical nature. The referenced ITB package is hereby addended in accordance with the following items as fully as completely as if the same were fully set forth therein:



Figure 1 Pepe Hernandez Softball Field, Virginia Street



Figure 2 Nelson English Park, Catherine Street

- **Electrical service points on the 2 locations**
 - **The voltage will be 3 phase 277/480 Y**
 - **Contractor to install riser up pole to KEYS Transformers. Approx height is 25' to be determined at a later date with utility**

END OF ADDENDUM No. 2

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 2 by acknowledging Addendum in their proposal or by submitting the addendum with the bid package. Bids submitted without acknowledgement or without this Addendum may be considered non-responsive.

Signature Name of Business