



PORT & MARINE SERVICES

201 William Street
Key West, FL
33040

ADDENDUM NO. 3

**EXTERIOR SIGNAGE SYSTEM
KEY WEST HISTORIC SEAPORT
ITB #22-009**

The information contained in this Addendum adds information to be included in the Bid and is hereby made a part of the Contract Documents. The referenced bid package is hereby addended in accordance with the following items:

GENERAL NOTES:

1. Mandatory Pre-Bid sign-in sheet attached.

QUESTIONS and CLARIFICATIONS:

1. Per the meeting of 10-11-22 – Footer detail – “Drill Shaft or Spread” Direct bury or steel imbed?

Concrete foundation to designed by the sign fabricators Florida Licensed Engineer

2. Post material – “Greenheart or Gun Barrels”?

Provide post material as specified

3. For ST-A All maps & Add panels to be supplied from Southernmost Signs – is the city buying these direct or are we to purchase them?

Contractor responsible for contracting with Southernmost Signs

4. Will MOT be required or will the city allow cones & Barricades around work sites.

If contractor intends working within the right-of-way MOT would be required. Cones and barricades are adequate for use on Seaport property.

5. Will daytime work hours per permitted?

Yes, daytime work hours are permitted

6. Will Parking spaces be blocked off to all for installation?

Parking spaces may be blocked for installation at entrance of parking lots

7. Can you furnish preferred "Knife Plate" / "Shoe Mount" details.

Attachment to foundation or docks to be designed by the sign fabricators Florida Licensed Engineer

8. For ST-A footer & support please furnish preferred Steel imbed detail.

See response #7

9. What material Samples will be required.

Contractor to provide all finish material samples

All other elements of the Contract and Bid documents, including the Bid Date shall remain unchanged. All Bidders shall acknowledge receipt and acceptance of this **Addendum No. 3** by submitting the addendum with their proposal. Proposals submitted without acknowledgement or without this Addendum may be considered non-responsive.

Signature

Name of Business

