



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3867

ADDENDUM # 2 ITB #13-019 CEMETERY SEXTON'S HOUSE – CE #1002

July 8, 2013

To All Bidders,

The following changes and additions are hereby made a part of Project number CE #1002, Cemetery Sexton's House, as fully and completely as if the same were fully set forth therein:

1. Bid date has been extended to July 17, 2013 at 3:30pm in the City Clerk's Office.
2. Addendum #1: Delete item #6.
3. Specification Division 2C Site Improvements: Delete item c. "New Entrance Gates" in its entirety.
4. Sheet C1: Where new metal fencing is shown on plan, modify and re-use existing fence panels.
5. Sheet E2: Fixture C is 5" dia, not 6" dia. Same fixture otherwise
6. Sheet E2: The fixtures in the Storeroom and interior Bathroom should be "E", not "D".
7. Sheet E2: All ceiling fans should be marked "N", not "G". The fans will be 52" Hunter Classic fans, model 23855 with walnut blades and canopy for 8' ceiling

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 2 by acknowledging Addendum in their proposal or by submitting the addendum with the bid package. Bids submitted without acknowledgement or without this Addendum may be considered non-responsive.

Signature

Name of Business