



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

---

Development Review Committee  
December 16, 2021  
Utilities Comments

**541 White Street  
Amendment to Development Agreement**

No comments.

**541 White Street  
Major Development Plan**

Sanitary Sewer

Please confirm existing pump station has capacity for additional units.  
Please provide existing and additional estimated peak flow to the pump station.

**5537 College Road  
Major Development Plan**

Solid Waste

Please show dimensions for the fence around the solid waste storage area, with the goal of confirming sufficient area for two dumpsters, one for trash and one for recycle materials.

Storm Water Management Plan

Water quantity post minus pre-development is greater than water quality calculation. Please show where additional storm water runoff will be discharged.

Sanitary Sewer

Please coordinate sanitary sewer connection with Key West Resort Utilities.