

## Karen Olson

---

**From:** Gary Centonze <garysplumbing1@aol.com>  
**Sent:** Thursday, May 2, 2024 8:28 PM  
**To:** Karen Olson  
**Cc:** brian@garysplumbingandfire.com; Keri O'Brien; Steven P. McAlearney  
**Subject:** [EXTERNAL] Re: ITB #24-009 Fire Pumps Replacement

**CAUTION:** This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Karen,

Good evening .. yes our bid did include FCAA approved RPDA backflow devices. Please note that our bid also included the FCAA code required Pump Suction Control Valve ( Cla- Valve) for each of the fire pump systems. It was not called out on the bid documents but should have been included in the bidders proposal as a "required" apparatus of a properly functioning system. We listed this on our valuation sheet as part of the bid documents.

Regards

Gary Centonze

Sent from my iPhone

On May 2, 2024, at 4:51 PM, Karen Olson <kolson@cityofkeywest-fl.gov> wrote:

Brian –

You have acknowledged receipt of Addendum #1. This addendum provided a revised bid schedule, which you have not used, that included the addition of backflows for each pump.

Can you verify whether or not your pricing is inclusive of these 4 backflows including all labor, removal & disposal, equipment and materials for a complete installation.

Thanks

***Karen Olson***

Deputy Director  
Port & Marine Services  
(305)809-3803