

# **POLICE STATION WINDOWS REPLACEMENT: ITB NO: 13-003**

## **Addendum No.1**

June 11, 2013

The information contained in this Addendum modifies, supplements, or replaces information contained in the Bid Documents and is hereby made a part of the Contract Documents.

The non-mandatory Pre Bid Meeting, was held June 4, 2013 at 10 AM as scheduled in the bid documents.

The following items are clarifications, deletions, revisions, changes and modifications that change the original Contract Documents only in the amount and to the extent hereinafter specified as ADDENDUM NO.1.

1. Question: Alternate #2 calls for bullet proof glazing at window types C and D. What level of protection is required?

Level 2 protection is required. This results in specialized laminated glazing that is approximately 1" thick.

2. Question: What are the limits of painting around replacement windows and new work including feathered E.I.F.S finish, interior and exterior?

Assume that the exterior finishing (feather into existing and new paint) will require 12" around (4 sides) each opening in addition to the new sand finish stucco surround detailed in the drawings. Match existing color and texture and provide a field sample installation for review by the owner and Architect.

The interior has new wood trim: returns and face trim at each opening. This allows for cutting out the gyp. board and covering the edge without painting the interior walls unless deteriorated (water damaged) gyp. bd. is encountered.

Provide a UNIT PRICE per square yard to remove damaged gyp. bd. from existing metal furring, replace with new matching material (5/8") and finish (tape, float and paint)

Additional items of clarification;

Typical window head detail 2/A-2 calls for a saw cut and 24 ga. flashing across the tops of all window openings, with weeps. Weeps shall be 2" wide. There shall be 2 per window segment (4 weeps at a double window etc.) Weeps shall be placed symmetrically and will be included in the field sample installation discussed above.

### **Attachments; Pre Bid Attendees List**

All other items remain as called for in the documents.  
End of Addendum No. 1

Police Station Windows

6-4-13

SIGN-IN SHEET

NAME	COMPANY	PHONE/FAX	EMAIL
Pablo Arcia	ABC Const.	305-663-0322 305-267-2403	kmeld@abcconstruction.com
MOISES BICHACHI	ELCI CONSTRUCTION	205-891-7990 205-891-7993	moises@elciconstruction.com
Ken Levell	Gary The Carpenter	305 292 0261 305 292 2225	garythecarpenter@cbctmail
Brad Hager	Royal Coast	305-735-4042	brad@royal-coast.com
CHRISTIAN BRISSON	PENRO FALCOU ELECT. CONT.	305-872-2200 2219	cbpkr@bellsouth.net
Ken Bygler	Pedro Falcon	805-872-2200 2219	Kenbygler@bellsouth.net
FRANK TERDISKA	W.P. HICKS ARCH.	805-296-5222	
BILL HORN	WP HORN ARCH.	296-8302	WPHORN@AOL.COM
LES MOUZON	TAGARELLI Const.	813-390-5510 813-626-2951	LMOUZON@ME.COM
ZACK NICHOLS	MAULEY DE BOER LUMBER	305-304-2901	ZACK@MAULEYDEBOER.COM
Rick Williams	CSI Construction	888-931-0125	RVAINO@construction-specialists.com

SIGN-IN SHEET

NAME	COMPANY	PHONE/FAX	EMAIL
CRAIG OVERHOLT	Overholt Construction	305-234-9677 Ph.	COVERHOLT@overholtcc.com
Rachel BeShore	Bella Construction	305 292 9886 305 292 9880	Rachel@concretebella.com