



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

Development Review Committee
October 28, 2021
Utilities Comments

**111 Olivia Street
Major Development Plan**

Solid Waste

Please provide a site plan that shows trash and recycling storage area(s), minimum capacity one 6-yard dumpster or two 4-yard dumpsters.

In accordance with Sec. 108-279, solid waste storage area(s) are required to be screened from adjacent properties and public view.

Storm Water Management Plan

Please adjust, revise location of exfiltration trenches to be constructed on the site, within the parcel boundary.

Sanitary Sewer

Please provide a grease interceptor for the kitchen plumbing system, including the mop sink, three-compartment sink, and kitchen floor drains, in accordance with the Florida Building Code: Plumbing, Chapter 10, Section 1003. Sewer connections to the grease interceptor shall exclude all non-food wastewater flows. (Sec. 74-171)

**927 Catherine Street
Easement**

No comments.

**911 Center Street
Easement**

No comments.