



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

Development Review Committee
November 15, 2018
Utilities Comments

**5610 College Road
Conditional Use**

Stormwater Management System

Pursuant to Sec. 108-777, please provide a stormwater management plan for that retains one-inch of stormwater runoff. Stormwater retention swales shall be planted with ground cover, i.e., sodded, to prevent erosion. Based on the lease area plus parking space, and utilizing a 50% credit for dry retention, 80 cubic feet of treatment volume will be required.

**1020 18th Terrace
Amendment to Conditional Use**
No comments.