

Natalie Hill

From: Scott Fraser
Sent: Friday, May 18, 2018 4:34 PM
To: Natalie Hill
Subject: RE: FLOODPLAIN COMMENTS: DRC Agenda - 5/24/2018

Floodplain Comments:

- **#2 Transient License Transfer - 629 United Street #2**
 - No comments
- **#3 Transient License Transfer - License in Unassigned Status to 805 Shavers Lane**
 - No comments
- **#4 Vacation of City Property - An application for Vacation of City Right-of-Way for an alleyway**
 - No comments
- **#5 Major Development Plan - 638 United Street**
 - Building height appears to be measured from grade rather than required crown-on-road.
- **#6 Minor Development Plan - 3228 Flagler Avenue**
 - Revised plans don't seem to address earlier floodplain comments noted below.
 - Site Data Table, Application page 16
 - Missing flood zone data (AE-8)
 - Missing Design Flood Elevation (DFE) (+9-ft / +9.5-ft for BPAS)
 - Flood Zone, Application page 5
 - Incorrect explanation.
 - This area isn't 8-ft above the Base Flood Elevation (BFE), as stated. Nor is any new development required to be constructed 9.5-ft above the BFE.
 - The Base Flood Elevation for this site is at +8-ft above NGVD (sea level). An Elevation Certificate will establish the height of grade, and thus how high above grade these buildings need to be constructed.
 - The minimum elevation is +9.5-ft above NGVD (sea level).
 - Flood Hazard Areas, Application page 11
 - Incorrectly states this property is located in an X flood zone.
 - It's located in an AE-8 flood zone.
 - Elevation Certificate not found
 - Building Height Certificate not found
 - Plans Page A302 (and any other pages showing elevations)
 - Need elevation drawings where view of ground floor is not obstructed by fencing/non-enclosure walls.
 - Elevation measurement need to be relevant to "NGVD" and labeled as such.
 - Crown of Road (COR) elevation not shown.
 - Overall building height from COR not shown.
 - Ground floor should be labeled as such or "lowest floor," rather than "1st floor." The first finished floor will be the first inhabitable floor.
 - Building appears to exceed maximum overall building height of 40-ft.

- Ground flood enclosure
 - If Building Height Exception is being utilized, the ground floor enclosure is limited to a maximum of 299sf, which appears to have been exceeded.
 - Flood venting will be required. Will need calculations for square-footage of area to be protected and square-inches of flood venting.
 - Each enclosure within an enclosure will need its own flood venting, with separate calculations.
 - If engineered flood vents are utilized, Florida state engineer’s or ICC certification will need to be submitted with application.
 - Vents need to be called-out on plans
 - Flood resistant construction materials need to be listed.
- Question
 - Ground floor: What will be in the equipment room, and how will any electrical equipment be protected from flood conditions?
 - Ground floor: In the Trash & Recycling Area,
 - What do the six squares represent? [Answer: Trash bins. Will clarify.]
- Elevator:
 - Special flood zone requirements, refer to ASCE 24-14, Sections 7.5 & C7.5
 - Also, local ordinance higher standard, default cab return must be above Design Flood Elevation.
- **#7 Conditional Use - 3228 Flagler Avenue**
 - No comments
- **#8 Minor Development Plan & Conditional Use - 1400 Block of Duval Street**
 - Submission comments from application
 - A4 Topography: “This site is flat and at sea level”
 - Not accurate. According to LIDAR, the street elevation is roughly +3-feet above sea level (NGVD)
 - C: High tides resulting in water above street drains doesn’t constitute failure of these drains, as claimed.
 - Section 108-228 Identification of the Persons
 - “Owner: City of Key West”
 - “Owner’s Authorized Agent: Michael Halpern”
 - Don’t understand this relationship. Is Halpern being identified as the City’s Authorized Agent?
 - Key West, Florida has full legal ownership interest it the property.
 - Question whether the State of Florida may also have an interest in the property, given that it’s a pubic way ending at the ocean.
 - 2. On or off-site improvement needs:
 - “Roadway or signalization improvement: none needed”
 - Won’t permanent traffic barricades be necessary?
 - Plans call for curb removal.
 - 3. Onsite amenities proposed...
 - D. Landscape: At this site, such landscaping in the ROW will be repeatedly destroyed by tropical storm activity.
 - Plans Page A0.1
 - Flood Zone incorrect
 - Should read “AE-9, VE-10 & VE-12”
 - Are the two large rectangles in the middle of the street vendor vehicles?

Scott Fraser, CFM - Floodplain Administrator

T: 305-809-3810 | sfraser@cityofkeywest-fl.gov | www.CityofKeyWest-FL.gov/Flood

From: Natalie Hill

Sent: Thursday, May 17, 2018 2:07 PM

To: Alfonso Matthew <Alfonso.Matthew@KeysEnergy.com>; Alison Higgins <ahiggins@cityofkeywest-fl.gov>; Cassandra Jackson <cjackson@cityofkeywest-fl.gov>; Dee Dee Green <dgreen@cityofkeywest-fl.gov>; Elizabeth Ignoffo <eignoffo@cityofkeywest-fl.gov>; Enid Torregrosa <etorregrosa@cityofkeywest-fl.gov>; John Wilkins <jwilkins@cityofkeywest-fl.gov>; Karen DeMaria <kdemaria@cityofkeywest-fl.gov>; Kelly Perkins <kperkins@cityofkeywest-fl.gov>; Kenneth Wardlow <kwardlow@cityofkeywest-fl.gov>; director - Keys Arts <director@keysarts.com>; Maria Abreu <Maria.Abreu@keysenergy.com>; Melissa Paul-Leto <mleto@cityofkeywest-fl.gov>; Patrick Wright <pwright@cityofkeywest-fl.gov>; Rod Delostrinos <rdelostrinos@cityofkeywest-fl.gov>; Rogelio Hernandez <rhernandez@cityofkeywest-fl.gov>; Ron Wampler <rwampler@cityofkeywest-fl.gov>; Scott Fraser <sfraser@cityofkeywest-fl.gov>; Steven P. McAlearney <smcalearney@cityofkeywest-fl.gov>; Steve Torrence <storrence@cityofkeywest-fl.gov>; Thaddeus Calvert <tcalvert@cityofkeywest-fl.gov>; Todd C. Stoughton <tstoughton@cityofkeywest-fl.gov>; Wesley Jones <wjones@cityofkeywest-fl.gov>; Vanessa Sellers <vanessasellers@gmail.com>; Virginia Haller <vhaller@cityofkeywest-fl.gov>; Jeffrey Burgess <jburgess@cityofkeywest-fl.gov>

Subject: DRC Agenda - 5/24/2018

Good Afternoon DRC Members,

The May DRC Agenda is now available for review on the City's website.

Please note that we are expecting a couple of other items to be added to this month's Agenda. They should be available tomorrow for review.

Thank you and have a great day!

<http://keywest.legistar.com/Calendar.aspx>

Respectfully,

Natalie L. Hill

Administrative Assistant II
City of Key West
Planning Department at
Josephine Parker City Hall
1300 White Street
(305) 809-3764
nhill@cityofkeywest-fl.gov
www.cityofkeywest-fl.gov

