Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

Development Review Committee October 24, 2024 Utilities Comments

430 Greene Street EasementNo Comments.

217 Virginia Street Easement
No Comments.

401 South Street EasementNo Comments.

3101 North Roosevelt Boulevard Major Development Plan

Solid Waste

Please provide a site plan showing dimensions for the solid waste storage areas. Minimum dimension for dumpster enclosure is 20 feet wide with 12-foot-wide opening installed with two six-foot wide gates.

Enclosure and orientation of the gates to the roadway must be aligned to allow the licensed hauler truck access to the dumpsters. Location and orientation of the solid waste storage enclosures will need to be confirmed through Waste Management. Adjustment and/or relocation may be necessary.