Development Review Committee Utilities Comments Page 2

610 Duval Street Transfer of Transient Unit License

Parking Spaces

Parking spaces back out onto the right-of-way where there is an existing wall/fence. To protect the existing wall/fence, please install bollard or equal.

Stormwater Management

Swale adjacent to existing tree may be adjusted to prevent impact to tree roots.

Sanitary Sewer

Please coordinate sanitary sewer lateral location and connection to the public sewer system through the Utilities Department.