



CITY OF KEY WEST

1300 White Street, Key West, FL 33040 (305) 809-3700

Invitation to Bid ITB 24-005

City of Key West WWTP Well System Mechanical Integrity Testing Addendum No. 1

January 16, 2024

This addendum is issued to respond to questions received regarding ITB 24-005 for mechanical integrity testing at the Richard A Heyman Environmental Protection Facility.

Questions and Request for Information

1. The specifications mention the Engineer as the City's Representative. That being said, who is going to be responsible for the FDEP compliance standards, recordings, and final report for this MIT?

Response: Engineer of Record, Allen E. Perez, P.E., Perez Engineering and Development, Inc., will be responsible for preparing the deep injection well operating permit renewal application with supporting information, and with the assistance of McNabb Hydrogeologic Consulting, Inc., will provide field observation services and prepare the final report for mechanical integrity testing of IW-1 and IW-2 deep injection wells.

Contractor will be responsible for providing the casing pressure test results, video surveys of casings and visible well bore, high-resolution temperature logs, and radioactive tracer survey to the Engineer of Record and Professional Geologist.

2. Will the contractor have to subcontract residential engineering services to submit the necessary FDEP required documentation and final report?

Response: No. The contractor will not be required to submit documentation to the Florida Department of Environmental Protection. The Engineer of Record, Allen E. Perez, P.E., Perez Engineering and Development, Inc., will be responsible for compiling and providing the required documents to the Florida Department of Environmental Protection.

END OF ADDENDUM NO. 1