



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

---

Development Review Committee  
March 23, 2017  
Utilities Comments

**527 Duval Street  
Easement**  
No comments.

**2310 Staples Avenue  
Lot Split**

Sanitary Sewer

Separate building sewer and point of connection is required for each building structure. (Sec. 74-141)

Please coordinate new sewer connection through the Utilities Department. Costs for installation of the new sewer line shall be the responsibility of the property owner. (Sec. 74-133 and Sec. 74-203)

Solid Waste

Please coordinate any request for trash and recycle carts through the Utilities Department.

Requirements for placement of solid waste receptacles on the right-of-way, such as container weight limit, time of placement, and bulk item pickups, are listed in Section 58-31, City of Key West Code of Ordinances, Chapter 58, Article II.

**1119 White Street  
Minor Development Plan**

Sanitary Sewer

Please provide proof of inspection ticket, dimensions or capacity, for existing grease interceptor.

Solid Waste

Please coordinate trash and recycle service through the city's franchise hauler, Waste Management., Inc. Phone number is 305-296-8297.

**425 Frances Street – 219 Ann Street  
Transient License Transfer**  
No comments.