



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3883

ADDENDUM NO. 1

SMATHERS BEACH BATHROOMS / ITB 17-018

July 20, 2017

This addendum is issued as supplemental information to the bid package for clarification of certain matters of both a general and a technical nature. The referenced Invitation to Bid (ITB) package is hereby amended in accordance with the following items:

Pre-Bid Request for Information:

1.) What is the required elevation of the electrical panel at the bathrooms?

Elevation +14 NGVD

2.) Is the City set on a prefab bathroom or is concrete block acceptable?

See BID ALTERNATE NO. 1 -SITE CONSTRUCTED BATHROOM on page 11 of the PROPOSAL.

3.) Is there a specific pre-fab company to be used?

No, as long as the company bidding this job can demonstrate their (Pre-engineered / Pre-manufactured) bathroom building meets the design intent of the drawings and specifications, all applicable building / code requirements, freight weight limitations on A1A, wave action requirements for VE zone, FEMA flood, etc.

4.) Will use of lights while working on lift station connection at night across South Roosevelt conflict with turtle nesting season.

Contractor will coordinate with "Save-A-Turtle" representative relative to lighting limitations; however, turtle nesting season ends October 31, 2017.

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 with Attachment by submitting the addendum with their proposal. Proposals submitted without acknowledgement or without this Addendum may be considered non-responsive.

Signature

Name of Business