

## Gary Volenec

---

**From:** Ron Wampler  
**Sent:** Tuesday, August 08, 2017 2:11 PM  
**To:** James Bouquet  
**Cc:** Gary Volenec; Enid Torregrosa; Greg Veliz  
**Subject:** FW: Navy Museum  
**Attachments:** IMG\_1442.JPG; ATT00001.txt; IMG\_1439.JPG; ATT00002.txt; IMG\_1438.JPG; ATT00003.txt; IMG\_1437.JPG; ATT00004.txt; IMG\_1436.JPG; ATT00005.txt; IMG\_1435.JPG; ATT00006.txt; IMG\_1432.JPG; ATT00007.txt

The Navy Museum building at Truman Waterfront has been posted 'Unsafe' due to extensive structural spalling of tie-beams and columns. Several load bearing columns have shearing evident at their bases due to initial spalling (see attached photos). The front entry has been posted and the building must be secured from unauthorized entry since it is not habitable and subject to structural failure.

Respectfully,  
Ron Wampler CFM, CBO

-----Original Message-----

**From:** Ron Wampler [mailto:rwampler@cityofkeywest-fl.gov]  
**Sent:** Tuesday, August 08, 2017 12:50 PM  
**To:** Ron Wampler <rwampler@cityofkeywest-fl.gov>  
**Subject:** Navy Museum