



# Permit Details

## City of Key West


**PERMIT NUMBER**  
**BLD2019-0247**

### Description:

Type: <b>MECHANICAL HVAC</b>	Subtype: <b>COMMERCIAL HARC</b>	Status: <b>PERMIT PRINTED</b>	Applied: <b>1/23/2019 GH</b>
Parcel No: <b>00001580-000000</b>	Site Address: <b>409 CAROLINE ST KEY WEST, FL 33040</b>		Approved: <b>2/26/2019 MB</b>
Subdivision:	Block:	Lot:	Issued: <b>2/26/2019 MB</b>
Lot Sq Ft: <b>0</b>	Building Sq Ft: <b>0</b>	Zoning:	Finalized:
Valuation: <b>\$6,500.00</b>	Occupancy Type:	Construction Type:	Expired: <b>2/15/2021 MB</b>
No. Buildings: <b>0</b>	No. Stories: <b>0</b>	No. Unites: <b>0</b>	

Details: **INSTALLATION OF TWO 2-TON DUCTLESS SYSTEMS WITH HEAT. UNITS MOUNTED ON WALL BRACKETS ABOVE FLOOD LEVEL.. N.O.C REQUIRED. HARC INSPECTION. GH**  
**The ground level is 4ft in a AE6 zone plus one foot. Unit to be 3ft to the bottom.**

### Process Summary



Applied to Approved  
 Approved to Issued

### ADDITIONAL SITES

### CHRONOLOGY

### CONDITIONS

### CONTACTS

NAME TYPE	NAME	ADDRESS1	CITY	STATE	ZIP	PHONE	FAX	EMAIL
APPLICANT	CURRY REFRIGERATION AND AC INC	5570 3RD AVE	KEY WEST	FL	33040	(305)294-1164		CURRYAC@BELLSOUTH.NET
CONTRACTOR	CURRY REFRIGERATION AND AC INC	5570 3RD AVE	KEY WEST	FL	33040	(305)294-1164		CURRYAC@BELLSOUTH.NET
OWNER	LKT SERVICES & COMPANIES LLC	199 N TRANQUIL PATH	SPRING	TX	77380	(305)304-4495		
QUALIFIER	CURRY REFRIGERATION AND AC INC	5570 3RD AVE	KEY WEST	FL	33040	(305)294-1164		CURRYAC@BELLSOUTH.NET

### FINANCIAL INFORMATION



# Permit Details

## City of Key West

**PERMIT NUMBER**  
**BLD2019-0247**

DESCRIPTION	ACCOUNT	QTY	AMOUNT	PAID	PAID DATE	RECEIPT #	CHECK #	METHOD	PAID BY	CLTD BY
BUILDING PLAN REVIEW	00100003220000	0	\$10.00	\$0.00						
DBPR SURCHARGE	00100003220000	0	\$2.00	\$0.00						
DEO SURCHARGE	00100003220000	0	\$2.97	\$0.00						
EDUCATION FEE	00100003220000	0	\$2.00	\$0.00						
Total Paid for ADMINISTRATION:			\$16.97	\$0.00						
HARC APPLICATION FEE	00100003240000	0	\$50.00	\$50.00	1/23/19	R8623	8225	CHECK	CURRY REFRIGERATION AND AC INC	GH
HARC INSPECTION FEE	00100003240000	0	\$25.00	\$0.00						
HARC REVIEW FEE	00100003240000	0	\$50.00	\$0.00						
Total Paid for HARC:			\$125.00	\$50.00						
AIR CONDITIONING AND OR HEAT PUMP SYSTEMS	00100003220000	0	\$168.00	\$0.00						
MECHANICAL PLAN REVIEW FEE	00100003220000	0	\$10.00	\$0.00						
Total Paid for MECHANICAL PERMIT:			\$178.00	\$0.00						
TOTALS:			\$319.97	\$50.00						

### INSPECTIONS

### PARENT PROJECTS

### REVIEWS

REVIEW TYPE	REVIEWER	SENT DATE	DUE DATE	RETURNED DATE	STATUS	REMARKS	NOTES
01-PERMIT TECH							



# Permit Details

## City of Key West

**PERMIT NUMBER**  
**BLD2019-0247**

PLANNING	Melissa Paul Leto	1/23/2019	2/12/2019	2/12/2019	APPROVED		need boundary survey, draw on the survey the proposed locations of the ac units. and indicate the setback measurements.
							Emailing you the survey
URBAN FORESTRY	Karen DeMaria	1/23/2019	1/23/2019	1/25/2019	APPROVED		
MECHANICAL	Terry Richardson	1/23/2019	1/23/2019	2/15/2019	CORRECTIONS NEEDED	NOA is for the wrong code addition.	Please submit a currant NOA as per the FBC 6th addition. Fresh air intack as per FBC-Mechanical 403
							Was submitted via email
HARC	Terry Richardson	2/12/2019	2/12/2019	2/12/2019	APPROVED		
		2/12/2019					
MECHANICAL	Terry Richardson	2/26/2019	2/26/2019	2/26/2019	APPROVED		

### BOND INFORMATION

### ATTACHMENTS

Attachment Type	CREATED	OWNER	DESCRIPTION	PATHNAME	SUBDIR	ETRAKIT ENABLED
DOC	1/25/2019	Joelle Deese	bld19-0247_app.pdf	bld19-0247_app.pdf		0
DOC	1/24/2019	Karen DeMaria	409 Caroline AC COndenser slabs.pdf	409 Caroline AC COndenser slabs.pdf		0
DOC	2/12/2019	Melissa Paul Leto	409 Caroline Survey.pdf	409 Caroline Survey.pdf		0