



# Permit Details

## City of Key West


**PERMIT NUMBER**  
**BLD2021-0849**

Description: **ATF CC2020-01335 On hold: 21-0583 pending variance**

Type: <b>PLUMBING</b>	Subtype: <b>RESIDENTIAL</b>	Status: <b>INFORMATION REQUIRED</b>	Applied: <b>3/26/2021 GH</b>
Parcel No: <b>00059580-000200</b>	Site Address: <b>1617 WHITE ST KEY WEST, FL 33040</b>		Approved: <b>3/26/2021 GH</b>
Subdivision:	Block:	Lot:	Issued:
Lot Sq Ft: <b>0</b>	Building Sq Ft: <b>0</b>	Zoning:	Finalized:
Valuation: <b>\$4,500.00</b>	Occupancy Type:	Construction Type:	Expired:
No. Buildings: <b>0</b>	No. Stories: <b>0</b>	No. Unites: <b>0</b>	

Details: **ROUGH AND SET ONE TOILET, ONE LAVATORY, ONE SHOWER, ONE WATER HEATER IN ACCESSORY STRUCTURE. BUILDING CONTRATOR: KW BOYZ BLDG PERMIT#21-0583 (PLANS). N.O.C. REQUIRED. GH**

### Process Summary

 Applied to Approved

### ADDITIONAL SITES

### CHRONOLOGY

### CONDITIONS

### CONTACTS

NAME TYPE	NAME	ADDRESS1	CITY	STATE	ZIP	PHONE	FAX	EMAIL
APPLICANT	SHAWN HUDGINS PLUMBING INC	HUDGINS, SHAWN (QUALIFIER)	KEY WEST	FL	33040	(305)294-6276		SHAWN@SHAWNHUDGINSPLUMBING.COM
CONTRACTOR	SHAWN HUDGINS PLUMBING INC	HUDGINS, SHAWN (QUALIFIER)	KEY WEST	FL	33040	(305)294-6276		SHAWN@SHAWNHUDGINSPLUMBING.COM
OWNER	STEEL CITY MOTOTRS LLC	9925 Jourdan Way	Dallas	TX	75230	(563)529-4223		LINDELGB@GMAIL.COM
QUALIFIER	SHAWN HUDGINS PLUMBING INC	HUDGINS, SHAWN (QUALIFIER)	KEY WEST	FL	33040	(305)294-6276		SHAWN@SHAWNHUDGINSPLUMBING.COM

### FINANCIAL INFORMATION



# Permit Details

## City of Key West

**PERMIT NUMBER**  
**BLD2021-0849**

DESCRIPTION	ACCOUNT	QTY	AMOUNT	PAID	PAID DATE	RECEIPT #	CHECK #	METHOD	PAID BY	CLTD BY
AFTER THE FACT	00100003220000	0	\$250.00	\$0.00						
BUILDING PLAN REVIEW	00100003220000	0	\$10.00	\$0.00						
DBPR-BCAIB-468	00100002080200	0	\$2.00	\$0.00						
DEO-FBC-553	00100002080200	0	\$2.00	\$0.00						
EDUCATION FEE	00100003220000	0	\$2.00	\$0.00						
Total Paid for ADMINISTRATION:			\$266.00	\$0.00						
PLUMBING SITE WORK	00100003220000	0	\$120.00	\$0.00						
Total Paid for PLUMBING:			\$120.00	\$0.00						
TOTALS:			\$386.00	\$0.00						

### INSPECTIONS

### PARENT PROJECTS

### REVIEWS

REVIEW TYPE	REVIEWER	SENT DATE	DUE DATE	RETURNED DATE	STATUS	REMARKS	NOTES
PLUMBING	Terrence Justice	3/26/2021	4/7/2021	4/7/2021	CORRECTIONS NEEDED		No info provided on grinder pump already installed. No info on sewer connection to City lateral. No cleanouts shown.
01-PERMIT TECH	Gerzale Hill	3/26/2021	3/26/2021	3/26/2021	APPROVED		

### BOND INFORMATION

### ATTACHMENTS

Attachment Type	CREATED	OWNER	DESCRIPTION	PATHNAME	SUBDIR	ETRAKIT ENABLED
DOC	3/26/2021	Gerzale Hill	BLD21-0849 APP.pdf	BLD21-0849 APP.pdf		0





# Permit Details

## City of Key West

**PERMIT NUMBER**  
**BLD2021-0849**

ATTACHMENTS						
Attachment Type	CREATED	OWNER	DESCRIPTION	PATHNAME	SUBDIR	ETRAKIT ENABLED
DOC	3/29/2021	Gerzale Hill	Lindle, John _1617 White St. 02-14-2021 Permit Drawings.pdf	Lindle, John _1617 White St. 02-14-2021 Permit Drawings.pdf		0