



City of Key West, FL

City Hall
1300 White Street
Key West FL 33040

Legislation Text

File #: 14-7039, **Version:** 1

Case # 14-1631

Theresa Cioffi

3222 Riviera Drive

a/k/a 1600 Riviera Street

FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured Fuel tank, propane, within a flood zone, below flood level

Officer Scott Fraser

Certified Service: 12-20-2014

Initial Hearing: 1-28-2015

In compliance April 9, 2015, request dismissal

Count 1: For failure to obtain a fuel gas permit and properly secure the tank against buoyancy in accordance with the International Building Code.