



Legislation Details

File #: 2017-96 **Version:** 1 **Name:**

Type: Code Violations **Status:** Passed

File created: 12/30/2016 **In control:** Code Compliance Hearing

On agenda: 1/25/2017 **Final action:** 4/26/2017

Title: Case # 16-667
Daniel J. Dingeman
6 Sunset Key Drive
Sec. 122-990(6)(b) Dimensional requirements
Sec. 14-37 Building permits; professional plans; display of permits; address; exceptions.
Sec. 14-327 Inspection.
Officer Kenneth JW Waite
Certified Service: 12-12-2016
Initial Hearing: 1-25-2017

In compliance April 25, 2017, request dismissal

Count 1: Failure to obtain an after-the-fact permit or an after-the-fact variance as the location of pool pump to the dividing fence is 8 inches and the required minimum setback is 2.5 feet. Count 2: Failure to apply for permits to relocate the pool pump. Count 3: Failure to obtain a mechanical inspection for the pool pump from the City of Key West Building Department.

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
4/26/2017	1	Code Compliance Hearing	Dismissed	
3/29/2017	1	Code Compliance Hearing	Continuance	
1/25/2017	1	Code Compliance Hearing	Continuance	