



### Legislation Details

**File #:** 14-7039      **Version:** 1      **Name:**

**Type:** Code Violations      **Status:** Passed

**File created:** 1/5/2015      **In control:** Code Compliance Hearing

**On agenda:** 1/28/2015      **Final action:** 4/29/2015

**Title:** Case # 14-1631  
Theresa Cioffi  
3222 Riviera Drive  
a/k/a 1600 Riviera Street  
FBC Fuel/Gas 301.11 (ASCE 24-05 Sec. 7.4.1) Unsecured Fuel tank, propane, within a flood zone, below flood level  
Officer Scott Fraser  
Certified Service: 12-20-2014  
Initial Hearing: 1-28-2015

In compliance April 9, 2015, request dismissal

Count 1: For failure to obtain a fuel gas permit and properly secure the tank against buoyancy in accordance with the International Building Code.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:**

Date	Ver.	Action By	Action	Result
4/29/2015	1	Code Compliance Hearing	Dismissed	
3/20/2015	1	Code Compliance Hearing	Continuance	
2/25/2015	1	Code Compliance Hearing	Continuance	
1/28/2015	1	Code Compliance Hearing	Continuance	