



City of Key West, FL

City Hall
1300 White Street
Key West FL 33040

Legislation Text

File #: 13-3804, **Version:** 1

Case # 12-1159

Daniel Soldano
617 Angela Street
Sec. 14-256 Electrical permit required
Sec. 14-262 Request for inspection
Officer Barbara Meizis
Posted: 2-3-2013
Initial Hearing: 2-27-2013

New Case

Continuance denied

Count 1: Temporary electric pole shall be disconnected and permanent connection from house to main pole shall be installed. **Count 2:** Electrical inspection is required.