



Legislation Details

File #: 2017-6 **Version:** 1 **Name:**

Type: Code Violations **Status:** Passed

File created: 12/6/2016 **In control:** Code Enforcement Hearing

On agenda: 12/21/2016 **Final action:** 4/26/2017

Title: Case # 16-1398
 Suzana Dragacevac
 68 Seaside North Court
 FBC 1612.4 [ASCE 24-05] Unprotected Enclosed Structures Below Design Flood Elevation
 Sec. 14-37 Building permits; professional plans; display of permits; address; exceptions - Mechanical
 Sec. 14-37 Building permits; professional plans; display of permits; address; exceptions - Plumbing
 Sec. 14-37 Building permits; professional plans; display of permits; address; exceptions - Electrical
 Sec. 14-262 Requests for inspection, required
 Sec. 66-87 Business tax receipt required
 FBC 1612 & ASCE 24-05 [Sections 7.2, 7.3 & &.4] Plumbing/Electrical/Mechanical
 Installed/Constructed Below Flood
 Officer Scott Fraser
 Hand Served: 1-9-2017
 Initial Hearing: 12-21-2016

In compliance April 10, 2017, fees still due

Count 1: Within a FEMA designated AE-8 flood zone, open area has been enclosed, contrary to flood damage prevention provisions. Count 2: Within a FEMA designated AE-8 flood zone, Respondent did install or allow to be installed, electronic devices/appliances below established flood safety levels. Count 3: Within a FEMA designated AE-8 flood zone, Respondent did install or allow to be installed, plumbing connections and fixtures below established flood safety levels. Count 4: Within a FEMA designated AE-8 flood zone, Respondent did install or allow to be installed, electrical wiring, outlets and fixtures below established flood safety levels. Count 5: Within a FEMA designated AE-8 flood zone, Respondent did energize or allow to be energized, electrical wiring, electrical outlets and fixtures absent the required safety inspections having been requested nor performed, contrary to law and the safety of the general public. Count 6: For failure to obtain a business receipt to rent the second dwelling. Count 7: Within a FEMA designated AE-8 flood zone, Respondent did install or allow to be installed, electrical wiring, outlets, receptacles and plumbing fixtures below established flood safety levels, contrary to the safety of the general public.

Sponsors:

Indexes:

Code sections:

Attachments:

| Date | Ver. | Action By | Action | Result |
|------------|------|--------------------------|----------------|--------|
| 4/26/2017 | 1 | Code Enforcement Hearing | Violation Fine | |
| 3/29/2017 | 1 | Code Enforcement Hearing | Continuance | |
| 12/21/2016 | 1 | Code Enforcement Hearing | Continuance | |